

## TABLE OF CONTENTS

---

### **DIVISION 01 – GENERAL REQUIREMENTS**

Summary of Work.....	01 1100
Electronic Drawings.....	01 1150
Substitution Procedures.....	01 2500
Contract Modification Procedures.....	01 2600
Payment Procedures.....	01 2900
Project Management & Coordination.....	01 3100
Submittal Procedures.....	01 3300
Quality Requirements.....	01 4000
Definitions, References and Regulations .....	01 4200
Temporary Facilities and Controls.....	01 5000
Construction Indoor Air Quality Management.....	01 5719
Product Requirements.....	01 6000
Execution.....	01 7300
Construction and Demolition Waste Management and Disposal.....	01 7419
Closeout Procedures.....	01 7700
Operation and Maintenance Data.....	01 7823
Project Record Documents.....	01 7839
Demonstration and Training.....	01 7900
General Commissioning Requirements.....	01 9113

**- SECTION 01 1100 -**  
**SUMMARY OF WORK**

---

## **PART 1 – GENERAL**

### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### **1.2 SUMMARY**

- A. Section Includes:
  - 1. Project information.
  - 2. Work covered by Contract Documents.
  - 3. Phased construction.
  - 4. Work by Owner.
  - 5. Work under separate contracts.
  - 6. Future work.
  - 7. Purchase contracts.
  - 8. Owner-furnished products.
  - 9. Contractor-furnished, Owner-installed products.
  - 10. Access to site.
  - 11. Coordination with occupants.
  - 12. Work restrictions.
  - 13. Specification and drawing conventions.
  - 14. Miscellaneous provisions.

### **1.3 RELATED REQUIREMENTS**

- A. Section 01 5000 "Temporary Facilities and Controls" for limitations and procedures governing temporary use of Owner's facilities.

### **1.4 PROJECT INFORMATION**

- A. Project Identification: West Valley College – STEM Classroom HVAC Upgrades
  - 1. Project Location: 14000 Fruitvale Avenue, Saratoga, CA 95070.
- B. Owner: West Valley-Mission Community College District.
  - 1. Address: 14000 Fruitvale Ave., Saratoga, CA 95070.

### **1.5 WORK COVERED BY CONTRACT DOCUMENTS**

- A. The Work of Project is defined by the Contract Documents and consists generally of the following:
  - 1. The major components of this scope of work are anticipated to be: 1)**HVAC Renovations and Upgrades** within the West Valley College Science and Math Building, including selective demolition of existing mechanical equipment, ductwork,

pipng, and related components as indicated on the Drawings and in the Specifications. 2) **Installation of New Mechanical Systems**, including new fan coil units, energy recovery ventilators (ERVs), exhaust and supply fans, associated ductwork, hydronic piping, controls, insulation, testing, adjusting, and balancing, as required to serve classrooms, laboratories, offices, and support spaces. 3) **Laboratory Ventilation Improvements**, including modifications to existing fume hood exhaust systems, make-up air systems, and interlocks to support code-compliant laboratory operations. 4) **Electrical and Controls Work** necessary to support new HVAC systems, including new power connections, panels, controls wiring, integration with the Building Automation System (BAS), and coordination with existing electrical infrastructure. 5) **Structural and Miscellaneous Work** required to support new mechanical and electrical equipment, including equipment pads, hangers, supports, penetrations, firestopping, and patching of existing finishes disturbed by the Work. 6) **Fire and Life Safety Scope**, including installation of rolling fire shutters and coordination with fire alarm systems, smoke control requirements, and DSA-approved fire and life safety provisions. 7) **Phased Construction and Occupied Campus Coordination**, with work to be performed in multiple phases to minimize disruption to ongoing campus operations. Construction phasing, sequencing, access restrictions, and work areas shall comply with **Attachment B – Construction Phasing Plan**, which identifies specific phase areas, anticipated sequencing, and periods of concentrated work. Work will occur on an active campus. 8) **Temporary Measures and Protection**, including dust control, noise control, temporary separations, utility outages, and protection of adjacent occupied spaces in accordance with campus requirements and the phasing plan. 9) **Testing, Commissioning, and Closeout**, including system testing, TAB, commissioning services, training, and delivery of complete record documentation, warranties, and closeout submittals. The commissioning agent will be hired by the district to support commissioning efforts.

- B. Type of Contract: Project will be constructed under a single prime contract.
- C. The Work includes all labor, materials and equipment necessary for the Contractor to fulfill all of its obligations pursuant to the Contract Documents, including but not limited to:
  - 1. Home office overhead.
  - 2. Off-site supervision.
  - 3. Project administration including preparation, research and distribution of project correspondence and submittals.
  - 4. Schedule preparation and maintenance.
  - 5. Guarantees and warranties.
  - 6. Temporary protection.
  - 7. Temporary utilities and facilities, including mobilization and demobilization.
    - a. Contractor to supply portable restrooms to support work operations.
  - 8. Material handling and storage.
  - 9. Safety equipment.
  - 10. Travel time to and from the Site to the Contractor's home office.
- D. Sequence the Work subject to the Owner's use of the site, the requirements of the Construction Phasing, Technical Specifications and the Contract provisions for Time of Completion found elsewhere in these documents.

- E. Provide materials and perform work indicated or required to produce finished results shown.
- F. Contractor shall coordinate all work and shall be responsible for division of work among the various subcontractors.
  - 1. Coordinate the work of this Contract with the activities of the Owner, local agencies and serving utilities.
- G. Laws, Codes and Regulations: Intent of the Contract Documents is to construct the Work shown therein, in accordance with applicable laws, codes and regulations.

#### **1.6 WORK BY OWNER**

- A. General: Cooperate fully with Owner so work may be carried out smoothly, without interfering with or delaying work under this Contract or work by Owner. Coordinate the Work of this Contract with work performed by Owner.

#### **1.7 WORK UNDER SEPARATE CONTRACTS**

- A. General: Cooperate fully with separate contractors so work on those contracts may be carried out smoothly, without interfering with or delaying work under this Contract or other contracts. Coordinate the Work of this Contract with work performed under separate contracts.
- B. Owner reserves the right to issue other contracts for work on the site which may be constructed concurrently with these Contracts.
- C. Hazardous materials removal or abatement will be performed by the Owner's separate contractor.
  - 1. This work will be performed concurrently with this contract in the event that hazardous materials are encountered.
  - 2. Notify the Owner as described in the General Conditions.
  - 3. These Contract Documents do not contain necessary components for removal or abatement of hazardous material.

#### **1.8 OWNER-FURNISHED PRODUCTS**

- A. Owner will furnish products indicated. The Work includes receiving, unloading, handling, storing, protecting, and installing Owner-furnished products and making building services connections.
- B. Owner-Furnished Products: As shown on the Drawings and as specified.

#### **1.9 ACCESS TO SITE**

- A. General: Contractor will have full use of Project site for construction operations during construction period. Contractor's use of Project site is limited only by Owner's right to perform work or to retain other contractors on portions of Project.
- B. Do not unreasonably encumber the site with materials or equipment. Confine stockpiling of materials and location of storage sheds to area approved by the Architect. If additional storage is necessary, Contractor shall obtain and pay for such storage off site without additional expense to the Owner.

1. Move stored products, temporary facilities, controls or fencing, under Contractor's control, which interfere with operations of the Owner or separate contractors, on or off the site, without cost to the Owner.
  2. Do not overload structures with weight that will endanger them.
- C. Assume full responsibility for protection and safekeeping of materials and tools stored at the site. Lock vehicles such as passenger cars and trucks and other mechanized or motorized construction equipment, when parked and unattended to prevent unauthorized use. Do not leave such vehicles or equipment unattended with the motor running or the ignition key in place.
- D. Perform site access activities, including arrival and departure of workers, deliveries, storing, handling and removal of materials, equipment, and debris to minimize dust, mud or accumulated debris, or undue interference with the convenience, sanitation or routine of Owner's activities.
- E. Time and coordinate cutovers and connection of new utilities to existing systems and other similar activities to avoid interference with or interruption of Owner's activities.
- F. Protect existing finished work remaining in place from damage due to construction activities. Repair and replace finished work damaged by activities of this contract to match adjacent undamaged work to the satisfaction of Owner and Architect at no extra cost to the Owner.
1. Protect improvements on adjoining properties as well as those on the Owner's property.
  2. Restore all improvements damaged by this work to their original condition as acceptable to the owner of the improvement.
- G. Assume responsibility for safety and support of structures. Cease operations and notify Architect immediately if safety of structure appears to be endangered. Take precautions to properly support structure. Do not resume operations until safety is restored. Assume liability for such movement, settlement, damage or injury.
- H. Provide, erect and maintain barricades and guard rails as required by governing regulatory agencies to protect workers. Refer to other pertinent sections of Division 01.

### **1.10 COORDINATION WITH OCCUPANTS**

- A. Owner Limited Occupancy of Completed Areas of Construction: Owner reserves the right to occupy and to place and install equipment in completed portions of the Work, prior to Substantial Completion of the Work, provided such occupancy does not interfere with completion of the Work. Such placement of equipment and limited occupancy shall not constitute acceptance of the total Work.
1. Architect will prepare a Certificate of Substantial Completion for each specific portion of the Work to be occupied prior to Owner acceptance of the completed Work.
  2. Obtain a Certificate of Occupancy from authorities having jurisdiction before limited Owner occupancy.
  3. Before limited Owner occupancy, mechanical and electrical systems shall be fully operational, and required tests and inspections shall be successfully completed. On occupancy, Owner will operate and maintain mechanical and electrical systems serving occupied portions of Work.

4. On occupancy, Owner will assume responsibility for maintenance and custodial service for occupied portions of Work.

### 1.11 WORK RESTRICTIONS

- A. Work Restrictions, General: Comply with restrictions on construction operations.
  1. Comply with limitations on use of public streets and with other requirements of authorities having jurisdiction.
- B. On-Site Work Hours: Limit work on-site to normal business working hours, Monday through Friday, unless otherwise indicated.
  1. Weekend and Early Morning Hours: Restrictions on times permitted in accordance with regulations by authorities having jurisdiction for restrictions on noisy work.
  2. Hours for Utility Shutdowns: Per Owner's restrictions.
  3. Hours for Core Drilling and noisy activity: Per Owner's restrictions and regulations by authorities having jurisdiction for restrictions on noisy work.
- C. Noise, Vibration, and Odors: Coordinate operations with Owner that may result in high levels of noise and vibration, odors, or other disruption to neighboring properties.
  1. Notify Architect not less than two days in advance of proposed disruptive operations.
  2. Obtain Architect's written permission before proceeding with disruptive operations.

### 1.12 CORRELATION AND INTENT

- A. Correlation and Intent: Contract Documents are Complementary and Inclusive.
  1. The Contract Documents are complementary and are intended to include all items required for the proper execution and completion of the Work.
  2. All items of work mentioned in the Specifications and not shown on the Drawings, or shown on the Drawings and not mentioned in the Specifications, shall be provided by Contractor as if shown or mentioned in both.
- B. Coverage of the Drawings and Specifications:
  1. The Drawings and Specifications generally describe the work to be performed by Contractor. Generally, the Specifications describe work which cannot be readily indicated on the Drawings and indicate types, qualities, and methods of installation of the various materials and equipment required for the Work.
  2. It is not intended to mention every item of Work in the Specifications, which can be adequately shown on the Drawings, or to show on the Drawings all items of Work described or required by the Specifications even if they are of such nature that they could have been shown.
- C. Provide all materials or labor for Work, which is shown on either by the Drawings or the Specifications (or is reasonably inferable as necessary to complete the Work), whether or not the Work is expressly covered in either the Drawings and/or the Specifications.
- D. Work is intended to be of sound, quality construction. Include adequate amounts to cover installation of all items indicated, described, or implied in Contract Documents.
- E. Conflicts. In the event there is a discrepancy between the various Contract Documents, the Owner/Contractor Agreement shall control. Without limiting Contractor's obligation to identify

conflicts for resolution by the Architect identified elsewhere in this Article it is intended that the more stringent, higher quality, and greater quantity of Work shall apply.

F. Conformance with Laws:

1. Each and every provision of law required by law to be inserted in this Contract shall be deemed to be inserted herein, and the Contract shall be read and enforced as though it were included herein, and if through mistake or otherwise any such provision is not inserted, or is not correctly inserted, then upon application of either party the Contract shall be amended in writing to make such insertion or correction.
2. Before commencing any portion of the Work, Contractor shall check and review the Contract Documents for such portion for conformance and compliance with all laws, ordinances, codes, rules and regulations of all governmental authorities and public utilities affecting the construction and operation of the physical plant of the Project, all quasi- governmental and other regulations affecting the construction and operation of the physical plant of the Project, and other special requirements, if any, designated in the Contract Documents.
3. In the event Contractor observes any violation of any law, ordinance, code, rule or regulation, or inconsistency with any such restrictions or special requirements of the Contract Documents, Contractor shall immediately notify Architect in writing of same and shall cause to be corrected any such violation or inconsistency in the manner provided hereunder.

G. Ambiguity:

1. Before commencing any portion of the Work, carefully examine all Drawings and Specifications and other information as to materials and methods of construction and other Project requirements.
2. Immediately notify Owner and Architect of any perceived or alleged error, inconsistency, ambiguity, or lack of detail or explanation in the Drawings and Specifications in the manner provided herein.
3. If the Contractor or its Subcontractors, material or equipment suppliers, or any of their officers, agents, and employees performs, permits, or causes the performance of any Work under the Contract Documents, which it knows or should have known to be in error, inconsistent, or ambiguous, or not sufficiently detailed or explained, Contractor shall bear any and all costs arising, including, without limitation, the cost of correction without increase or adjustment to the Contract Price or the time for performance.
4. If Contractor performs, permits, or causes the performance of any Work under the Contract Documents prepared by or on behalf of Contractor which is in error, inconsistent or ambiguous, or not sufficiently detailed or explained, Contractor shall bear any and all resulting costs, including, without limitation, the cost of correction, without increase to or adjustment in the Contract Price or the time for performance.
5. In no case shall any Subcontractor proceed with the Work if uncertain without the Contractor's written direction and/or approval.

### 1.13 SPECIFICATION AND DRAWING CONVENTIONS

- A. Specification Content: The Specifications use certain conventions for the style of language and the intended meaning of certain terms, words, and phrases when used in particular situations. These conventions are as follows:

1. Imperative mood and streamlined language are generally used in the Specifications. The words "shall," "shall be," or "shall comply with," depending on the context, are implied where a colon (:) is used within a sentence or phrase.
2. Specification requirements are to be performed by Contractor unless specifically stated otherwise.
3. Titles. The Specifications are separated into titled sections for convenience only and not to dictate or determine the trade or craft involved.
4. As Shown, Etc. Where "as shown," "as indicated," "as detailed," or words of similar import are used, reference is made to the Drawings accompanying the Specifications unless otherwise stated. Where "as directed," "as required," "as permitted," "as authorized," "as accepted," "as selected," or words of similar import are used, the direction, requirement, permission, authorization, approval, acceptance, or selection by Architect is intended unless otherwise stated.
5. Provide. "Provide" means "provided complete in place," that is, furnished, installed, tested, and ready for operation and use.
6. General Conditions. The General Conditions and supplementary general conditions are a part of each and every section of the Specifications.
7. Abbreviations.
  - a. In the interest of brevity, the Specifications are generally written in an abbreviated form in the imperative tense and may not include complete sentences.
  - b. Omission of words or phrases such as "Contractor shall," "shall be," etc., are intentional. Nevertheless, the requirements of the Specifications are mandatory and directed to the Contractor.
  - c. Omitted words or phrases shall be supplied by inference in the same manner as they are when a "note" occurs on the Drawings.
8. Plural. Words in the singular shall include the plural whenever applicable or the context so indicates.
9. Metric. The Documents may indicate metric units of measurement as a supplement to U.S. customary units. When indicated thus: 1 inch (25 mm), the U. S. customary unit is specific, and the metric unit is nonspecific. When not shown with parentheses, the unit is specific. The metric units correspond to the "International System of Units" (SI) and generally follow ASTM E 380, "Standard for Metric Practice."
10. Reference Standard Specifications. All references to standard specifications of a society, institute, association, or governmental authority is a reference to the organization's reference standard specifications, which are in effect at the date of the Contractor's proposal, or effective date as required by governing codes.
  - a. If applicable specifications are revised prior to completion of any part of the Work, the Contractor may, if acceptable to Architect, perform such Work in accordance with the revised specifications.
  - b. The standard specifications, except as modified in the Specifications for the Project, shall have full force and effect as though printed in the Specifications. Architect will furnish, upon request, information as to how copies of the standard specifications referred to may be obtained.
  - c. Procurement of reference standards and standard specifications is the sole responsibility of the Contractor.
11. Absence of Modifiers. In the interest of brevity, the Contract Documents frequently omit modifying words such as "all" and "any" and articles such as "the" and "an," but the fact that a modifier or an article is absent from one statement and appears in another shall not affect the interpretation of either statement.

B. Rules of Document Interpretation

1. In the event of conflict or ambiguity within the drawings, the following rules shall apply:
    - a. General Notes, when identified as such, shall be incorporated into other portions of Drawings.
    - b. Schedules, when identified as such, are complementary with other notes and other portions of Drawings including those identified as General Notes.
    - c. Larger scale drawings shall take precedence over smaller scale drawings.
    - d. General or Typical Details and Symbols apply at all locations where specifically noted; at all locations conforming to the title of the Detail; at all locations of similar or identical graphic indication; at all locations where similar conditions are not fully or specifically shown or identified and complement similar details of specific conditions.
    - e. Details and Notes apply at all locations of similar or identical graphic indications and at all locations where similar conditions are not fully or specifically shown or identified.
    - f. Limitation of Indication does not affect Extent of Application: Indications of notes, details, and symbols may be limited to promote clarity. No limitation of application is intended nor shall be construed unless specifically noted.
  2. Figured, derived, or numerical dimensions shall govern. At no time shall the Contractor base construction on scaled drawings.
  3. Specifications shall govern as to materials, workmanship, and installation procedures.
  4. In the case of disagreement or conflict between or within standards, specifications, and drawings, the more stringent, higher quality, and greater quantity of Work shall apply.
- C. Division 01 General Requirements: Requirements of Sections in Division 01 apply to the Work of all Sections in the Specifications.
- D. Drawing Coordination: Requirements for materials and products identified on Drawings are described in detail in the Specifications. One or more of the following are used on Drawings to identify materials and products:
1. Terminology: Materials and products are identified by the typical generic terms used in the individual Specifications Sections.
  2. Abbreviations: Materials and products on Drawings may be identified by abbreviations scheduled on Drawings.
  3. Keynoting: Materials and products are identified by reference keynotes referencing Specification Section numbers or terminology found in this Project Manual.
  4. The Drawings, General provisions of the Contract, including General and Supplementary Conditions and other Division 01 specifications apply to the Work of all specifications sections as if specifically reproduced therein.

#### **1.14 EXISTING CONDITIONS**

- A. Intent of the Drawings is to show existing conditions with information developed from field surveys and Owner's records, and to generally show the extent and type of work required to prepare the existing areas for new work. The information shown on the Drawings is not a guarantee of existing conditions.

#### **1.15 CONTRACT COMPLETION**

- A. Date of Completion and Beneficial Occupancy is defined as the Date of Completion of all punch list items, including, but not limited to the following:

PROJECT NO.  
#CA23-2526

STEM Classroom HVAC Upgrades  
WEST VALLEY COLLEGE, SARATOGA, CA

1. Confirmation of mechanical and electrical systems testing and balancing, control sequences and operations.
  2. Completion of final cleaning, paint touch-up and adjusting.
  3. Adjustment and Contractor's certification of the finish hardware operation.
  4. Removal of Contractor's temporary facilities and materials.
  5. Owner's acceptance of the Work.
  6. Certificate of Occupancy issued by the Authority Having Jurisdiction.
- B. Owner's occupancy prior to completion of any or all of the above items, or other such missing or incomplete work as may occur, shall not be construed as acceptance of the Work or as Completion.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

**- SECTION 01 1150 -**  
**ELECTRONIC DRAWINGS**

---

**PART 1 – GENERAL**

**1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.2 SUMMARY**

- A. The Architect-Engineer, if requested, will provide the General Contractor with a one-time electronic copy of the Contract Document Drawings limited to Plan sheets and Exterior Building Elevations for distribution to subcontractors and suppliers. Release of other sheets will be at the sole discretion of the Architect.
  - 1. The Architect nor its' consultants assume any liability for such usage of these electronic files.
- B. The electronic copy will be provided via electronic file transfer in AutoCad 2014 format, or later.

**1.3 REFERENCES**

- A. A copy of the Agreement is included at the end of this Section.

**PART 2 – PRODUCTS (NOT USED)**

**PART 3 – EXECUTION**

**3.1 EXECUTION**

- A. Contractor shall provide signed agreement to the Architect prior to receiving delivery of the electronic drawing files.

**- END OF SECTION -**

# AN AGREEMENT BETWEEN ARCHITECT / ENGINEER OF RECORD AND CONTRACTOR FOR TRANSFER OF COMPUTER AIDED DRAFTING (CAD) FILES ON ELECTRONIC MEDIA

Architect / Engineer of Record (AER): \_\_\_\_\_

Contractor: \_\_\_\_\_

Address: \_\_\_\_\_

Date: \_\_\_\_\_

Project Name: \_\_\_\_\_

Location: \_\_\_\_\_

The AER will provide the following CAD files, dated \_\_\_\_\_, for the convenience of the contractor in preparing shop fabrication drawings:

---

Drawings were prepared on the following:

Computer Software: \_\_\_\_\_ Version: \_\_\_\_\_

Contract Document Drawings provided are limited to Plan sheets and Exterior Building Elevations. Sheets will be released at the sole discretion of the AER.

## TERMS AND CONDITIONS:

1. AER makes no representation as to the compatibility of the CAD files with any hardware or software.
2. Since the information set forth on the CAD files can be modified unintentionally or otherwise, the AER reserves the right to remove all indicia of its ownership and/or involvement from each electronic display. This media should not be considered a certified document.
3. All information on the CAD files is considered instruments of service of the AER and shall not be used for other projects, for additions to this project, or completion of this project by others. CAD files shall remain the property of the AER, and in no case shall the transfer of these files be considered a sale.
4. AER makes no representation regarding the accuracy, completeness, or permanence of CAD files, nor for their merchantability or fitness for a particular purpose. Addenda information or revisions made after the date indicated on the CAD files may not have been incorporated. In the event of a conflict between the AER's sealed Contract Drawings and CAD files, the sealed Contract Drawings shall govern. It is the Contractor's responsibility to determine if any conflicts exist. The CAD files shall not be considered to be Contract Documents as defined by the General Provisions of the Contract for Construction.
5. The use of CAD files prepared by the AER shall not in any way obviate the Contractor's responsibility for the proper checking and coordination of dimensions, details, member sizes and

gage, and quantities of materials as required to facilitate complete and accurate fabrication and erection.

6. The Contractor shall, to the fullest extent permitted by law, indemnify, defend and hold harmless the AER, and its sub-consultants from all claims, damages, losses, expenses, penalties and liabilities of any kind, including attorney's fees, arising out of or resulting from the use of the CAD files by the Contractor, or by third party recipients of the CAD files from the Contractor.
7. The AER believes that no licensing or copyright fees are due to others on account of the transfer of the CAD files, but to the extent any are, the Contractor will pay the appropriate fees and hold the AER harmless from such claims.
8. Any purchase order number provided by the Contractor is for Contractor's accounting purposes only. Purchase order terms and conditions are void and are not a part of this Agreement.
9. Payment of the service fee is due upon receipt of the CAD files.
10. This Agreement shall be governed by the laws of the principal place of business of the AER.

**AUTHORIZED ACCEPTANCE**

**By Architect / Engineer Of Record**

**By Contractor**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Title

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

\_\_\_\_\_  
Date

## - SECTION 01 2500 - SUBSTITUTION PROCEDURES

---

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for substitutions.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 6000 "Product Requirements" for requirements for submitting comparable product submittals for products by listed manufacturers.

#### 1.4 DEFINITIONS

- A. Substitutions: Changes in products, materials, equipment, and methods of construction from those required by the Contract Documents and proposed by Contractor.
  - 1. Substitutions for Cause: Changes proposed by Contractor that are required due to changed Project conditions, such as unavailability of product, regulatory changes, or unavailability of required warranty terms.
  - 2. Substitutions for Convenience: Changes proposed by Contractor or Owner that are not required in order to meet other Project requirements but may offer advantage to Contractor or Owner.

#### 1.5 ACTION SUBMITTALS

- A. Substitution Requests: Submit three copies of each request for consideration. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
  - 1. Substitution Request Form: Use facsimile of form provided in Project Manual.
  - 2. Documentation: Show compliance with requirements for substitutions and the following, as applicable:
    - a. Statement indicating why specified product or fabrication or installation cannot be provided, if applicable.
    - b. Coordination information, including a list of changes or revisions needed to other parts of the Work and to construction performed by Owner and separate contractors, that will be necessary to accommodate proposed substitution.
    - c. Detailed comparison of significant qualities of proposed substitution with those of the Work specified. Include annotated copy of applicable Specification Section. Significant qualities may include attributes such as performance, weight, size, durability, visual effect, sustainable design characteristics, warranties, and specific features and requirements indicated. Indicate deviations, if any, from the Work specified.

- d. Product Data, including drawings and descriptions of products and fabrication and installation procedures.
  - e. Samples, where applicable or requested.
  - f. Certificates and qualification data, where applicable or requested.
  - g. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners.
  - h. Material test reports from a qualified testing agency indicating and interpreting test results for compliance with requirements indicated.
  - i. Research reports evidencing compliance with building code in effect for Project, from ICC-ES.
  - j. Detailed comparison of Contractor's construction schedule using proposed substitution with products specified for the Work, including effect on the overall Contract Time. If specified product or method of construction cannot be provided within the Contract Time, include letter from manufacturer, on manufacturer's letterhead, stating date of receipt of purchase order, lack of availability, or delays in delivery.
  - k. Cost information, including a proposal of change, if any, in the Contract Sum.
  - l. Contractor's certification that proposed substitution complies with requirements in the Contract Documents except as indicated in substitution request, is compatible with related materials, and is appropriate for applications indicated.
  - m. Contractor's waiver of rights to additional payment or time that may subsequently become necessary because of failure of proposed substitution to produce indicated results.
  - n. Written certification by the proposer that the Substitution is equal or better in every respect to that required by the contract Documents and that substitution will perform adequately in the application intended.
  - o. Written certification that the proposer will pay for all permits, fees, and costs required to implement the substitution, and including waiver of all claims for additional costs or time extension which may subsequently become apparent, and reimbursement of Owner and Architect for review or redesign services associated with re-approval by authorities.
3. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within seven days of receipt of a request for substitution. Architect will notify Contractor, through Construction Manager, of acceptance or rejection of proposed substitution within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
- a. Forms of Acceptance: Change Order, Construction Change Directive, or Architect's Supplemental Instructions for minor changes in the Work.
  - b. Use product specified if Architect does not issue a decision on use of a proposed substitution within time allocated.
- B. Specific Requirements:
1. Substitutions shall not alter the weight, point loads, or load distribution of specified equipment or assemblies without written approval. Where structural calculations, framing design, or load capacity assumptions are based on the weight of specified products, any proposed substitution shall meet or be less than the specified product's weight and load characteristics. If a proposed substitution exceeds the specified product's weight, introduces different loading conditions, or otherwise affects structural performance, the following shall apply:
    - a. The substitution request shall include documented weight data and comparison to the specified product.

- b. The Contractor shall submit revised structural calculations, prepared and stamped by a California-licensed Structural Engineer, demonstrating compliance with the project's structural design criteria.
- c. The Contractor shall be solely responsible for all additional structural modifications, redesign, reinforcement, coordination, permitting, construction costs, schedule impacts, and required re-approvals resulting from the substitution.
- d. Substitutions resulting in increased structural loads may be rejected at the Owner's sole discretion, even if structural adequacy can be demonstrated.

Acceptance of a substitution does not relieve the Contractor of responsibility for full compliance with the Contract Documents, applicable codes, and performance requirements.

## 1.6 QUALITY ASSURANCE

- A. Compatibility of Substitutions: Investigate and document compatibility of proposed substitution with related products and materials. Engage a qualified testing agency to perform compatibility tests recommended by manufacturers.

## 1.7 PROCEDURES

- A. Coordination: Revise or adjust affected work as necessary to integrate work of the approved substitutions.

# PART 2 – PRODUCTS

## 2.1 SUBSTITUTIONS

- A. Substitutions for Cause: Submit requests for substitution immediately on discovery of need for change, but not later than 15 days prior to time required for preparation and review of related submittals.
  1. Conditions of Consideration: Architect will consider requests for substitution for cause only when one or more of the following conditions are met and documented:
    - a. Specified item fails to comply with regulatory requirement.
    - b. Specified item is no longer manufactured.
    - c. Specified item, through no fault of the Contractor, unavailable in the time frame required to meet project schedule.
    - d. Specified item, through subsequent information disclosure, will not perform properly or fit in designated space.
    - e. Manufacturer declares specified product to be unsuitable for use intended or refuses to warrant installation of product,
    - f. Substitution would be, in the sole judgment of the Architect, a substantial benefit to the Owner in terms of cost, time, energy conservation, or other consideration of merit.
  2. Conditions of Review: Architect will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied,

Architect will return requests without action, except to record noncompliance with these requirements:

- a. Requested substitution is consistent with the Contract Documents and will produce indicated results.
  - b. Requested substitution provides sustainable design characteristics that specified product provided for achieving required prerequisites and credits.
  - c. Substitution request is fully documented and properly submitted.
  - d. Requested substitution will not adversely affect Contractor's construction schedule.
  - e. Requested substitution has received necessary approvals of authorities having jurisdiction.
  - f. Requested substitution is compatible with other portions of the Work.
  - g. Requested substitution has been coordinated with other portions of the Work.
  - h. Requested substitution provides specified warranty.
  - i. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.
- B. Substitutions for Convenience: Architect will consider requests for substitution if received within 35 days after the Notice to Proceed. Requests received after that time may be considered or rejected at discretion of Architect.
1. Conditions of Review: Architect will consider Contractor's request for substitution when the following conditions are satisfied. If the following conditions are not satisfied, Architect will return requests without action, except to record noncompliance with these requirements:
    - a. Requested substitution offers Owner a substantial advantage in cost, time, energy conservation, or other considerations, after deducting additional responsibilities Owner must assume. Owner's additional responsibilities may include compensation to Architect for redesign and evaluation services, increased cost of other construction by Owner, and similar considerations.
    - b. Requested substitution does not require extensive revisions to the Contract Documents.
    - c. Requested substitution is consistent with the Contract Documents and will produce indicated results.
    - d. Requested substitution provides sustainable design characteristics that specified product provided for achieving required prerequisites and credits.
    - e. Substitution request is fully documented and properly submitted.
    - f. Requested substitution will not adversely affect Contractor's construction schedule.
    - g. Requested substitution has received necessary approvals of authorities having jurisdiction.
    - h. Requested substitution is compatible with other portions of the Work.
    - i. Requested substitution has been coordinated with other portions of the Work.
    - j. Requested substitution provides specified warranty.
    - k. If requested substitution involves more than one contractor, requested substitution has been coordinated with other portions of the Work, is uniform and consistent, is compatible with other products, and is acceptable to all contractors involved.

## **PART 3 – EXECUTION**

### **3.1 LIMITATIONS ON SUBSTITUTIONS SUBMITTED PRIOR TO THE RECEIPT OF BIDS**

- A. Architect will consider requests for substitutions of specified equipment and/or materials only when requests are received by Architect within fourteen (14) days prior to the date established for the receipt of bids.
- B. Architect will consider a substitution request only if request is made in strict conformance with provisions of this Section. Request shall be fully responsive to all product requirements of the specified product, including those requirements noted in this section in the article titled PRODUCTS.
- C. Burden of proof of merit of requested substitution is the responsibility of the proposer requesting the substitution.
- D. It is the sole responsibility of the proposer requesting the substitution to establish proper content of submittal for requests for substitutions. Incomplete submittals will be rejected.
- E. When substitution is not accepted, provide specified product.
- F. Substitute products shall not be included within the bid without written acceptance by Addendum.
- G. No material changes permitted after the bid opening date. All alternate manufacturers and/or materials shall be submitted and approved in writing by the Architect prior to bid due date, except as otherwise provided in this section. Failure to comply with this requirement is grounds for disqualification of substitution.

### **3.2 LIMITATIONS ON SUBSTITUTIONS SUBMITTED AFTER THE AWARD OF THE CONTRACT**

- A. The Contract is based upon the standards of quality established by those items of equipment and/or materials which are indicated in the Contract Documents, including those products designated in the Notice Inviting Bids as "District Standards".
- B. Notwithstanding other provisions of this section and the above, the Architect may consider a request for substitution after the date of the receipt of bids or contract award, if in the sole discretion of the Architect, there appears to be just cause for such a request. The acceptance of such a late request does not waive any other specified requirement.
- C. Architect will consider a request for substitution only if request is made in strict conformance with provisions of this section. Request shall be fully responsive to all product requirements of the specified product, including those requirements noted in related section 01 6000.
- D. Substitutions will not be considered when they are indicated or implied on shop drawing or product data submittals, without separate written request, or when acceptance will require revision to the Contract Documents.

- E. Review of submittals does not constitute acceptance of substitutions indicated or implied on submittals.
- F. Substitutions will not be considered when requested or submitted directly by subcontractor or supplier.
- G. Contractor's failure or inability to pursue the work promptly or coordinate activities properly shall not establish a cause for consideration of Substitutions.
- H. Burden of proof of merit of requested substitution is the responsibility of the Contractor.
- I. It is the sole responsibility of the Contractor to establish proper content of submittal for requests for substitutions. Incomplete submittals will be rejected.
- J. When substitution is not accepted, provide specified product.
- K. Substitute products shall not be provided without written acceptance by Change Order.

### **3.3 SUBSTITUTION PROCEDURES**

- A. Instructions to Bidders and General Conditions of the Contract may specify time restrictions for submitting requests for substitutions during the bidding period. Comply with requirements in related documents and procedures specified in this section.
- B. Do not request substitutions after expiration of specified periods.
- C. Substitutions may be considered when a product becomes unavailable through no fault of the Contractor.
- D. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents.
  - 1. All Performance Requirements listed in Articles titled QUALITY ASSURANCE, DESIGN CRITERIA, PERFORMANCE REQUIREMENTS and WARRANTY must be met and provided with the Request for Substitution.
  - 2. All Salient Physical Attributes must be met and documented with the Request for Substitution.
  - 3. Document each request on Architect's Request for Substitution (RFS) form with complete data substantiating compliance of proposed substitution with Contract Documents. All requests for substitution must be submitted on the specified form which may be obtained from the Architect. Requests received without the Request Form will be rejected.
- E. A request for substitution constitutes a representation that the submitter:
  - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product.
  - 2. Will provide the same warranty for the substitution as for the specified product.
  - 3. Will coordinate installation and make changes to other Work that may be required for the Work to be complete with no additional cost to Owner.
  - 4. Waives all claims for additional costs or time extension which may subsequently become apparent.

5. Will reimburse Owner and Architect for review or redesign services associated with re-approval by authorities.
- F. Regulatory Requirements: Proposer requesting the substitution shall be responsible for obtaining all regulatory approvals required for proposed substitutions.
- G. All regulatory approval shall be obtained for proposed substitutions prior to submittal of substitution request to Architect.
- H. All costs incurred by the Owner in obtaining regulatory approvals for proposed substitutions, including the costs of the Architect and any authority having jurisdiction over the project shall be reimbursed to the Owner. Costs of these services shall be reimbursed regardless of final acceptance or rejection of substitution.
- I. Substitutions will not be considered when they are indicated or implied on shop drawing or product data submittals, without separate written request, or when acceptance will require revision to the Contract Documents.

#### **3.4 ARCHITECT'S REVIEW OF SUBSTITUTIONS**

- A. The Architect will accept or reject proposed substitutions within fourteen (14) days of receipt of request.
- B. If a decision on a substitution cannot be made within the time allocated, the specified product shall be used.
- C. No extension of bid period or contract time will be made for substitution review.
- D. Final acceptance of a substitution submitted prior to the date established for the receipt of bids will be in the form of an Addendum.
- E. Final acceptance of a substitution submitted after the award of the contract will be in the form of a Change Order.
- F. Architect/Engineer shall be the judge of the acceptability of the proposed substitution. Architect's decision on substitution requests is final and does not require documentation or justification.
- G. Rejection Of Substitution Request: Any of the following reasons shall be cause for rejection, all as determined by the Architect;
  1. Vagueness or incompleteness of Substitution submittal,
  2. Insufficient data, failure to meet specified requirements, (including warranty).
  3. Qualification of the requirements of the Substitution Form, including modification of any of the requirements.
- H. The Architect/Engineer will notify Contractor in writing of decision to accept, accept as noted, or not accept the request for substitution.
- I. Substitute products shall not be ordered or installed without written acceptance.

- J. Owner shall receive full benefit of any cost reduction as a result of any request for substitution.
- K. Provide submittals for accepted substitutions in accordance with specified requirements of the respective section and provisions of Section 01 3300.
- L. An accepted substitution is not acceptable as a submittal. Provide separate submittals for each review.

**- END OF SECTION -**

## - MATERIALS OR PRODUCT SUBSTITUTION REQUEST -

To:		Project:	
Specified Item:			
Section No.	Page No.	Paragraph No.	
Description:			
Reason for Request: <input type="checkbox"/> Substitution for Cause, or <input type="checkbox"/> Substitution for Convenience			
The undersigned requests consideration of the following Proposed Substitution:			
<p>The attached data include product description, specifications, drawings, photographs, performance and test data required for evaluation of request; applicable portions of data are clearly identified.</p> <p>Additionally, attached data include a description a description of changes to Contract Documents which proposed substitution will require for its proper installation. The undersigned certifies that the following paragraphs, unless modified by attachments, are correct:</p> <ol style="list-style-type: none"> <li>1. The proposed substitution does not affect dimensions shown on drawings.</li> <li>2. The undersigned will pay for changes to the building design, including engineering design, detailing, and construction costs caused by the requested substitution.</li> <li>3. The proposed substitution will have no adverse effect on other trades, the construction schedule, or specified warranty requirements.</li> </ol> <p><b>The undersigned further states that the function, appearance, and quality of the proposed substitution are equivalent or superior to the specified item, as fully documented with this request. Contractor waives all claims for additional cost or time arising from this Substitution.</b></p>			
Submitted By:		For Use By Architect:	
Signature:		[    ] Returned Without Action.	
Contractor:		[    ] Accepted.	
Address:		[    ] Accepted As Noted.	
Date:		[    ] Not Accepted.	
Phone:		[    ] Received too Late.	
Attachments:		Remarks:	

## - SECTION 01 2600 - CONTRACT MODIFICATION PROCEDURES

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for handling and processing Contract modifications.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 2500 "Substitution Procedures" for administrative procedures for handling requests for substitutions made after the Contract award.

#### 1.4 MINOR CHANGES IN THE WORK

- A. Architect will issue supplemental instructions authorizing minor changes in the Work, not involving adjustment to the Contract Sum or the Contract Time, on form provided by the Architect.

#### 1.5 PROPOSAL REQUESTS

- A. Owner-Initiated Proposal Requests: Architect will issue a detailed description of proposed changes in the Work that may require adjustment to the Contract Sum or the Contract Time. If necessary, the description will include supplemental or revised Drawings and Specifications.
  - 1. Work Change Proposal Requests issued by Architect are not instructions either to stop work in progress or to execute the proposed change.
  - 2. Within time specified in Proposal Request or 20 days, when not otherwise specified, after receipt of Proposal Request, submit a quotation estimating cost adjustments to the Contract Sum and the Contract Time necessary to execute the change.
    - a. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
    - b. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
    - c. Include costs of labor and supervision directly attributable to the change.
  - d. Include an updated Contractor's construction schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.

- e. Quotation Form: Use forms provided by Owner. Sample copies are included in Project Manual.
  
- B. Contractor-Initiated Proposals: If latent or changed conditions require modifications to the Contract, Contractor may initiate a claim by submitting a request for a change to Architect.
  - 2. Include a statement outlining reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and the Contract Time.
  - 3. Include a list of quantities of products required or eliminated and unit costs, with total amount of purchases and credits to be made. If requested, furnish survey data to substantiate quantities.
  - 4. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
  - 5. Include costs of labor and supervision directly attributable to the change.
  - 6. Include an updated Contractor's construction schedule that indicates the effect of the change, including, but not limited to, changes in activity duration, start and finish times, and activity relationship. Use available total float before requesting an extension of the Contract Time.
  - 7. Comply with requirements in Section 01 2500 "Substitution Procedures" if the proposed change requires substitution of one product or system for product or system specified.
  - 8. Proposal Request Form: Use form provided by Owner. Sample copy is included in Project Manual.

## **1.6 CHANGE ORDER PROCEDURES**

- A. On Owner's approval of a Work Change Proposal Request, Architect will issue a Change Order for signatures of Owner and Contractor on AIA Document G701.

## **1.7 CONSTRUCTION CHANGE DIRECTIVE**

- A. Construction Change Directive: Architect may issue a Construction Change Directive on form provided by the Architect. Construction Change Directive instructs Contractor to proceed with a change in the Work, for subsequent inclusion in a Change Order.
  - 1. Construction Change Directive contains a complete description of change in the Work. It also designates method to be followed to determine change in the Contract Sum or the Contract Time.
  
- B. Documentation: Maintain detailed records on a time and material basis of work required by the Construction Change Directive.
  - 1. After completion of change, submit an itemized account and supporting data necessary to substantiate cost and time adjustments to the Contract.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

## - SECTION 01 2900 - PAYMENT PROCEDURES

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements necessary to prepare and process Applications for Payment.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 2600 "Contract Modification Procedures" for administrative procedures for handling changes to the Contract.
- B. Section 01 3200 "Construction Progress Documentation" for administrative requirements governing the preparation and submittal of the Contractor's construction schedule.
- C. Section 018113 "Sustainable Design Requirements" for administrative requirements governing submittal of cost breakdown information required for LEED documentation.

#### 1.4 DEFINITIONS

- A. Schedule of Values: A statement furnished by Contractor allocating portions of the Contract Sum to various portions of the Work and used as the basis for reviewing Contractor's Applications for Payment.

#### 1.5 SCHEDULE OF VALUES

- A. Coordination: Coordinate preparation of the schedule of values with preparation of Contractor's construction schedule.
  - 1. Coordinate line items in the schedule of values with other required administrative forms and schedules, including the following:
    - a. Application for Payment forms with continuation sheets.
    - b. Submittal schedule.
    - c. Items required to be indicated as separate activities in Contractor's construction schedule.

2. Submit Draft schedule of values to Architect at earliest possible date, but no later than fourteen (14) days after Notice to Proceed.
  3. Revise Draft schedule of values as required by Architect.
  4. Submit the revised schedule of values to Architect at earliest possible date, but no later than seven days before the date scheduled for submittal of initial Applications for Payment.
  5. Subschedules for Phased Work: Where the Work is separated into phases requiring separately phased payments, provide subschedules showing values coordinated with each phase of payment.
  6. Subschedules for Separate Elements of Work: Where the Contractor's construction schedule defines separate elements of the Work, provide subschedules showing values coordinated with each element.
- B. Format and Content: Use Project Manual table of contents as a guide to establish line items for the schedule of values. Provide at least one line item for each Specification Section.
1. Identification: Include the following Project identification on the schedule of values:
    - a. Project name and location.
    - b. Name of Architect.
    - c. Architect's project number.
    - d. Contractor's name and address.
    - e. Date of submittal.
  2. Arrange schedule of values consistent with format of AIA Document G703.
  3. Arrange the schedule of values in tabular form with separate columns to indicate the following for each item listed:
    - a. Related Specification Section or Division.
    - b. Description of the Work.
    - c. Name of subcontractor.
    - d. Name of manufacturer or fabricator.
    - e. Name of supplier.
    - f. Change Orders (numbers) that affect value.
    - g. Dollar value of the following, as a percentage of the Contract Sum to nearest one-hundredth percent, adjusted to total 100 percent.
      - Labor.
      - Materials.
      - Equipment.
  4. Provide a breakdown of the Contract Sum in enough detail to facilitate continued evaluation of Applications for Payment and progress reports. Coordinate with Project Manual table of contents. Provide multiple line items for principal subcontract amounts in excess of five percent of the Contract Sum.
  5. Round amounts to nearest whole dollar; total shall equal the Contract Sum.
  6. Provide a separate line item in the schedule of values for each part of the Work where Applications for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed. Payment for materials stored or not yet installed is at

the option of the Owner. Obtain permission for each item separately before including in Application for Payment.

- a. Differentiate between items stored on-site and items stored off-site. If required, include evidence of insurance.
7. Provide separate line items in the schedule of values for initial cost of materials, for each subsequent stage of completion, and for total installed value of that part of the Work.
8. Allowances: Provide a separate line item in the schedule of values for each allowance. Show line-item value of unit-cost allowances, as a product of the unit cost, multiplied by measured quantity. Use information indicated in the Contract Documents to determine quantities.
9. Purchase Contracts: Provide a separate line item in the schedule of values for each purchase contract. Show line-item value of purchase contract. Indicate owner payments or deposits, if any, and balance to be paid by Contractor.
10. Each item in the schedule of values and Applications for Payment shall be complete. Include total cost and proportionate share of general overhead and profit for each item.
  - a. Temporary facilities and other major cost items that are not direct cost of actual work-in-place may be shown either as separate line items in the schedule of values or distributed as general overhead expense, at Contractor's option.
11. Schedule Updating: Update and resubmit the schedule of values before the next Applications for Payment when Change Orders or Construction Change Directives result in a change in the Contract Sum.

## **1.6 APPLICATIONS FOR PAYMENT**

- A. Each Application for Payment following the initial Application for Payment shall be consistent with previous applications and payments as certified by Architect and paid for by Owner.
  1. Initial Application for Payment, Application for Payment at time of Substantial Completion, and final Application for Payment involve additional requirements.
- B. Payment Application Times: Submit Application for Payment to Architect by the 25th of the month. The period covered by each Application for Payment is one month, ending on the last day of the month.
  1. Submit draft copy of Application for Payment seven days prior to due date for review by Architect.
- C. Application for Payment Forms: Use AIA Document G702 and AIA Document G703 or other forms acceptable to the Owner as form for Applications for Payment.
- D. Application Preparation: Complete every entry on form. Notarize and execute by a person authorized to sign legal documents on behalf of Contractor. Architect will return incomplete applications without action.
  1. Entries shall match data on the schedule of values and Contractor's construction schedule. Use updated schedules if revisions were made.

2. Include amounts for work completed following previous Application for Payment, whether or not payment has been received. Include only amounts for work completed at time of Application for Payment.
  3. Include amounts of Change Orders and Construction Change Directives issued before last day of construction period covered by application.
  4. Indicate separate amounts for work being carried out under Owner-requested project acceleration.
  5. Stored Materials: Include in Application for Payment amounts applied for materials or equipment purchased or fabricated and stored, but not yet installed. Differentiate between items stored on-site and items stored off-site. Payment for materials stored or not yet installed is at the option of the Owner. Obtain permission for each item separately before including in Application for Payment.
  6. Provide certificate of insurance, evidence of transfer of title to Owner, and consent of surety to payment, for stored materials.
  7. Provide statement that project Record Drawings have been updated through the date of the Application for Payment.
  8. Provide submittals required by Section 01 7419 through the date of the Application for Payment. Receipt of required Waste Management submittals is a condition precedent to approval of payment.
  9. Provide supporting documentation that verifies amount requested, such as paid invoices. Match amount requested with amounts indicated on documentation; do not include overhead and profit on stored materials.
  10. Provide summary documentation for stored materials indicating the following:
    - a. Value of materials previously stored and remaining stored as of date of previous Applications for Payment.
    - b. Value of previously stored materials put in place after date of previous Application for Payment and on or before date of current Application for Payment.
    - c. Value of materials stored since date of previous Application for Payment and remaining stored as of date of current Application for Payment.
- E. Transmittal: Submit three signed and notarized original copies of each Application for Payment to Architect by a method ensuring receipt within 24 hours. One copy shall include waivers of lien and similar attachments if required.
1. Transmit each copy with a transmittal form listing attachments and recording appropriate information about application.
- F. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's lien from entities lawfully entitled to file a mechanic's lien arising out of the Contract and related to the Work covered by the payment.
1. Submit partial waivers on each item for amount requested in previous application, after deduction for retainage, on each item.
  2. When an application shows completion of an item, submit conditional final or full waivers.
  3. Owner reserves the right to designate which entities involved in the Work must submit waivers.

4. Waiver Forms: Submit executed waivers of lien on forms acceptable to Owner.
- G. Waivers of Mechanic's Lien: With each Application for Payment, submit waivers of mechanic's liens from subcontractors, sub-subcontractors, and suppliers for construction period covered by the previous application.
  1. Submit partial waivers on each item for amount requested in previous application, after deduction for retainage, on each item.
  2. When an application shows completion of an item, submit conditional final or full waivers.
  3. Owner reserves the right to designate which entities involved in the Work must submit waivers.
  4. Submit final Application for Payment with or preceded by conditional final waivers from every entity involved with performance of the Work covered by the application who is lawfully entitled to a lien.
  5. Waiver Forms: Submit executed waivers of lien on forms, acceptable to Owner.
- H. Initial Application for Payment: Administrative actions and submittals that must precede or coincide with submittal of first Application for Payment include the following:
  1. List of subcontractors.
  2. Schedule of values.
  3. Contractor's construction schedule (preliminary if not final).
  4. Combined Contractor's construction schedule (preliminary if not final) incorporating Work of multiple contracts, with indication of acceptance of schedule by each Contractor.
  5. Products list (preliminary if not final).
  6. Schedule of unit prices.
  7. Submittal schedule (preliminary if not final).
  8. List of Contractor's staff assignments.
  9. List of Contractor's principal consultants.
  10. Copies of building permits.
  11. Copies of authorizations and licenses from authorities having jurisdiction for performance of the Work.
  12. Initial progress report.
  13. Report of preconstruction conference.
  14. Certificates of insurance and insurance policies.
  15. Performance and payment bonds.
  16. Data needed to acquire Owner's insurance.
- I. Application for Payment at Substantial Completion: After Architect issues the Certificate of Substantial Completion, submit an Application for Payment showing 100 percent completion for portion of the Work claimed as substantially complete.
  1. Include documentation supporting claim that the Work is substantially complete and a statement showing an accounting of changes to the Contract Sum.
  2. This application shall reflect Certificate(s) of Substantial Completion issued previously for Owner occupancy of designated portions of the Work.

- J. Final Payment Application: After completing Project closeout requirements, submit final Application for Payment with releases and supporting documentation not previously submitted and accepted, including, but not limited, to the following:
1. Evidence of completion of Project closeout requirements.
  2. Insurance certificates for products and completed operations where required and proof that taxes, fees, and similar obligations were paid.
  3. Updated final statement, accounting for final changes to the Contract Sum.
  4. AIA Document G706, "Contractor's Affidavit of Payment of Debts and Claims."
  5. AIA Document G706A, "Contractor's Affidavit of Release of Liens".
  6. AIA Document G707, "Consent of Surety to Final Payment".
  7. Evidence that claims have been settled.
  8. Final meter readings for utilities, a measured record of stored fuel, and similar data as of date of Substantial Completion or when Owner took possession of and assumed responsibility for corresponding elements of the Work.
  9. Final liquidated damages settlement statement.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

## - SECTION 01 3100 - PROJECT MANAGEMENT & COORDINATION

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative provisions for coordinating construction operations on Project including, but not limited to, the following:
  - 1. General coordination procedures.
  - 2. Coordination drawings.
  - 3. Requests for Information (RFIs).
  - 4. Project meetings.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 3200 "Construction Progress Documentation" for preparing and submitting Contractor's construction schedule.
- B. Section 01 7300 "Execution" for procedures for coordinating general installation and field-engineering services, including establishment of benchmarks and control points.
- C. Section 01 7700 "Closeout Procedures" for coordinating closeout of the Contract.
- D. Section 01 9113 "General Commissioning Requirements" for coordinating the Work with Owner's Commissioning Authority.

#### 1.4 DEFINITIONS

- A. RFI: Request from Owner, Architect, or Contractor seeking information required by or clarifications of the Contract Documents.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Subcontract List: Prepare a written summary identifying individuals or firms proposed for each portion of the Work, including those who are to furnish products or equipment fabricated to a special design. Include the following information in tabular form:
  - 1. Name, address, and telephone number of entity performing subcontract or supplying products.
  - 2. Number and title of related Specification Section(s) covered by subcontract.
  - 3. Drawing number and detail references, as appropriate, covered by subcontract.

- B. Key Personnel Names: Within 15 days of starting construction operations, submit a list of key personnel assignments, including superintendent and other personnel in attendance at Project site. Identify individuals and their duties and responsibilities; list addresses and telephone numbers, including home, office, and cellular telephone numbers and e-mail addresses. Provide names, addresses, and telephone numbers of individuals assigned as alternates in the absence of individuals assigned to Project.
  - 1. Post copies of list in project meeting room, in temporary field office, and by each temporary telephone. Keep list current at all times.

## 1.6 GENERAL COORDINATION PROCEDURES

- A. Coordination: Coordinate construction operations included in different Sections of the Specifications to ensure efficient and orderly installation of each part of the Work. Coordinate construction operations, included in different Sections that depend on each other for proper installation, connection, and operation.
  - 1. Schedule construction operations in sequence required to obtain the best results where installation of one part of the Work depends on installation of other components, before or after its own installation.
  - 2. Coordinate installation of different components to ensure maximum performance and accessibility for required maintenance, service, and repair.
  - 3. Make adequate provisions to accommodate items scheduled for later installation.
- B. Coordination: Each contractor shall coordinate its construction operations with those of other contractors and entities to ensure efficient and orderly installation of each part of the Work. Each contractor shall coordinate its operations with operations, included in different Sections that depend on each other for proper installation, connection, and operation.
  - 1. Schedule construction operations in sequence required to obtain the best results where installation of one part of the Work depends on installation of other components, before or after its own installation.
  - 2. Coordinate installation of different components with other contractors to ensure maximum performance and accessibility for required maintenance, service, and repair.
  - 3. Make adequate provisions to accommodate items scheduled for later installation.
- C. Prepare memoranda for distribution to each party involved, outlining special procedures required for coordination. Include such items as required notices, reports, and list of attendees at meetings.
  - 1. Prepare similar memoranda for Owner and separate contractors if coordination of their Work is required.
- D. Administrative Procedures: Coordinate scheduling and timing of required administrative procedures with other construction activities and activities of other contractors to avoid conflicts and to ensure orderly progress of the Work. Such administrative activities include, but are not limited to, the following:
  - 1. Preparation of Contractor's construction schedule.
  - 2. Preparation of the schedule of values.
  - 3. Installation and removal of temporary facilities and controls.
  - 4. Delivery and processing of submittals.

5. Progress meetings.
  6. Preinstallation conferences.
  7. Project closeout activities.
  8. Startup and adjustment of systems.
- E. Conservation: Coordinate construction activities to ensure that operations are carried out with consideration given to conservation of energy, water, and materials. Coordinate use of temporary utilities to minimize waste.
1. Salvage materials and equipment involved in performance of, but not actually incorporated into, the Work. See other Sections for disposition of salvaged materials that are designated as Owner's property.

### 1.7 COORDINATION DRAWINGS

- A. Coordination Drawings, General: Prepare coordination drawings for Facilities Services Utilities (Mechanical, Electrical, Plumbing, Telecom/Data and Electronic Safety and Security) throughout the project as limited space availability necessitates increased coordination, and in all locations where coordination is required to facilitate integration of products and materials fabricated or installed by more than one entity.
1. Content: Project-specific information, drawn accurately in AutoCAD format to a scale large enough to indicate and resolve conflicts. Do not base coordination drawings on standard printed data. Include the following information, as applicable:
    - a. Use applicable Drawings as a basis for preparation of coordination drawings. Prepare sections, elevations, and details as needed to describe relationship of various systems and components.
    - b. General Contractor is responsible for coordination of the addition of trade-specific information to the coordination drawings by multiple contractors in a sequence that best provides for coordination of the information and resolution of conflicts between installed components before submitting for review.
    - c. Indicate functional and spatial relationships of components of architectural, structural, civil, mechanical, and electrical systems.
    - d. Indicate space requirements for routine maintenance and for anticipated replacement of components during the life of the installation.
    - e. Show location and size of access doors required for access to concealed dampers, valves, and other controls.
    - f. Indicate required installation sequences.
    - g. Indicate dimensions shown on the Drawings. Specifically note dimensions that appear to be in conflict with submitted equipment and minimum clearance requirements. Provide alternate sketches to Architect indicating proposed resolution of such conflicts. Minor dimension changes and difficult installations will not be considered changes to the Contract.
    - h. Prepare coordination drawings at full scale (life size) at locations requested by Architect, demonstrate conflict resolution in mockups and on in-situ construction.
- B. Coordination Drawing Organization: Organize coordination drawings as follows:
1. Floor Plans and Reflected Ceiling Plans: Show architectural and structural elements, and mechanical, plumbing, fire-protection, fire-alarm, and electrical Work. Show locations of visible ceiling-mounted devices relative to acoustical ceiling grid. Supplement plan drawings with section drawings where required to adequately represent the Work.

2. Plenum Space: Indicate subframing for support of ceiling and wall systems, mechanical and electrical equipment, and related Work. Locate components within ceiling plenum to accommodate layout of light fixtures indicated on Drawings. Indicate areas of conflict between light fixtures and other components.
  3. Mechanical Rooms: Provide coordination drawings for mechanical rooms showing plans and elevations of mechanical, plumbing, fire-protection, fire-alarm, and electrical equipment.
  4. Structural Penetrations: Indicate penetrations and openings required for all disciplines.
  5. Slab Edge and Embedded Items: Indicate slab edge locations and sizes and locations of embedded items for metal fabrications, sleeves, anchor bolts, bearing plates, angles, door floor closers, slab depressions for floor finishes, curbs and housekeeping pads, and similar items.
  6. Mechanical and Plumbing Work: Show the following:
    - a. Sizes and bottom elevations of ductwork, piping, and conduit runs, including insulation, bracing, flanges, and support systems.
    - b. Dimensions of major components, such as dampers, valves, diffusers, access doors, cleanouts and electrical distribution equipment.
    - c. Fire-rated enclosures around ductwork.
  7. Electrical Work: Show the following:
    - a. Runs of vertical and horizontal conduit 1-1/4 inches (32 mm) in diameter and larger.
    - b. Light fixture, exit light, emergency battery pack, smoke detector, and other fire-alarm locations.
    - c. Panel board, switch board, switchgear, transformer, busway, generator, and motor control center locations.
    - d. Location of pull boxes and junction boxes, dimensioned from column center lines.
  8. Fire-Protection System: Show the following:
    - a. Locations of standpipes, mains piping, branch lines, pipe drops, and sprinkler heads.
  9. Review: Architect will review coordination drawings to confirm that the Work is being coordinated, but not for the details of the coordination, which are Contractor's responsibility. If Architect determines that coordination drawings are not being prepared in sufficient scope or detail, or are otherwise deficient, Architect will so inform Contractor, who shall make changes as directed and resubmit.
  10. Coordination Drawing Prints: Prepare coordination drawing prints according to requirements in Section 01 3300 "Submittal Procedures."
- C. Coordination Digital Data Files: Prepare coordination digital data files according to the following requirements:
1. File Preparation Format: Same digital data software program, version, and operating system as original Drawings.
  2. File Preparation Format: DWG Version operating in Microsoft Windows operating system.
  3. File Submittal Format: Submit or post coordination drawing files using format same as file preparation format and Portable Data File (PDF) format.
  4. Architect will furnish Contractor one set of digital data files of Drawings for use in preparing coordination digital data files as specified in related Section 01 1150 "Electronic Drawings"
    - a. Architect makes no representations as to the accuracy or completeness of digital data files as they relate to Drawings.

- b. Digital Data Software Program: Drawings are available in AutoCAD Format.
  - c. Contractor shall execute a data licensing agreement in the form of Agreement included in this Project Manual or an Agreement form acceptable to Owner and Architect.
- D. Coordination Meetings: As described below in PROJECT MEETINGS Article.

### 1.8 REQUEST FOR INFORMATION (RFI)

- A. An RFI is a written request prepared by the Contractor asking the Architect to provide additional information necessary to clarify an item which the Contractor feels is not clearly shown or called for in the drawings or specifications, or to address questions which have arisen under field conditions.
- B. An RFI cannot modify the Contract Cost, Contract Time, or the Contract Documents.
- C. General: Immediately on discovery of the need for additional information or interpretation of the Contract Documents, Contractor shall prepare and submit an RFI in the form specified.
  - 1. Architect will return RFIs submitted to Architect by other entities controlled by Contractor with no response.
  - 2. Coordinate and submit RFIs in a prompt manner so as to avoid delays in Contractor's work or work of subcontractors.
  - 3. Submit RFIs to Architect on the form included in the project manual. Submittals not conforming to this requirement will be returned.
- D. Content of the RFI: Include a detailed, legible description of item needing information or interpretation and the following:
  - 1. Project name.
  - 2. Project number.
  - 3. Date.
  - 4. Name of Contractor.
  - 5. Name of Architect.
  - 6. RFI number, numbered sequentially.
  - 7. RFI subject.
  - 8. Specification Section number and title and related paragraphs, as needed to describe the request.
  - 9. Drawing number and detail references, as needed to describe the request.
  - 10. Field dimensions and conditions, as needed to describe the request.
  - 11. Contractor's suggested resolution. If Contractor's suggested resolution impacts the Contract Time or the Contract Sum, Contractor shall state impact in the RFI.
  - 12. Contractor's signature.
  - 13. Attachments: Include sketches, descriptions, measurements, photos, Product Data, Shop Drawings, coordination drawings, and other information necessary to fully describe items needing interpretation.
    - a. Include dimensions, thicknesses, structural grid references, and details of affected materials, assemblies, and attachments on attached sketches.
- E. RFI Forms: Form bound in Project Manual or a Software-generated form with substantially the same content as indicated above, acceptable to Architect.

1. Attachments shall be electronic files in Adobe Acrobat PDF format.
- F. Architect's Action: Architect will review each RFI, determine action required, and respond. Allow ten (10) working days for Architect's response for each RFI. RFIs received by Architect after 1:00 p.m. will be considered as received the following working day. If the Architect cannot respond to the RFI within ten (10) working days, the Architect shall notify the Contractor and the Owner, of the estimated amount of time that will be required to respond.
1. The following Contractor-generated RFIs will be returned without action. Time spent by the Architect in identifying and managing the following will be compensable as described below for frivolous RFIs:
    - a. Requests for approval of submittals.
    - b. Requests for approval of substitutions.
    - c. Requests for approval of Contractor's means and methods.
    - d. Requests for coordination information already indicated in the Contract Documents.
    - e. Requests for adjustments in the Contract Time or the Contract Sum.
    - f. Requests for interpretation of Architect's actions on submittals.
    - g. Incomplete RFIs or inaccurately prepared RFIs.
  2. Architect's action may include a request for additional information, in which case Architect's time for response will date from time of receipt of additional information.
  3. Frivolous RFIs: The Contractor may be invoiced by the Owner for any costs incurred for professional services, which shall be deducted from the next progress payment, for each RFI requesting an interpretation or decision of a matter where the information sought is equally available to the party making such request, or as otherwise defined in this section as frivolous.
  4. Architect's action on RFIs that may result in a change to the Contract Time or the Contract Sum may be eligible for Contractor to submit Change Proposal according to Section 01 2600 "Contract Modification Procedures."
    - a. If Contractor believes the RFI response warrants change in the Contract Time or the Contract Sum, notify Architect in writing within 10 days of receipt of the RFI response.
- G. RFI Log: Prepare, maintain, and submit a tabular log of RFIs organized by the RFI number. Submit log weekly. Include the following:
1. Project name.
  2. Name and address of Contractor.
  3. Name and address of Architect.
  4. RFI number including RFIs that were returned without action or withdrawn.
  5. RFI description.
  6. Date the RFI was submitted.
  7. Date Architect's response was received.
- H. On receipt of Architect's action, update the RFI log and immediately distribute the RFI response to affected parties. Review response and notify Architect within seven days if Contractor disagrees with response.
1. Identification of related Minor Change in the Work, Construction Change Directive, and Proposal Request, as appropriate.

### 1.9 ARCHITECT'S SUPPLEMENTAL INSTRUCTIONS (ASI)

- A. An ASI is a written supplemental instruction issued and signed by the Architect for minor changes to the Work, without change in Contract Sum or Contract Time.
- B. An ASI cannot modify the Contract Cost, Contract Time, or the Contract Documents.
- C. Architect Authority:
  - 1. The Architect has authority to order minor changes in the Work not involving any adjustment in the Contract Sum, an extension of the Contract Time, or a change which is inconsistent with the intent of the Contract Documents.
  - 2. The Contractor shall carry out such written orders promptly.

### 1.10 PROJECT MEETINGS

- A. General: Schedule and conduct meetings and conferences at Project site unless otherwise indicated.
  - 1. Attendees: Inform participants and others involved, and individuals whose presence is required, of date and time of each meeting. Notify Owner and Architect of scheduled meeting dates and times.
  - 2. Agenda: Prepare the meeting agenda. Distribute the agenda to all invited attendees.
  - 3. Minutes: Entity responsible for conducting meeting will record significant discussions and agreements achieved. Distribute the meeting minutes to everyone concerned, including Owner and Architect, within three days of the meeting.
- B. Preconstruction Conference: Architect will schedule and conduct a preconstruction conference before starting construction, at a time convenient to Owner and Architect, but no later than 15 days after execution of the Agreement.
  - 1. Conduct the conference to review responsibilities and personnel assignments.
  - 2. Attendees: Authorized representatives of Owner, Owner's Commissioning Authority, Architect, and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the conference. Participants at the conference shall be familiar with Project and authorized to conclude matters relating to the Work.
  - 3. Agenda: Discuss items of significance that could affect progress, including the following:
    - a. Tentative construction schedule.
    - b. Phasing.
    - c. Critical work sequencing and long-lead items.
    - d. Designation of key personnel and their duties.
    - e. Lines of communications.
    - f. Procedures for processing field decisions and Change Orders.
    - g. Procedures for RFIs.
    - h. Procedures for testing and inspecting.
    - i. Procedures for processing Applications for Payment.
    - j. Distribution of the Contract Documents.
    - k. Submittal procedures.
    - l. Sustainable design requirements.
    - m. Preparation of record documents.
    - n. Use of the premises.
    - o. Work restrictions.

- p. Working hours.
  - q. Owner's occupancy requirements.
  - r. Responsibility for temporary facilities and controls.
  - s. Procedures for moisture and mold control.
  - t. Procedures for disruptions and shutdowns.
  - u. Construction waste management and recycling.
  - v. Parking availability.
  - w. Office, work, and storage areas.
  - x. Equipment deliveries and priorities.
  - y. First aid.
  - z. Security.
  - aa. Progress cleaning.
4. Minutes: Entity responsible for conducting meeting will record and distribute meeting minutes.
- C. Coordination Conferences: Conduct a minimum of three Coordination Conferences at Project site to review Coordination Drawings specified in COORDINATION DRAWINGS Article of this Section for construction activity that requires coordination with other construction. Coordination Conferences are separate from and do not substitute for Pre-Construction Conferences which may be described in various Sections.
- 1. Attendees: Facilities Services Utilities (Mechanical, Electrical, Plumbing, Telecom/Data and Electronic Safety and Security) subcontractors.
  - 2. Installer and representatives of manufacturers and fabricators involved in or affected by coordination or integration with materials and installations that have preceded or will follow, shall attend the meeting.
  - 3. Advise Architect and Owner's Commissioning Authority of scheduled meeting dates.
  - 4. Optional Attendance: The Architect.
  - 5. Agenda: Review progress of construction coordination activities and preparations for the future activities under consideration, including requirements for the following:
    - a. Submittals.
    - b. Sustainable design requirements.
    - c. Review of Coordination Drawings, including posting of full-scale (life-size) plots to determine or demonstrate acceptable coordination requirements.
    - d. Review of mockups.
    - e. Possible conflicts.
    - f. Aesthetic Appearance.
    - g. Compatibility requirements.
    - h. Time schedules.
    - i. Compatibility of materials.
    - j. Acceptability of substrates.
    - k. Space and access limitations.
    - l. Regulations of authorities having jurisdiction.
    - m. Installation procedures.
    - n. Coordination with other work.
    - o. Required performance results.
  - 6. Record significant conference discussions, agreements, and disagreements, including required corrective measures and actions.
  - 7. Reporting: Distribute minutes of the meeting to each party present and to other parties requiring information.

8. Do not proceed with installation if the conference cannot be successfully concluded. Initiate whatever actions are necessary to resolve impediments to performance of the Work and reconvene the conference at earliest feasible date.

D. Preinstallation Conferences: Conduct a preinstallation conference at Project site before each construction activity that requires coordination with other construction.

1. Attendees: Installer and representatives of manufacturers and fabricators involved in or affected by the installation and its coordination or integration with other materials and installations that have preceded or will follow, shall attend the meeting. Advise Architect and Owner's Commissioning Authority of scheduled meeting dates.
2. Agenda: Review progress of other construction activities and preparations for the particular activity under consideration, including requirements for the following:
  - a. Contract Documents.
  - b. Options.
  - c. Related RFIs.
  - d. Related Change Orders.
  - e. Purchases.
  - f. Deliveries.
  - g. Submittals.
  - h. Sustainable design requirements.
  - i. Review of mockups.
  - j. Possible conflicts.
  - k. Compatibility requirements.
  - l. Time schedules.
  - m. Weather limitations.
  - n. Manufacturer's written instructions.
  - o. Warranty requirements.
  - p. Compatibility of materials.
  - q. Acceptability of substrates.
  - r. Temporary facilities and controls.
  - s. Space and access limitations.
  - t. Regulations of authorities having jurisdiction.
  - u. Testing and inspecting requirements.
  - v. Installation procedures.
  - w. Coordination with other work.
  - x. Required performance results.
  - y. Protection of adjacent work.
  - z. Protection of construction and personnel.

3. Record significant conference discussions, agreements, and disagreements, including required corrective measures and actions.
4. Reporting: Distribute minutes of the meeting to each party present and to other parties requiring information.
5. Do not proceed with installation if the conference cannot be successfully concluded. Initiate whatever actions are necessary to resolve impediments to performance of the Work and reconvene the conference at earliest feasible date.

- E. Project Closeout Conference: Schedule and conduct a project closeout conference, at a time convenient to Owner and Architect, but no later than 90 days prior to the scheduled date of Substantial Completion.
1. Conduct the conference to review requirements and responsibilities related to Project closeout.
  2. Attendees: Authorized representatives of Owner, Owner's Commissioning Authority, Architect, and their consultants; Contractor and its superintendent; major subcontractors; suppliers; and other concerned parties shall attend the meeting. Participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
  3. Agenda: Discuss items of significance that could affect or delay Project closeout, including the following:
    - a. Preparation of record documents.
    - b. Procedures required prior to inspection for Substantial Completion and for final inspection for acceptance.
    - c. Submittal of written warranties.
    - d. Requirements for completing sustainable design documentation.
    - e. Requirements for preparing operations and maintenance data.
    - f. Requirements for delivery of material samples, attic stock, and spare parts.
    - g. Requirements for demonstration and training.
    - h. Preparation of Contractor's punch list.
    - i. Procedures for processing Applications for Payment at Substantial Completion and for final payment.
    - j. Submittal procedures.
    - k. Coordination of separate contracts.
    - l. Owner's partial occupancy requirements.
    - m. Installation of Owner's furniture, fixtures, and equipment.
    - n. Responsibility for removing temporary facilities and controls.
  4. Minutes: Entity conducting meeting will record and distribute meeting minutes.
- F. Progress Meetings: Conduct progress meetings at regular intervals.
1. Coordinate dates of meetings with preparation of payment requests.
  2. Attendees: In addition to representatives of Owner, Owner's Commissioning Authority and Architect, each contractor, subcontractor, supplier, and other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings. All participants at the meeting shall be familiar with Project and authorized to conclude matters relating to the Work.
  3. Agenda: Review and correct or approve minutes of previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to status of Project.
    - a. Contractor's Construction Schedule: Review progress since the last meeting. Determine whether each activity is on time, ahead of schedule, or behind schedule, in relation to Contractor's construction schedule. Determine how construction behind schedule will be expedited; secure commitments from parties

involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.

- 1) Review schedule for next period.
- b. Review present and future needs of each entity present, including the following:
  - 1) Interface requirements.
  - 2) Sequence of operations.
  - 3) Resolution of BIM component conflicts.
  - 4) Status of submittals.
  - 5) Status of LEED sustainable design documentation.
  - 6) Deliveries.
  - 7) Off-site fabrication.
  - 8) Access.
  - 9) Site utilization.
  - 10) Temporary facilities and controls.
  - 11) Progress cleaning.
  - 12) Quality and work standards.
  - 13) Status of correction of deficient items.
  - 14) Field observations.
  - 15) Status of RFIs.
  - 16) Status of proposal requests.
  - 17) Pending changes.
  - 18) Status of Change Orders.
  - 19) Pending claims and disputes.
  - 20) Documentation of information for payment requests.
4. Minutes: Entity responsible for conducting the meeting will record and distribute the meeting minutes to each party present and to parties requiring information.
  - a. Schedule Updating: Revise Contractor's construction schedule after each progress meeting where revisions to the schedule have been made or recognized. Issue revised schedule concurrently with the report of each meeting.

### 1.11 PROJECT WEB SITE

- A. Provide, administer, and use Project Web site for purposes of hosting and managing project communication and documentation until Final Completion. Project Web site shall include the following functions:
  1. Project directory.
  2. Project correspondence.
  3. Meeting minutes.
  4. Contract modifications forms and logs.
  5. RFI forms and logs.
  6. Task and issue management.
  
  7. Photo documentation.
  8. Schedule and calendar management.
  9. Submittals forms and logs.

10. Payment application forms.
  11. Drawing and specification document hosting, viewing, and updating.
  12. Online document collaboration.
  13. Reminder and tracking functions.
  14. Archiving functions.
- B. Provide up to [seven] Project Web site user licenses for use of the Owner's Commissioning Authority, Construction Manager, Architect, and Architect's consultants. Provide [eight] hours of software training at Architect's office for Project Web site users.
- C. On completion of Project, provide [one] <Insert number> complete archive copy(ies) of Project Web site files to Owner and to Architect in a digital storage format acceptable to Architect.
- D. Provide [one of ]the following Project Web site software packages under their current published licensing agreements:
1. Autodesk, Buzzsaw.
  2. Autodesk, Constructware.
  3. Meridian Systems, [Prolog] [Prolog and ProjectTalk].
  4. <Insert name of hosting company and product>.
- E. Contractor, subcontractors, and other parties granted access by Contractor to Project Web site shall execute a data licensing agreement in the form of [AIA Document C106] [Agreement included in this Project Manual] [Agreement acceptable to Owner and Architect].

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

## - SECTION 01 3300 - SUBMITTAL PROCEDURES

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes requirements for the submittal schedule and administrative and procedural requirements for submitting Shop Drawings, Product Data, Samples, and other submittals.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 1150 "Electronic Drawings."
- B. Section 01 2900 "Payment Procedures" for submitting Applications for Payment and the schedule of values.
- C. Section 01 3200 "Construction Progress Documentation" for submitting schedules and reports, including Contractor's construction schedule.
- D. Section 01 7823 "Operation and Maintenance Data" for submitting operation and maintenance manuals.
- E. Section 01 7839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.
- F. Section 01 7900 "Demonstration and Training" for submitting video recordings of demonstration of equipment and training of Owner's personnel.

#### 1.4 WORK NOT INCLUDED

- A. Submittals which are not required will not be reviewed by the Architect.
- B. The Contractor may require subcontractors to provide drawings, setting diagrams or similar information as part of the coordination of the Work. The Architect will not review this data.
- C. Material Safety Data Sheets (MSDS) - Limitation of Review: Certain Submittals require provision of these documents by the Contractor. These documents contain information necessary for operation of the facility. The Architect's review of these submittals is limited to noting inclusion of the document for the Owner's use. No further review or comment on MSDS documents by Architect shall be performed or inferred.

## 1.5 DEFINITIONS

- A. Action Submittals: Written and graphic information and physical samples that require Architect's responsive action. Action submittals are those submittals indicated in individual Specification Sections as "action submittals."
- B. Informational Submittals: Written and graphic information and physical samples that do not require Architect's responsive action. Submittals may be rejected for not complying with requirements. Informational submittals are those submittals indicated in individual Specification Sections as "informational submittals."
- C. File Transfer Protocol (FTP): Communications protocol that enables transfer of files to and from another computer over a network and that serves as the basis for standard Internet protocols. An FTP site is a portion of a network located outside of network firewalls within which internal and external users are able to access files.
- D. Portable Document Format (PDF): An open standard file format licensed by Adobe Systems used for representing documents in a device-independent and display resolution-independent fixed- layout document format.

## 1.6 ACTION SUBMITTALS

- A. Submittal Schedule: Submit a schedule of submittals, arranged in chronological order by dates required by construction schedule. Include time required for review, ordering, manufacturing, fabrication, and delivery when establishing dates. Include additional time required for making corrections or revisions to submittals noted by Architect and additional time for handling and reviewing submittals required by those corrections.
  - 1. Coordinate submittal schedule with list of subcontracts, the schedule of values, and Contractor's construction schedule.
  - 2. Initial Submittal: Submit concurrently with startup construction schedule. Include submittals required during the first 60 days of construction. List those submittals required to maintain orderly progress of the Work and those required early because of long lead time for manufacture or fabrication.
  - 3. Final Submittal: Submit concurrently with the first complete submittal of Contractor's construction schedule.
    - a. Submit revised submittal schedule to reflect changes in current status and timing for submittals.
  - 4. Format: Arrange the following information in a tabular format:
    - a. Scheduled date for first submittal.
    - b. Specification Section number and title.
    - c. Submittal category: Action; informational.
    - d. Name of subcontractor.
    - e. Description of the Work covered.
    - f. Scheduled date for Architect's final release or approval.
    - g. Scheduled date of fabrication.
    - h. Scheduled dates for purchasing.
    - i. Scheduled dates for installation.
    - j. Activity or event number.

## 1.7 SUBMITTAL ADMINISTRATIVE REQUIREMENTS

- A. Architect's Digital Data Files: Electronic digital data files of the Contract Drawings will be provided by Architect for Contractor's use in preparing submittals as specified in Section 01 1150 "Electronic Drawings".
1. Architect will furnish Contractor one set of digital data drawing files of the Contract Drawings for use in preparing Shop Drawings and Project record drawings.
    - a. Architect makes no representations as to the accuracy or completeness of digital data drawing files as they relate to the Contract Drawings.
    - b. Digital Drawing Software Program: The Contract Drawings are available in AutoCAD.
    - c. Refer to Section 01 1150 "Electronic Drawings."
    - d. Contractor shall execute a data licensing agreement in the form of Agreement included in Project Manual.
    - e. The following digital data files will be furnished for each appropriate discipline:
      - 1) Floor plans.
      - 2) Reflected ceiling plans.
      - 3) Other files as appropriate to the work.
- B. Coordination: Coordinate preparation and processing of submittals with performance of construction activities.
1. Coordinate each submittal with fabrication, purchasing, testing, delivery, other submittals, and related activities that require sequential activity.
  2. Submit all submittal items required for each Specification Section concurrently unless partial submittals for portions of the Work are indicated on approved submittal schedule.
  3. Submit action submittals and informational submittals required by the same Specification Section as separate packages under separate transmittals.
  4. Coordinate transmittal of different types of submittals for related parts of the Work so processing will not be delayed because of need to review submittals concurrently for coordination.
    - a. Architect reserves the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.
- C. Processing Time: Allow time for submittal review, including time for resubmittals, as follows. Time for review shall commence on Architect's receipt of submittal. No extension of the Contract Time will be authorized because of failure to transmit submittals enough in advance of the Work to permit processing, including resubmittals.
1. Initial Review: Allow 15 working days for initial review of each submittal. Allow additional time if coordination with subsequent submittals is required. Architect will advise Contractor when a submittal being processed must be delayed for coordination.
  2. Intermediate Review: If intermediate submittal is necessary, process it in same manner as initial submittal.
  3. Resubmittal Review: Allow 15 working days for review of each resubmittal. Allow same period as for initial review.

4. Sequential Review: Where sequential review of submittals by Architect's consultants, Owner, or other parties is indicated, allow 15 working days for initial review of each submittal by Architect and one additional party and 5 additional working days for each additional party review required.
  5. Submittal review durations may exceed these minimum durations in the event that submittals are incomplete or otherwise deficient.
- D. Paper Submittals: Place a permanent label or title block on each submittal item for identification.
1. Indicate name of firm or entity that prepared each submittal on label or title block.
  2. Provide a space approximately 6 by 8 inches (150 by 200 mm) on label or beside title block to record Contractor's review and approval markings and action taken by Architect.
  3. Include the following information for processing and recording action taken:
    - a. Project name.
    - b. Date.
    - c. Name of Architect.
    - d. Name of Contractor.
    - e. Name of subcontractor.
    - f. Name of supplier.
    - g. Name of manufacturer.
    - h. Submittal number or other unique identifier, including revision identifier.
      - 1) Submittal number shall use Specification Section number followed by a decimal point and then a sequential number (e.g., 061000.01). Resubmittals shall include an alphabetic suffix after another decimal point (e.g., 061000.01.A).
    - i. Number and title of appropriate Specification Section.
    - j. Drawing number and detail references, as necessary to describe the submittal.
    - k. Location(s) where product is to be installed, as necessary to describe the submittal.
    - l. Other necessary identification.
  4. Additional Paper Copies: Unless additional copies are required for final submittal, and unless Architect observes noncompliance with provisions in the Contract Documents, initial submittal may serve as final submittal.
    - a. Submit one copy of submittal to concurrent reviewer in addition to specified number of copies to Architect.
  5. Transmittal for Paper Submittals: Assemble each submittal individually and appropriately for transmittal and handling. Transmit each submittal using a transmittal form. Architect will discard submittals received from sources other than Contractor.
    - a. Transmittal Form for Paper Submittals: Use form acceptable to the Architect.
    - b. Transmittal Form for Paper Submittals: Provide locations on form for the following information:
      - 1) Project name.
      - 2) Date.
      - 3) Destination (To:).
      - 4) Source (From:).
      - 5) Name and address of Architect.
      - 6) Name of Contractor.
      - 7) Name of firm or entity that prepared submittal.

- 8) Names of subcontractor, manufacturer, and supplier.
- 9) Category and type of submittal.
- 10) Submittal purpose and description.
- 11) Specification Section number and title.
- 12) Specification paragraph number or drawing designation and generic name for each of multiple items.
- 13) Drawing number and detail references, as appropriate.
- 14) Indication of full or partial submittal.
- 15) Transmittal number.
- 16) Submittal and transmittal distribution record.
- 17) Remarks.
- 18) Signature of transmitter.

- E. Electronic Submittals: Identify and incorporate information in each electronic submittal file as follows:
1. Assemble complete submittal package into a single indexed file incorporating submittal requirements of a single Specification Section and transmittal form with links enabling navigation to each item.
  2. Name file with submittal number or other unique identifier, including revision identifier.
    - a. File name shall use project identifier and Specification Section number followed by a decimal point and then a sequential number (e.g., MFH-061000.01). Resubmittals shall include an alphabetic suffix after another decimal point (e.g., MFH- 061000.01.A).
  3. Provide means for insertion to permanently record Contractor's review and approval markings and action taken by Architect.
  4. Transmittal Form for Electronic Submittals: Use software-generated form from electronic project management software or other electronic form acceptable to Owner, containing the following information:
    - a. Project name.
    - b. Date.
    - c. Name and address of Architect.
    - d. Name of Contractor.
    - e. Name of firm or entity that prepared submittal.
    - f. Names of subcontractor, manufacturer, and supplier.
    - g. Category and type of submittal.
    - h. Submittal purpose and description.
    - i. Specification Section number and title.
    - j. Specification paragraph number or drawing designation and generic name for each of multiple items.
    - k. Drawing number and detail references, as appropriate.
    - l. Location(s) where product is to be installed, as appropriate.
    - m. Related physical samples submitted directly.
    - n. Indication of full or partial submittal.
    - o. Transmittal number.

- p. Submittal and transmittal distribution record.
  - q. Other necessary identification.
  - r. Remarks.
5. Metadata: Include the following information as keywords in the electronic submittal file metadata:
- a. Project name.
  - b. Number and title of appropriate Specification Section.
  - c. Manufacturer name.
  - d. Product name.
- F. Options: Identify options requiring selection by Architect.
- G. Deviations and Additional Information: On an attached separate sheet, prepared on Contractor's letterhead, record relevant information, requests for data, revisions other than those requested by Architect on previous submittals, and deviations from requirements in the Contract Documents, including minor variations and limitations. Include same identification information as related submittal.
- H. Resubmittals: Make resubmittals in same form and number of copies as initial submittal.
- 1. Note date and content of previous submittal.
  - 2. Note date and content of revision in label or title block and clearly indicate extent of revision.
  - 3. Resubmit submittals until they are marked with approval notation from Architect's action stamp.
- I. Distribution: Furnish copies of final submittals to manufacturers, subcontractors, suppliers, fabricators, installers, authorities having jurisdiction, and others as necessary for performance of construction activities. Show distribution on transmittal forms.
- J. Use for Construction: Retain complete copies of submittals on Project site. Use only final action submittals that are marked with approval notation from Architect's action stamp.

## **PART 2 – PRODUCTS**

### **2.1 SUBMITTAL PROCEDURES**

- A. General Submittal Procedure Requirements: Prepare and submit submittals required by individual Specification Sections. Types of submittals are indicated in individual Specification Sections.
- 1. Submit electronic submittals via email as PDF electronic files.
    - a. Architect will return annotated file. Annotate and retain one copy of file as an electronic Project record document file.
  - 2. Action Submittals: Submit number of paper copies of each submittal required for Contractor's use, but not more than seven (7). Architect will retain two copies, Architect's consultants will each retain one copy. Additional copies beyond seven will be discarded by the Architect.

3. Informational Submittals: Submit two paper copies of each submittal unless otherwise indicated. Architect will not return copies.
  4. Certificates and Certifications Submittals: Provide a statement that includes signature of entity responsible for preparing certification. Certificates and certifications shall be signed by an officer or other individual authorized to sign documents on behalf of that entity.
    - a. Provide a notarized statement on original paper copy certificates and certifications where indicated.
- B. Product Data: Collect information into a single submittal for each element of construction and type of product or equipment.
1. If information must be specially prepared for submittal because standard published data are not suitable for use, submit as Shop Drawings, not as Product Data.
  2. Mark each copy of each submittal to show which products and options are applicable. Modify standard data to delete information or products which are not pertinent.
  3. Include the following information, as applicable:
    - a. Manufacturer's catalog cuts.
    - b. Manufacturer's product specifications.
    - c. Standard color charts.
    - d. Statement of compliance with specified referenced standards.
    - e. Testing by recognized testing agency.
    - f. Application of testing agency labels and seals.
    - g. Notation of coordination requirements.
    - h. Availability and delivery time information.
  4. For equipment, include the following in addition to the above, as applicable:
    - a. Wiring diagrams showing factory-installed wiring.
    - b. Printed performance curves.
    - c. Operational range diagrams.
    - d. Clearances required to other construction, if not indicated on accompanying Shop Drawings.
  5. Submit Product Data before or concurrent with Samples.
  6. Submit Product Data in the following format:
    - a. PDF electronic file.
- C. Shop Drawings: Prepare Project-specific information, drawn accurately to scale. Do not base Shop Drawings on reproductions of the Contract Documents or standard printed data, unless submittal based on Architect's digital data drawing files is otherwise permitted.
1. Preparation: Fully illustrate requirements in the Contract Documents. Include the following information, as applicable:
    - a. Identification of products.
    - b. Schedules.
    - c. Compliance with specified standards.
    - d. Notation of coordination requirements.
    - e. Notation of dimensions established by field measurement.
    - f. Relationship and attachment to adjoining construction clearly indicated.
    - g. Seal and signature of professional engineer if specified.
  2. Sheet Size: Except for templates, patterns, and similar full-size drawings, submit Shop Drawings on sheets at least 8-1/2 by 11 inches (215 by 280 mm), but no larger than 30 by 42 inches (750 by 1067 mm).

3. Submit Shop Drawings in the following format:
  - a. PDF electronic file.
  
- D. Samples: Submit Samples for review of kind, color, pattern, and texture for a check of these characteristics with other elements and for a comparison of these characteristics between submittal and actual component as delivered and installed.
  1. Transmit Samples that contain multiple, related components such as accessories together in one submittal package.
  2. Identification: Attach label on unexposed side of Samples that includes the following:
    - a. Generic description of Sample.
    - b. Product name and name of manufacturer.
    - c. Sample source.
    - d. Number and title of applicable Specification Section.
    - e. Specification paragraph number and generic name of each item.
  3. For projects where electronic submittals are required, provide corresponding electronic submittal of Sample transmittal, digital image file illustrating Sample characteristics, and identification information for record.
  4. Disposition: Maintain sets of approved Samples at Project site, available for quality-control comparisons throughout the course of construction activity. Sample sets may be used to determine final acceptance of construction associated with each set.
    - a. Samples that may be incorporated into the Work are indicated in individual Specification Sections. Such Samples must be in an undamaged condition at time of use.
    - b. Samples not incorporated into the Work, or otherwise designated as Owner's property, are the property of Contractor.
  5. Samples for Initial Selection: Submit manufacturer's color charts consisting of units or sections of units showing the full range of colors, textures, and patterns available.
    - a. Number of Samples: Submit two full set(s) of available choices where color, pattern, texture, or similar characteristics are required to be selected from manufacturer's product line. Architect will return submittal with options selected.
  6. Samples for Verification: Submit full-size units or Samples of size indicated, prepared from same material to be used for the Work, cured and finished in manner specified, and physically identical with material or product proposed for use, and that show full range of color and texture variations expected. Samples include, but are not limited to, the following: partial sections of manufactured or fabricated components; small cuts or containers of materials; complete units of repetitively used materials; swatches showing color, texture, and pattern; color range sets; and components used for independent testing and inspection.
    - a. Number of Samples: Submit maximum of seven sets of Samples. Architect will retain two Sample sets; remainder will be returned. Mark up and retain one returned Sample set as a project record sample.
      - 1) Submit a single Sample where assembly details, workmanship, fabrication techniques, connections, operation, and other similar characteristics are to be demonstrated.
      - 2) If variation in color, pattern, texture, or other characteristic is inherent in material or product represented by a Sample, submit at

least three sets of paired units that show approximate limits of variations.

- E. Colors And Patterns:
1. Submit color and pattern selections for all products offering a choice of these attributes unless a specific color or pattern is referenced in the Contract Documents.
  2. Submit within 35 days of Notice of Award a list of all required color selections organized by product, including manufacturer and model. Include samples of manufacturer's complete color range for all products.
  3. Architect will not select colors or patterns until samples of all items requiring selections have been submitted. Architect will not make partial color selections.
  4. Failure to submit all color selections as specified above, thus requiring additional unanticipated time for the Architect to make selections will not be basis for extension of Contract Time.
  5. Architect will make color selections within 30 working days following complete submittal of samples. This period will commence with the receipt of the latest incremental submittal, as applicable.
  6. Architect will issue Color Schedule.
- F. Product Schedule: As required in individual Specification Sections, prepare a written summary indicating types of products required for the Work and their intended location. Include the following information in tabular form:
1. Type of product. Include unique identifier for each product indicated in the Contract Documents or assigned by Contractor if none is indicated.
  2. Manufacturer and product name, and model number if applicable.
  3. Number and name of room or space.
  4. Location within room or space.
  5. Submit product schedule in the following format:
    - a. PDF electronic file.
- G. Coordination Drawing Submittals: Comply with requirements specified in Section 01 3100 "Project Management and Coordination."
- H. Contractor's Construction Schedule: Comply with requirements specified in Section 01 3200 "Construction Progress Documentation."
- I. Application for Payment and Schedule of Values: Comply with requirements specified in Section 01 2900 "Payment Procedures."
- J. Test and Inspection Reports and Schedule of Tests and Inspections Submittals: Comply with requirements specified in Section 01 4000 "Quality Requirements."
- K. Closeout Submittals and Maintenance Material Submittals: Comply with requirements specified in Section 01 7700 "Closeout Procedures."
- L. Maintenance Data: Comply with requirements specified in Section 01 7823 "Operation and Maintenance Data."

- M. Qualification Data: Prepare written information that demonstrates capabilities and experience of firm or person. Include lists of completed projects with project names and addresses, contact information of architects and owners, and other information specified.
- N. Welding Certificates: Prepare written certification that welding procedures and personnel comply with requirements in the Contract Documents. Submit record of Welding Procedure Specification and Procedure Qualification Record on AWS forms. Include names of firms and personnel certified.
- O. Installer Certificates: Submit written statements on manufacturer's letterhead certifying that Installer complies with requirements in the Contract Documents and, where required, is authorized by manufacturer for this specific Project.
- P. Manufacturer Certificates: Submit written statements on manufacturer's letterhead certifying that manufacturer complies with requirements in the Contract Documents. Include evidence of manufacturing experience where required.
- Q. Product Certificates: Submit written statements on manufacturer's letterhead certifying that product complies with requirements in the Contract Documents.
- R. Material Certificates: Submit written statements on manufacturer's letterhead certifying that material complies with requirements in the Contract Documents.
- S. Material Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting test results of material for compliance with requirements in the Contract Documents.
- T. Product Test Reports: Submit written reports indicating that current product produced by manufacturer complies with requirements in the Contract Documents. Base reports on evaluation of tests performed by manufacturer and witnessed by a qualified testing agency, or on comprehensive tests performed by a qualified testing agency.
- U. Research Reports: Submit written evidence, from a model code organization acceptable to authorities having jurisdiction, that product complies with building code in effect for Project. Include the following information:
  - 1. Name of evaluation organization.
  - 2. Date of evaluation.
  - 3. Time period when report is in effect.
  - 4. Product and manufacturers' names.
  - 5. Description of product.
  - 6. Test procedures and results.
  - 7. Limitations of use.
- V. Preconstruction Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of tests performed before installation of product, for compliance with performance requirements in the Contract Documents.
- W. Compatibility Test Reports: Submit reports written by a qualified testing agency, on testing agency's standard form, indicating and interpreting results of compatibility tests performed

before installation of product. Include written recommendations for primers and substrate preparation needed for adhesion.

- X. Field Test Reports: Submit written reports indicating and interpreting results of field tests performed either during installation of product or after product is installed in its final location, for compliance with requirements in the Contract Documents.
- Y. Design Data: Prepare and submit written and graphic information, including, but not limited to, performance and design criteria, list of applicable codes and regulations, and calculations. Include list of assumptions and other performance and design criteria and a summary of loads. Include load diagrams if applicable. Provide name and version of software, if any, used for calculations. Include page numbers.

## **2.2 DELEGATED-DESIGN SERVICES**

- A. Performance and Design Criteria: Where professional design services or certifications by a design professional are specifically required of Contractor by the Contract Documents, provide products and systems complying with specific performance and design criteria indicated.
  - 1. If criteria indicated are not sufficient to perform services or certification required, submit a written request for additional information to Architect.
- B. Delegated-Design Services Certification: In addition to Shop Drawings, Product Data, and other required submittals, submit digitally signed PDF electronic file and three paper copies of certificate, signed and sealed by the responsible design professional, for each product and system specifically assigned to Contractor to be designed or certified by a design professional.
  - 1. Indicate that products and systems comply with performance and design criteria in the Contract Documents. Include list of codes, loads, and other factors used in performing these services.
- C. Contractor is notified that significant lead time is required for delegated design review by Agency or Authority Having Jurisdiction and shall schedule work accordingly. No extension of Contract Time will be allowed for delays incurred by delegated design review.
  - 1. The Architect is not responsible for Agency or Authority Having Jurisdiction delays in delegated design review.

## **3 PART 3 – EXECUTION**

### **3.1 CONTRACTOR'S REVIEW**

- A. Action and Informational Submittals: Review each submittal and check for coordination with other Work of the Contract and for compliance with the Contract Documents. Note corrections and field dimensions. Mark with approval stamp before submitting to Architect.
  - 1. Assume full responsibility for coordinating and verifying information, quantities and dimensions shown in submittals.
  - 2. Note all deviations from the Contract Documents in writing and request Architect approval of deviation in writing.

3. Direct Architect's attention in writing to all changes made in submittals other than those specifically requested by Architect. Changes not so noted will be considered unreviewed.
- B. Project Closeout and Maintenance Material Submittals: See requirements in Section 01 7700 "Closeout Procedures."
  - C. Approval Stamp: Stamp each submittal with a uniform, approval stamp. Include Project name and location, submittal number, Specification Section title and number, name of reviewer, date of Contractor's approval, and statement certifying that submittal has been reviewed, checked, and approved for compliance with the Contract Documents.
  - D. Transmit submittals in groups containing all associated items to ensure availability of information during review. Refer to more specific requirements in the technical divisions.
    1. Do not submit partial submittals.
    2. Incomplete or partial submittals may be returned for enhancement. No extension of time will be allowed for delays related to incomplete submittals.
  - E. Stagger submittals for items or products with shorter lead times, reduced coordination needs with other work, or which will be needed later in the construction schedule. Prioritize and coordinate submittals only according to jointly-agreed initial list. Items requiring longer lead times shall be submitted first.
  - F. Do not provide submittals out-of-sequence. Submittals forwarded earlier than indicated on the jointly agreed schedule may be retained by the Architect for later processing. Required submittals which are not shown on the jointly-agreed schedule, or forwarded at times varying from the agreed schedule will be processed at the Architect's option. Minimum review period may be extended by the Architect for early or out-of-sequence submittals.
  - G. Accept reviewed submittals in the conditions delivered by the Architect. Architect reserves right to manage submittal review and stamping in any manner deemed expedient by the Architect and acceptable to the Owner and Authority Having Jurisdiction. These conditions of distribution may include, but not be limited to:
    1. Retention of all original documentation submitted and distribution of copies only, including original signatures of Agency reviewers, other Authorities Having Jurisdiction, Contractor's Design Professionals.
    2. Stamping/signature of the cover page only, not each drawing, document or item submitted.
    3. Summarizing complex comments in the form of memo or summary notation, without copying or enumeration of each and every occurrence of a comment. Such copying and enumeration, if required, shall be performed by the Contractor.
    4. Conditional or limited degree of approval/acceptance such as "Color/Texture Only" and similar reservations.
  - H. Distribute only submittals with Architect/Engineer (and Authority Having Jurisdiction as applicable) stamps of review. Contractor is responsible for coordination of submittals and comments following review. Contractor to provide all additional reproduction costs for copies required by the Contractor at his expense. No additional costs will be authorized for Contractor costs pertaining to submittals.

- I. Ensure that all reviewed Submittals are distributed intact with all comments, memos and attachments in place as received from the Architect. Owner and Architect will not be responsible for errors due to Contractor failure to transmit, coordinate or record Architect or Engineer comments.

### 3.2 ARCHITECT'S ACTION

- A. Action Submittals: Architect will review each submittal, make marks to indicate corrections or revisions required, and return it. Architect will stamp each submittal with an action stamp and will mark stamp appropriately to indicate action.
- B. Informational Submittals: Architect will review each submittal and will not return it, or will return it if it does not comply with requirements. Architect will forward each submittal to appropriate party.
- C. Partial submittals prepared for a portion of the Work will be reviewed when use of partial submittals has received prior approval from Architect.
- D. Incomplete submittals are unacceptable, will be considered nonresponsive, and will be returned for resubmittal without review.
- E. Submittals not required by the Contract Documents may be returned by the Architect without action.
- F. Architect will respond in writing to Contractor's written notifications of deviations from Contract Documents. No deviations from Contract Documents will be covered by the Architect's review unless requested by the Contractor in writing and approved by the Architect in writing.
- G. Submittals reviewed by the Architect which have been stamped shall be deemed to have the action stamp language affixed and made a part thereof, regardless of the initial or subsequent readability of the actual stamp.
- H. Architect's review of submittals has, as a primary objective, to assist in the completion of the project on time and in conformance with the Contract requirements by permitting review of material and fabricated items prior to ordering. Architect's review of submittals is based only on the data presented and extends only to conformance with general design intent and information contained in the Contract Documents.
- I. Architect's review of submittals does not constitute final acceptance or unqualified approval of items or work proposed or put in place, nor does it constitute acceptance of responsibility for the accuracy, coordination or completeness of submittals. Architect's review of submittals does not relieve the Contractor from the responsibility for errors, omissions, or compliance with all the requirements of the Contract Documents.
- J. Contractor shall accept reviewed submittals in the conditions delivered by the Architect. Architect reserves right to manage submittal review and stamping in any manner deemed expedient by the Architect and acceptable to the Owner and Authorities Having Jurisdiction. These conditions of distribution may include, but not be limited to:

1. Retention of all original documentation submitted and distribution of copies only, including original signatures of Agency review, other Authorities Having Jurisdiction, Design Professionals retained by the Contractor.
2. Stamping/signature of the cover page only, not each drawing, document or item submitted.
3. Summarizing complex comments in the form of memo or summary notation, without copying or enumeration of each and every occurrence of a comment. Such copying and enumeration shall be performed by the Contractor.
4. Conditional or limited degree of approval/acceptance such as "Color/Texture Only" and similar reservations.
5. Contractor shall ensure that all reviewed Submittals are distributed intact with all comments, memos and attachments in place as received from the Architect. Owner nor Architect will not be responsible for errors due to failure to coordinate or record A/E comments.

**- END OF SECTION -**

## - SECTION 01 4000 - QUALITY REQUIREMENTS

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for quality assurance and quality control.
- B. Testing and inspecting services are required to verify compliance with requirements specified or indicated. These services do not relieve Contractor of responsibility for compliance with the Contract Document requirements.
  - 1. Specific quality-assurance and -control requirements for individual construction activities are specified in the Sections that specify those activities. Requirements in those Sections may also cover production of standard products.
  - 2. Specified tests, inspections, and related actions do not limit Contractor's other quality-assurance and -control procedures that facilitate compliance with the Contract Document requirements.
  - 3. Requirements for Contractor to provide quality-assurance and -control services required by Architect, Owner, Commissioning Authority, or authorities having jurisdiction are not limited by provisions of this Section.
  - 4. Specific test and inspection requirements are not specified in this Section.

#### 1.3 DEFINITIONS

- A. Quality-Assurance Services: Activities, actions, and procedures performed before and during execution of the Work to guard against defects and deficiencies and substantiate that proposed construction will comply with requirements.
- B. Quality-Control Services: Tests, inspections, procedures, and related actions during and after execution of the Work to evaluate that actual products incorporated into the Work and completed construction comply with requirements. Services do not include contract enforcement activities performed by Architect.
- C. Mockups: Full-size physical assemblies that are constructed on-site. Mockups are constructed to verify selections made under Sample submittals; to demonstrate aesthetic effects and, where indicated, qualities of materials and execution; to review coordination, testing, or operation; to show interface between dissimilar materials; and to demonstrate compliance

with specified installation tolerances. Mockups are not Samples. Unless otherwise indicated, approved mockups establish the standard by which the Work will be judged.

1. Laboratory Mockups: Full-size physical assemblies constructed at testing facility to verify performance characteristics.
  2. Integrated Exterior Mockups: Mockups of the exterior envelope erected separately from the building but on Project site, consisting of multiple products, assemblies, and subassemblies.
  3. Room Mockups: Mockups of typical interior spaces complete with wall, floor, and ceiling finishes, doors, windows, millwork, casework, specialties, furnishings and equipment, and lighting.
- D. Preconstruction Testing: Tests and inspections performed specifically for Project before products and materials are incorporated into the Work, to verify performance or compliance with specified criteria.
- E. Product Testing: Tests and inspections that are performed by an NRTL, an NVLAP, or a testing agency qualified to conduct product testing and acceptable to authorities having jurisdiction, to establish product performance and compliance with specified requirements.
- F. Source Quality-Control Testing: Tests and inspections that are performed at the source, e.g., plant, mill, factory, or shop.
- G. Field Quality-Control Testing: Tests and inspections that are performed on-site for installation of the Work and for completed Work.
- H. Testing Agency: An entity engaged to perform specific tests, inspections, or both. Testing laboratory shall mean the same as testing agency.
- I. Installer/Applicator/Erector: Contractor or another entity engaged by Contractor as an employee, Subcontractor, or Sub-subcontractor, to perform a particular construction operation, including installation, erection, application, and similar operations.
1. Use of trade-specific terminology in referring to a trade or entity does not require that certain construction activities be performed by accredited or unionized individuals, or that requirements specified apply exclusively to specific trade(s).
- J. Experienced: When used with an entity or individual, "experienced" means having successfully completed a minimum of five previous projects similar in nature, size, and extent to this Project; being familiar with special requirements indicated; and having complied with requirements of authorities having jurisdiction.

#### **1.4 CONFLICTING REQUIREMENTS**

- A. Referenced Standards: If compliance with two or more standards is specified and the standards establish different or conflicting requirements for minimum quantities or quality levels, comply with the most stringent requirement. Refer conflicting requirements that are different, but apparently equal, to Architect for a decision before proceeding.
- B. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable limits.

To comply with these requirements, indicated numeric values are minimum or maximum, as appropriate, for the context of requirements. Refer uncertainties to Architect for a decision before proceeding.

### 1.5 ACTION SUBMITTALS

- A. Shop Drawings: For integrated exterior and laboratory mockups, provide plans, sections, and elevations, indicating materials and size of mockup construction.
  - 1. Indicate manufacturer and model number of individual components.
  - 2. Provide axonometric drawings for conditions difficult to illustrate in two dimensions.

### 1.6 INFORMATIONAL SUBMITTALS

- A. Contractor's Quality-Control Plan: For quality-assurance and quality-control activities and responsibilities.
- B. Qualification Data: For Contractor's quality-control personnel.
- C. Contractor's Statement of Responsibility: When required by authorities having jurisdiction, submit copy of written statement of responsibility sent to authorities having jurisdiction before starting work on the following systems:
  - 1. Seismic-force-resisting system, designated seismic system, or component listed in the designated seismic system quality-assurance plan prepared by Architect.
  - 2. Main wind-force-resisting system or a wind-resisting component listed in the wind-force-resisting system quality-assurance plan prepared by Architect.
- D. Testing Agency Qualifications: For testing agencies specified in "Quality Assurance" Article to demonstrate their capabilities and experience. Include proof of qualifications in the form of a recent report on the inspection of the testing agency by a recognized authority.
- E. Schedule of Tests and Inspections: Prepare in tabular form and include the following:
  - 1. Specification Section number and title.
  - 2. Entity responsible for performing tests and inspections.
  - 3. Description of test and inspection.
  - 4. Identification of applicable standards.
  - 5. Identification of test and inspection methods.
  - 6. Number of tests and inspections required.
  - 7. Time schedule or time span for tests and inspections.
  - 8. Requirements for obtaining samples.
  - 9. Unique characteristics of each quality-control service.

### 1.7 CONTRACTOR'S QUALITY-CONTROL PLAN

- A. Quality-Control Plan, General: Submit quality-control plan within 10 days of Notice to Proceed, and not less than five days prior to preconstruction conference. Submit in format acceptable to Architect. Identify personnel, procedures, controls, instructions, tests, records, and forms to be used to carry out Contractor's quality-assurance and quality-control responsibilities. Coordinate with Contractor's construction schedule.

- B. Quality-Control Personnel Qualifications: Engage qualified full-time personnel trained and experienced in managing and executing quality-assurance and quality-control procedures similar in nature and extent to those required for Project.
  - 1. Project quality-control manager may also serve as Project superintendent [shall not have other Project responsibilities].
- C. Submittal Procedure: Describe procedures for ensuring compliance with requirements through review and management of submittal process. Indicate qualifications of personnel responsible for submittal review.
- D. Testing and Inspection: In quality-control plan, include a comprehensive schedule of Work requiring testing or inspection, including the following:
  - 1. Contractor-performed tests and inspections including subcontractor-performed tests and inspections. Include required tests and inspections and Contractor-elected tests and inspections.
  - 2. Special inspections required by authorities having jurisdiction and indicated on the "Statement of Special Inspections."
  - 3. Owner-performed tests and inspections indicated in the Contract Documents, including tests and inspections indicated to be performed by the Commissioning Authority.
- E. Continuous Inspection of Workmanship: Describe process for continuous inspection during construction to identify and correct deficiencies in workmanship in addition to testing and inspection specified. Indicate types of corrective actions to be required to bring work into compliance with standards of workmanship established by Contract requirements and approved mockups.
- F. Monitoring and Documentation: Maintain testing and inspection reports including log of approved and rejected results. Include work Architect has indicated as nonconforming or defective. Indicate corrective actions taken to bring nonconforming work into compliance with requirements. Comply with requirements of authorities having jurisdiction.

## 1.8 REPORTS AND DOCUMENTS

- A. Test and Inspection Reports: Prepare and submit certified written reports specified in other Sections. Include the following:
  - 1. Date of issue.
  - 2. Project title and number.
  - 3. Name, address, and telephone number of testing agency.
  - 4. Dates and locations of samples and tests or inspections.
  - 5. Names of individuals making tests and inspections.
  - 6. Description of the Work and test and inspection method.
  - 7. Identification of product and Specification Section.
  - 8. Complete test or inspection data.
  - 9. Test and inspection results and an interpretation of test results.

10. Record of temperature and weather conditions at time of sample taking and testing and inspecting.
  11. Comments or professional opinion on whether tested or inspected Work complies with the Contract Document requirements.
  12. Name and signature of laboratory inspector.
  13. Recommendations on retesting and reinspecting.
- B. Manufacturer's Technical Representative's Field Reports: Prepare written information documenting manufacturer's technical representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of technical representative making report.
  2. Statement on condition of substrates and their acceptability for installation of product.
  3. Statement that products at Project site comply with requirements.
  4. Summary of installation procedures being followed, whether they comply with requirements and, if not, what corrective action was taken.
  5. Results of operational and other tests and a statement of whether observed performance complies with requirements.
  6. Statement whether conditions, products, and installation will affect warranty.
  7. Other required items indicated in individual Specification Sections.
- C. Factory-Authorized Service Representative's Reports: Prepare written information documenting manufacturer's factory-authorized service representative's tests and inspections specified in other Sections. Include the following:
1. Name, address, and telephone number of factory-authorized service representative making report.
  2. Statement that equipment complies with requirements.
  3. Results of operational and other tests and a statement of whether observed performance complies with requirements.
  4. Statement whether conditions, products, and installation will affect warranty.
  5. Other required items indicated in individual Specification Sections.
- D. Permits, Licenses, and Certificates: For Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents, established for compliance with standards and regulations bearing on performance of the Work.

## **1.9 1.9 QUALITY ASSURANCE**

- A. General: Qualifications paragraphs in this article establish the minimum qualification levels required; individual Specification Sections specify additional requirements.
- B. Manufacturer Qualifications: A firm experienced in manufacturing products or systems similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.
- C. Fabricator Qualifications: A firm experienced in producing products similar to those indicated for this Project and with a record of successful in-service performance, as well as sufficient production capacity to produce required units.

- D. Installer Qualifications: A firm or individual experienced in installing, erecting, or assembling work similar in material, design, and extent to that indicated for this Project, whose work has resulted in construction with a record of successful in-service performance.
- E. Professional Engineer Qualifications: A professional engineer who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing engineering services of the kind indicated. Engineering services are defined as those performed for installations of the system, assembly, or product that are similar in material, design, and extent to those indicated for this Project.
- F. Specialists: Certain Specification Sections require that specific construction activities shall be performed by entities who are recognized experts in those operations. Specialists shall satisfy qualification requirements indicated and shall be engaged for the activities indicated.
  - 1. Requirements of authorities having jurisdiction shall supersede requirements for specialists.
- G. Testing Agency Qualifications: An NRTL, an NVLAP, or an independent agency with the experience and capability to conduct testing and inspecting indicated, as documented according to ASTM E 329; and with additional qualifications specified in individual Sections; and, where required by authorities having jurisdiction, that is acceptable to authorities.
  - 1. NRTL: A nationally recognized testing laboratory according to 29 CFR 1910.7.
  - 2. NVLAP: A testing agency accredited according to NIST's National Voluntary Laboratory Accreditation Program.
- H. Manufacturer's Technical Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to observe and inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- I. Factory-Authorized Service Representative Qualifications: An authorized representative of manufacturer who is trained and approved by manufacturer to inspect installation of manufacturer's products that are similar in material, design, and extent to those indicated for this Project.
- J. Preconstruction Testing: Where testing agency is indicated to perform preconstruction testing for compliance with specified requirements for performance and test methods, comply with the following:
  - 1. Contractor responsibilities include the following:
    - a. Provide test specimens representative of proposed products and construction.
    - b. Submit specimens in a timely manner with sufficient time for testing and analyzing results to prevent delaying the Work.
    - c. Provide sizes and configurations of test assemblies, mockups, and laboratory mockups to adequately demonstrate capability of products to comply with performance requirements.
    - d. Build site-assembled test assemblies and mockups using installers who will perform same tasks for Project.
    - e. Build laboratory mockups at testing facility using personnel, products, and methods of construction indicated for the completed Work.

- f. When testing is complete, remove test specimens, assemblies, mockups, and laboratory mockups; do not reuse products on Project.
  2. Testing Agency Responsibilities: Submit a certified written report of each test, inspection, and similar quality-assurance service to Architect and Commissioning Authority, with copy to Contractor. Interpret tests and inspections and state in each report whether tested and inspected work complies with or deviates from the Contract Documents.
- K. Mockups: Before installing portions of the Work requiring mockups, build mockups for each form of construction and finish required to comply with the following requirements, using materials indicated for the completed Work:
  1. Build mockups in location and of size indicated or, if not indicated, as directed by Architect.
  2. Notify Architect seven days in advance of dates and times when mockups will be constructed.
  3. Employ supervisory personnel who will oversee mockup construction. Employ workers that will be employed during the construction at Project.
  4. Demonstrate the proposed range of aesthetic effects and workmanship.
  5. Obtain Architect's approval of mockups before starting work, fabrication, or construction.
    - a. Allow seven days for initial review and each re-review of each mockup.
  6. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
  7. Demolish and remove mockups when directed unless otherwise indicated.
- L. Integrated Exterior Mockups: Construct integrated exterior mockup according to approved Shop Drawings. Coordinate installation of exterior envelope materials and products for which mockups are required in individual Specification Sections, along with supporting materials.
- M. Laboratory Mockups: Comply with requirements of preconstruction testing and those specified in individual Specification Sections.
- N. Room Mockups: Construct room mockups incorporating required materials and assemblies, finished according to requirements. Provide required lighting and additional lighting where required to enable Architect to evaluate quality of the Work.

### **1.10 QUALITY CONTROL**

- A. Owner Responsibilities: Where quality-control services are indicated as Owner's responsibility, Owner will engage a qualified testing agency to perform these services.
  1. Owner will furnish Contractor with names, addresses, and telephone numbers of testing agencies engaged and a description of types of testing and inspecting they are engaged to perform.
  2. Payment for these services will be made from testing and inspecting allowances, as authorized by Change Orders.
  3. Costs for retesting and reinspecting construction that replaces or is necessitated by work that failed to comply with the Contract Documents will be charged to Contractor, and the Contract Sum will be adjusted by Change Order.

- B. Contractor Responsibilities: Tests and inspections not explicitly assigned to Owner are Contractor's responsibility. Perform additional quality-control activities required to verify that the Work complies with requirements, whether specified or not.
1. Unless otherwise indicated, provide quality-control services specified and those required by authorities having jurisdiction. Perform quality-control services required of Contractor by authorities having jurisdiction, whether specified or not.
  2. Where services are indicated as Contractor's responsibility, engage a qualified testing agency to perform these quality-control services.
    - a. Contractor shall not employ same entity engaged by Owner, unless agreed to in writing by Owner.
  3. Notify testing agencies at least 48 hours in advance of time when Work that requires testing or inspecting will be performed.
  4. Where quality-control services are indicated as Contractor's responsibility, submit a certified written report, in duplicate, of each quality-control service.
  5. Testing and inspecting requested by Contractor and not required by the Contract Documents are Contractor's responsibility.
  6. Submit additional copies of each written report directly to authorities having jurisdiction, when they so direct.
- C. Manufacturer's Field Services: Where indicated, engage a factory-authorized service representative to inspect field-assembled components and equipment installation, including service connections. Report results in writing as specified in Section 01 3300 "Submittal Procedures."
- D. Manufacturer's Technical Services: Where indicated, engage a manufacturer's technical representative to observe and inspect the Work. Manufacturer's technical representative's services include participation in preinstallation conferences, examination of substrates and conditions, verification of materials, observation of Installer activities, inspection of completed portions of the Work, and submittal of written reports.
- E. Retesting/Reinspecting: Regardless of whether original tests or inspections were Contractor's responsibility, provide quality-control services, including retesting and reinspecting, for construction that replaced Work that failed to comply with the Contract Documents.
- F. Testing Agency Responsibilities: Cooperate with Architect, Commissioning Authority and Contractor in performance of duties. Provide qualified personnel to perform required tests and inspections.
1. Notify Architect, Commissioning Authority, and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
  2. Determine the location from which test samples will be taken and in which in-situ tests are conducted.
  3. Conduct and interpret tests and inspections and state in each report whether tested and inspected work complies with or deviates from requirements.
  4. Submit a certified written report, in duplicate, of each test, inspection, and similar quality-control service through Contractor.
  5. Do not release, revoke, alter, or increase the Contract Document requirements or approve or accept any portion of the Work.
  6. Do not perform any duties of Contractor.

- G. Associated Services: Cooperate with agencies performing required tests, inspections, and similar quality-control services, and provide reasonable auxiliary services as requested. Notify agency sufficiently in advance of operations to permit assignment of personnel. Provide the following:
1. Access to the Work.
  2. Incidental labor and facilities necessary to facilitate tests and inspections.
  3. Adequate quantities of representative samples of materials that require testing and inspecting. Assist agency in obtaining samples.
  4. Facilities for storage and field curing of test samples.
  5. Delivery of samples to testing agencies.
  6. Preliminary design mix proposed for use for material mixes that require control by testing agency.
  7. Security and protection for samples and for testing and inspecting equipment at Project site.
- H. Coordination: Coordinate sequence of activities to accommodate required quality-assurance and control services with a minimum of delay and to avoid necessity of removing and replacing construction to accommodate testing and inspecting.
1. Schedule times for tests, inspections, obtaining samples, and similar activities.
- I. Schedule of Tests and Inspections: Prepare a schedule of tests, inspections, and similar quality-control services required by the Contract Documents as a component of Contractor's quality-control plan. Coordinate and submit concurrently with Contractor's construction schedule. Update as the Work progresses.
1. Distribution: Distribute schedule to Owner, Architect, Commissioning Authority, testing agencies, and each party involved in performance of portions of the Work where tests and inspections are required.

### **1.11 SPECIAL TESTS AND INSPECTIONS**

- A. Special Tests and Inspections: Owner will engage a qualified testing agency to conduct special tests and inspections required by authorities having jurisdiction as the responsibility of Owner, and as follows:
1. Verifying that manufacturer maintains detailed fabrication and quality-control procedures and reviews the completeness and adequacy of those procedures to perform the Work.
  2. Notifying Architect, Commissioning Authority, and Contractor promptly of irregularities and deficiencies observed in the Work during performance of its services.
  3. Submitting a certified written report of each test, inspection, and similar quality-control service to Architect and Commissioning Authority with copy to Contractor and to authorities having jurisdiction.
  4. Submitting a final report of special tests and inspections at Substantial Completion, which includes a list of unresolved deficiencies.
  5. Interpreting tests and inspections and stating in each report whether tested and inspected work complies with or deviates from the Contract Documents.
  6. Retesting and reinspecting corrected work.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 – EXECUTION**

### **3.1 TEST AND INSPECTION LOG**

- A. Test and Inspection Log: Prepare a record of tests and inspections. Include the following:
  - 1. Date test or inspection was conducted.
  - 2. Description of the Work tested or inspected.
  - 3. Date test or inspection results were transmitted to Architect.
  - 4. Identification of testing agency or special inspector conducting test or inspection.
  
- B. Maintain log at Project site. Post changes and revisions as they occur. Provide access to test and inspection log for Architect's, Commissioning Authority's, reference during normal working hours.

### **3.2 REPAIR AND PROTECTION**

- A. General: On completion of testing, inspecting, sample taking, and similar services, repair damaged construction and restore substrates and finishes.
  - 1. Provide materials and comply with installation requirements specified in other Specification Sections or matching existing substrates and finishes. Restore patched areas and extend restoration into adjoining areas with durable seams that are as invisible as possible. Comply with the Contract Document requirements for cutting and patching in Section 01 7300 "Execution".
  
- B. Protect construction exposed by or for quality-control service activities.
  
- C. Repair and protection are Contractor's responsibility, regardless of the assignment of responsibility for quality-control services.

**- END OF SECTION -**

## - SECTION 01 4200 - REFERENCES

---

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 DEFINITIONS

- A. General: Contract definitions are included in the Conditions of the Contract.
- B. Addenda: Written or graphic instruments issued prior to the opening of Bids, which clarify, correct or change the bidding requirements or the Contract Documents. Addenda shall not include the minutes of the Pre-bid Conference and Site Visit.
- C. Additive Bid: The sum to be added to the Base Bid if the change in scope of work as described in Additive Bid is accepted by Owner.
- D. Agreement: Agreement is the basic contract document that binds the parties to construction Work. Agreement defines relationships and obligations between Owner and Contractor and by reference incorporates Conditions of Contract, Drawings, and Specifications and contains Addenda and all Modifications subsequent to execution of Contract.
- E. Alternate: Work added to or deducted from the Base Bid, if accepted by Owner.
- F. "Approved": When used to convey Architect's action on Contractor's submittals, applications, and requests, "approved" is limited to Architect's duties and responsibilities as stated in the Conditions of the Contract. In no case will "approval" by Architect/Engineer be interpreted as a release of Contractor from responsibilities to fulfill requirements of contract documents.
- G. Approved Equal: Approved in writing by Owner as being of equivalent quality, utility and appearance.
- H. Architect Or Architect/Engineer: The person holding a valid Architect's license, whose firm has been designated as the Architect to provide architectural services on the project.
- I. Bid: The offer or proposal of the Bidder submitted on the prescribed form setting forth the prices for the Work to be performed.
- J. Bidder: One who submits a Bid.
- K. By Owner: Work that will be performed by Owner or its agents at the Owner's expense.

- L. By Others: Work that is outside scope of Work to be performed by Contractor under this Contract, which will be performed by Owner, other contractors, or other means.
- M. Change Order: A written instrument prepared by Architect and signed by Architect, Owner and Contractor, stating their agreement upon all of the following:
  - 1. a change in the Work,
  - 2. the amount of the adjustment in the Contract Sum, if any, and
  - 3. the amount of the adjustment in the Contract Time, if any.
- N. Concealed: Work not exposed to view in the finished Work, including within or behind various construction elements.
- O. Contract Conditions: Conditions of Contract define basic rights, responsibilities and relationships of Contractor and Owner and consists of two parts: General Conditions and Supplementary Conditions.
  - 1. General Conditions are general clauses, which are common to the Owner Contracts.
  - 2. Supplementary conditions modify or supplement General Conditions to meet specific requirements for this Contract.
- P. Contract Documents: Contract Documents shall consist of the documents identified as the Contract Documents in Contract Agreement, plus all changes, addenda and modifications thereto.
- Q. Contract Modification: Either:
  - 1. a written amendment to Contract signed by Contractor and Owner; or
  - 2. a Change Order; or
  - 3. a written directive for a minor change in the Work issued by Architect.
- R. Contract Sum: The sum stated in the Agreement and, including authorized adjustments, the total amount payable by Owner to Contractor for performance of the Work and the Contract Documents. (Also referred to as the Contract Price.)
- S. Contract Times: The number or numbers of days or the dates stated in the Agreement (i) to achieve substantial completion of the Work or designated milestones and/or (ii) to complete the Work so that it is ready for final payment and is accepted.
- T. Contractor: The person or entity identified as such in the Agreement and referred to throughout the Contract Documents as if singular in number and neuter in gender. The term "Contractor" means the Contractor or its authorized representative.
- U. Contractor's Employees: Persons engaged in execution of Work under Contract as direct employees of Contractor, as subcontractors, or as employees of subcontractors.
- V. Date of Substantial Completion: Date of Substantial Completion of Work or designated portion thereof is date certified by Architect when construction is sufficiently complete in accordance with Contract Documents for Owner to occupy Work or designated portion thereof for its use for which it is intended.
- W. Day: One calendar day, unless the word "day" is specifically modified to the contrary.

- X. Deductive Bid: The sum to be subtracting to the Base Bid if the change in scope of work as described in Deductive Bid is accepted by Owner.
- Y. Defective: An adjective which, when modifying the word "Work", refers to Work that is unsatisfactory or unsuited for the use intended, faulty, or deficient, that it does not conform to the Contract Documents, or does not meet the requirements of any inspection, reference standard, test or approval referred to in the Contract Documents (including but not limited to approval of samples and "or equal" items), or has been damaged prior to final payment (unless responsibility for the protection thereof has been assumed by Owner). Architect is the judge of whether Work is defective.
- Z. "Directed": A command or instruction by Architect. Other terms including "requested," "authorized," "selected," "approved," "required," and "permitted" have the same meaning as "directed." However, no such implied meaning will be interpreted to extend the Architect's/Engineer's responsibility into the Contractor's responsibility of construction supervision.
- AA. Drawings: The graphic and pictorial portions of Contract Documents, wherever located and whenever issued, showing the design, location and dimensions of the Work, generally including plans, elevations, sections, details, schedules and diagrams.
- BB. Engineer: Where referenced in General Conditions, the person holding a valid Engineer's license, whose firm has been designated (if any designated) within the Contract Documents as the Engineer to provide engineering services on the project.
- CC. Equal: Equal in opinion of Architect. Burden of proof of equality is responsibility of Contractor.
- DD. Exposed: Work exposed to view in the finished Work, including behind louvers, grilles, registers and various other construction elements.
- EE. Final Acceptance or Final Completion: All Work satisfactorily completed in accordance with Contract Documents. It includes, but is not limited to:
1. All Systems having been tested and accepted as having met requirements of Contract Documents.
  2. All required instructions and training sessions having been given by Contractor.
  3. All as-built drawings and operations and maintenance manuals and Machine Inventory Sheets having been submitted by Contractor, reviewed by Architect/Engineer and accepted by Owner.
  4. All punch list work, as directed by Owner, having been completed by Contractor.
  5. Generally all work, except Contractor maintenance after Final Acceptance, having been completed to satisfaction of Owner.
- FF. Force-Account: Work directed to be performed without prior agreement as to lump sum or unit price cost thereof, and which is to be billed at cost for labor, materials, equipment, taxes, and other costs, plus a specified percentage for overhead and profit.
- GG. "Furnish": Supply and deliver to Project site, ready for unloading, unpacking, assembly, installation, and similar operations.

- HH. "Indicated": Requirements expressed by graphic representations or in written form on Drawings, in Specifications, and in other Contract Documents. Other terms including "shown," "noted," "scheduled," and "specified" have the same meaning as "indicated." No limitation of location is intended.
- II. "Install": Operations at Project site including unloading, temporarily storing, unpacking, assembling, erecting, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning, and similar operations.
- JJ. Inspector: The person engaged by Owner to inspect the workmanship, materials, or manner of construction of buildings or portions of buildings, to determine if such construction complies with the Contract Documents and applicable codes.
1. The inspector is subject to approval by the Architect, Owner and he will report to Owner.
  2. The terms "Inspector" and "Project Inspector" are used interchangeably in the Contract Documents.
- KK. Latent: Not apparent by reasonable inspection, including but not limited to, the inspections and research required as a condition to bidding under the General Conditions.
- LL. Material or Materials: These words shall be construed to embrace machinery, manufactured articles, materials of construction (fabricated or otherwise), and any other classes of material to be furnished in connection with Contract, except where a more limited meaning is indicated by context.
- MM. Milestone: A principal event specified in Contract Documents relating to an intermediate completion date or time prior to Substantial Completion of all Work.
- NN. Modification: Same as Contract Modification.
- OO. Not In Contract: Work that is outside the scope of work to be performed by Contractor under this Contract.
- PP. Notice Of Award: A written notice given by Owner to lowest responsive, responsible bidder advising that Bidder's bid and other qualifying information is acceptable to Owner, requiring Bidder to fulfill the requirements of the Contract.
- QQ. Notice To Proceed: A written notice given by Owner to Contractor fixing the date on which the Contract Time will commence to run and on which contractor shall start to perform Contractor's obligations under the Contract Documents.
- RR. Off Site: Outside geographical location of the Project.
- SS. Owner: Individual or entity named as Owner in Section 01 1100 "Summary of Work". Unless otherwise expressly indicated or required by the context of usage, the term "Owner" as used in the Contract Documents shall be deemed references to Owner.
- TT. Owner-Furnished, Contractor-Installed: Items furnished by Owner at its cost for installation by Contractor at its cost under this Contract.

- UU. Owner Representative(s): The person or persons assigned by Owner to be Owner's representatives or, if so designated, agent(s) at the site.
- VV. Progress Report: a periodic report submitted by Contractor to Owner with progress payment invoices accompanying actual work accomplished to the Project Schedule.
1. See Section 01 2900 "Payment Procedures".
  2. See Section 01 3200 "Construction Progress Documentation".
  3. See Document 00 600 General Conditions.
- WW. Project: Total construction of which Work performed under this Contract may be whole or part.
- XX. Project Manual: Project Manual consists of Bidding Requirements, Agreement, Bonds, Certificates, Contract Conditions, and Specifications. The Project Manual is deemed to include and incorporate all matters noted in any Addenda issued by or on behalf of the Owner during the bidding for the Work.
- YY. "Project Site": Space available for performing construction activities. The extent of Project site is shown on Drawings and may or may not be identical with the description of the land on which Project is to be built.
- ZZ. Provide": Furnish and install, complete and ready for the intended use.
- AAA."Regulations": Laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, and rules, conventions, and agreements within the construction industry that control performance of the Work.
- BBB. Request For Information (RFI): A document prepared by Contractor, Owner or Architect/Engineer requesting information from one of the parties regarding the Project or Contract Documents. The RFI system is also a means for Owner and Architect to submit Contract Document clarifications or supplements to Contractor.
- CCC. Required: "As required", "As needed", "As necessary" and terms of similar import, where used, shall mean as required or as needed to complete the item or effort in question in accordance with the Contract Documents, applicable standards and specifications for the quality indicated.
- DDD. RFI-Reply: A document consisting of supplementary details, instructions or information issued by the Architect/Engineer, which clarifies or supplements Contract Documents and with which Contractor shall comply. RFI-Replies do not constitute changes in Contract Sum or Contract Times except as otherwise agreed in writing by Owner. RFI-Replies will be issued through the RFI administrative system.
- EEE. Samples: Physical examples of materials, equipment, or workmanship that are representative of some portion of the Work and which establish the standards by which such portion of the Work will be judged.
- FFF. Shop Drawings: All drawings, diagrams, illustrations, schedules and other data or information which are specifically prepared or assembled by or for Contractor and submitted by Contractor to illustrate some portion of the work.
- GGG. Shown: As indicated on Drawings.

HHH. Site: The particular geographical location of Work performed pursuant to Contract, including staging areas, work areas, storage and lay down areas, access and parking.

III. Specifications: The written portion of the Contract Documents consisting of requirements for materials, equipment, construction systems, standards and workmanship for the Work, and performance of related services.

JJJ. Specified: As written in Specifications.

KKK. Subcontractor: A person or entity who has a direct contract with Contractor to perform a portion of the Work at the site. The term "subcontractor" is referred to throughout the Contract Documents as if singular in number and neuter in gender and means a subcontractor or an authorized representative of the subcontractor. The term "subcontractor" does not include a separate contractor or subcontractors of a separate contractor.

LLL. Substantial Completion: The Work (or a specified part thereof) has progressed to the point where, in the opinion of the Architect/Engineer as evidenced by a Certificate of Substantial Completion, it is sufficiently complete, in accordance with Contract Documents, so that the Work (or specified part) can be utilized for the purposes for which it is intended; or if no such certificate is issued, when the Work is complete and ready for final payment is evidenced by written recommendation of the Architect/Engineer for final payment. The terms "substantially complete" and "substantially completed" as applied to all or part of the Work refer to Substantial Completion thereof.

MMM. Supplemental Instruction: A written work change directive to Contractor from Architect/Engineer, approved by Architect, ordering alterations or modifications which do not result in change in Contract Sum or Contract Times, and do not substantially change Drawings or Specifications.

NNN. Underground Facilities: All pipelines, conduits, ducts, cables, wires, manholes, vaults, tanks, tunnels or other such facilities or attachments, and any encasements containing such facilities which have been installed underground to furnish any of the following services or materials: Electricity, gases, steam, liquid petroleum products, telephone or other communications, cable television, sewage and drainage removal, traffic or other control systems or water.

OOO. Work: The entire completed construction or the various separately identifiable parts thereof required to be furnished under the Contract Documents. Work includes and is the result of performing or furnishing labor and furnishing and incorporating materials and equipment into the construction, and performing or furnishing services and furnishing documents, all is required by the Contract Documents. Wherever the word "work" is used, rather than the word "Work", it shall be understood to have its ordinary and customary meaning.

1. Wherever words "as directed", "as required", "as permitted", or words of like effect are used, it shall be understood that direction, requirements, or permission of Owner or Architect is intended. Words "sufficient", "necessary", "proper", and the like shall mean sufficient, necessary or proper in judgment of Owner or Architect. Words "approved", "acceptable", "satisfactory", "favorably reviewed" or words of like import, shall mean approved by, or acceptable to, or satisfactory to, or favorably reviewed by Owner or Architect.
2. Wherever the word "may" is used, the action to which it refers is discretionary. Wherever the word "shall" is used, the action to which it refers is mandatory.

PPP. VERIFIED REPORT: A periodic verified report submitted to DSA. Refer to sections 4-336, 4-337 and 4-343, Part 1, Title 24, California Code of Regulations.

QQQ. As appropriate, change orders are subject to approval by the Division of the State Architect. Refer to section 4-338, Part 1, Title 24, California Code of Regulations.

### 1.3 INDUSTRY STANDARDS

- A. Applicability of Standards: Unless the Contract Documents include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Contract Documents to the extent referenced. Such standards are made a part of the Contract Documents by reference.
- B. Publication Dates: Comply with standards in effect as of date of the Contract Documents unless otherwise indicated.
- C. Copies of Standards: Each entity engaged in construction on Project should be familiar with industry standards applicable to its construction activity. Copies of applicable standards are not bound with the Contract Documents.
  - 1. Where copies of standards are needed to perform a required construction activity, obtain copies directly from publication source.
- D. Reference to standards, specifications, manuals or codes of any technical society, organization or association, or to the laws or regulations of any governmental authority, whether such reference be specific or by implication, shall mean the latest standard, specification, manual, code or laws or regulations in effect at the time of opening of Bids, except as may be otherwise specifically stated in the Contract Documents.
- E. Except as otherwise specifically stated in the Contract Documents or as may be provided by Change Order, or supplemental instruction, the provisions of the Contract Documents shall take precedence in resolving conflicts, errors, ambiguity or discrepancy between the Contract Documents and:
  - 1. The provisions of standards, specifications, manuals, codes, or instructions (whether or not specifically incorporated by reference in the Contract Documents); or
  - 2. The provisions of laws or regulations applicable to the performance of the Work (unless such an interpretation of the provisions of the Contract Documents would result in violation of such law or regulation).
- F. No provision of referenced standards, specifications, manuals, codes or instructions shall be effective to change the duties and responsibilities of Owner, Contractor or Architect/Engineer, or their subcontractors, consultants, agents, or employees, from those set forth in the Contract Documents, nor shall it be effective to assign to Owner, Architect/Engineer or their consultants, agents or employees any duty or authority to supervise or direct the furnishing or performance of the Work or any duty or authority to undertake responsibility inconsistent with the provisions of the Contract Documents.

#### 1.4 REPORTING AND RESOLVING DISCREPANCIES

- A. Report in writing at once to Owner, with copies to Architect, all conflicts, errors, ambiguity or discrepancy within the Contract Documents or between the Contract Documents and provisions of laws or regulations applicable to the performance of the Work or of standards, specifications, manual, codes or instructions of manufacturers or suppliers. Do not proceed with the Work affected until direction to do so is given by the Architect.

#### 1.5 ABBREVIATIONS AND ACRONYMS

- A. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities indicated in Gale's "Encyclopedia of Associations: National Organizations of the U.S." or in Columbia Books' "National Trade & Professional Associations of the United States."
- B. Industry Organizations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.
1. AABC - Associated Air Balance Council; [www.aabc.com](http://www.aabc.com).
  2. AAMA - American Architectural Manufacturers Association; [www.aamanet.org](http://www.aamanet.org).
  3. AAPFCO - Association of American Plant Food Control Officials; [www.aapfco.org](http://www.aapfco.org).
  4. AASHTO - American Association of State Highway and Transportation Officials; [www.transportation.org](http://www.transportation.org).
  5. AATCC - American Association of Textile Chemists and Colorists; [www.aatcc.org](http://www.aatcc.org).
  6. ABMA - American Bearing Manufacturers Association; [www.americanbearings.org](http://www.americanbearings.org).
  7. ACI - American Concrete Institute; (Formerly: ACI International); [www.concrete.org](http://www.concrete.org).
  8. ACPA - American Concrete Pipe Association; [www.concrete-pipe.org](http://www.concrete-pipe.org).
  9. AEIC - Association of Edison Illuminating Companies, Inc. (The); [www.aeic.org](http://www.aeic.org).
  10. AF&PA - American Forest & Paper Association; [www.afandpa.org](http://www.afandpa.org).
  11. AGA - American Gas Association; [www.aga.org](http://www.aga.org).
  12. AHAM - Association of Home Appliance Manufacturers; [www.aham.org](http://www.aham.org).
  13. AHRI - Air-Conditioning, Heating, and Refrigeration Institute (The); [www.ahrinet.org](http://www.ahrinet.org).
  14. AI - Asphalt Institute; [www.asphaltinstitute.org](http://www.asphaltinstitute.org).
  15. AIA - American Institute of Architects (The); [www.aia.org](http://www.aia.org).
  16. AISC - American Institute of Steel Construction; [www.aisc.org](http://www.aisc.org).
  17. AISI - American Iron and Steel Institute; [www.steel.org](http://www.steel.org).
  18. AITC - American Institute of Timber Construction; [www.aitc-glulam.org](http://www.aitc-glulam.org).
  19. AMCA - Air Movement and Control Association International, Inc.; [www.amca.org](http://www.amca.org).
  20. ANSI - American National Standards Institute; [www.ansi.org](http://www.ansi.org).
  21. AOSA - Association of Official Seed Analysts, Inc.; [www.aosaseed.com](http://www.aosaseed.com).
  22. APA - APA - The Engineered Wood Association; [www.apawood.org](http://www.apawood.org).
  23. APA - Architectural Precast Association; [www.archprecast.org](http://www.archprecast.org).
  24. API - American Petroleum Institute; [www.api.org](http://www.api.org).
  25. ARI - Air-Conditioning & Refrigeration Institute; (See AHRI).
  26. ARI - American Refrigeration Institute; (See AHRI).
  27. ARMA - Asphalt Roofing Manufacturers Association; [www.asphaltroofing.org](http://www.asphaltroofing.org).
  28. ASCE - American Society of Civil Engineers; [www.asce.org](http://www.asce.org).
  29. ASCE/SEI - American Society of Civil Engineers/Structural Engineering Institute; (See ASCE).

30. ASHRAE - American Society of Heating, Refrigerating and Air-Conditioning Engineers; [www.ashrae.org](http://www.ashrae.org).
31. ASME - ASME International; (American Society of Mechanical Engineers); [www.asme.org](http://www.asme.org).
32. ASSE - American Society of Safety Engineers (The); [www.asse.org](http://www.asse.org).
33. ASSE - American Society of Sanitary Engineering; [www.asse-plumbing.org](http://www.asse-plumbing.org).
34. ASTM - ASTM International; (American Society for Testing and Materials International); [www.astm.org](http://www.astm.org).
35. ATIS - Alliance for Telecommunications Industry Solutions; [www.atis.org](http://www.atis.org).
36. AWEA - American Wind Energy Association; [www.awea.org](http://www.awea.org).
37. AWI - Architectural Woodwork Institute; [www.awinet.org](http://www.awinet.org).
38. AWMAC - Architectural Woodwork Manufacturers Association of Canada; [www.awmac.com](http://www.awmac.com).
39. AWPA - American Wood Protection Association; (Formerly: American Wood-Preservers' Association); [www.awpa.com](http://www.awpa.com).
40. AWS - American Welding Society; [www.aws.org](http://www.aws.org).
41. AWWA - American Water Works Association; [www.awwa.org](http://www.awwa.org).
42. BHMA - Builders Hardware Manufacturers Association; [www.buildershardware.com](http://www.buildershardware.com).
43. BIA - Brick Industry Association (The); [www.gobrick.com](http://www.gobrick.com).
44. BICSI - BICSI, Inc.; [www.bicsi.org](http://www.bicsi.org).
45. BIFMA - BIFMA International; (Business and Institutional Furniture Manufacturer's Association); [www.bifma.com](http://www.bifma.com).
46. BISSC - Baking Industry Sanitation Standards Committee; [www.bissc.org](http://www.bissc.org).
47. BOCA - BOCA; (Building Officials and Code Administrators International Inc.); (See ICC).
48. BWF - Badminton World Federation; (Formerly: International Badminton Federation); [www.bwfbadminton.org](http://www.bwfbadminton.org).
49. CDA - Copper Development Association; [www.copper.org](http://www.copper.org).
50. CEA - Canadian Electricity Association; [www.electricity.ca](http://www.electricity.ca).
51. CEA - Consumer Electronics Association; [www.ce.org](http://www.ce.org).
52. CFFA - Chemical Fabrics & Film Association, Inc.; [www.chemicalfabricsandfilm.com](http://www.chemicalfabricsandfilm.com).
53. CFSEI - Cold-Formed Steel Engineers Institute; [www.cfsei.org](http://www.cfsei.org).
54. CGA - Compressed Gas Association; [www.cganet.com](http://www.cganet.com).
55. CIMA - Cellulose Insulation Manufacturers Association; [www.cellulose.org](http://www.cellulose.org).
56. CISCA - Ceilings & Interior Systems Construction Association; [www.cisca.org](http://www.cisca.org).
57. CISPI - Cast Iron Soil Pipe Institute; [www.cispi.org](http://www.cispi.org).
58. CLFMI - Chain Link Fence Manufacturers Institute; [www.chainlinkinfo.org](http://www.chainlinkinfo.org).
59. CPA - Composite Panel Association; [www.pbmdf.com](http://www.pbmdf.com).
60. CRI - Carpet and Rug Institute (The); [www.carpet-rug.org](http://www.carpet-rug.org).
61. CRRC - Cool Roof Rating Council; [www.coolroofs.org](http://www.coolroofs.org).
62. CRSI - Concrete Reinforcing Steel Institute; [www.crsi.org](http://www.crsi.org).
63. CSA - Canadian Standards Association; [www.csa.ca](http://www.csa.ca).
64. CSA - CSA International; (Formerly: IAS - International Approval Services); [www.csa-international.org](http://www.csa-international.org).
65. CSI - Construction Specifications Institute (The); [www.csinet.org](http://www.csinet.org).
66. CSSB - Cedar Shake & Shingle Bureau; [www.cedarbureau.org](http://www.cedarbureau.org).
67. CTI - Cooling Technology Institute; (Formerly: Cooling Tower Institute); [www.cti.org](http://www.cti.org).
68. CWC - Composite Wood Council; (See CPA).

69. DASMA - Door and Access Systems Manufacturers Association; [www.dasma.com](http://www.dasma.com).
70. DHI - Door and Hardware Institute; [www.dhi.org](http://www.dhi.org).
71. ECA - Electronic Components Association; [www.ec-central.org](http://www.ec-central.org).
72. ECAMA - Electronic Components Assemblies & Materials Association; (See ECA).
73. EIA - Electronic Industries Alliance; (See TIA).
74. EIMA - EIFS Industry Members Association; [www.eima.com](http://www.eima.com).
75. EJMA - Expansion Joint Manufacturers Association, Inc.; [www.ejma.org](http://www.ejma.org).
76. ESD - ESD Association; (Electrostatic Discharge Association); [www.esda.org](http://www.esda.org).
77. ESTA - Entertainment Services and Technology Association; (See PLASA).
78. EVO - Efficiency Valuation Organization; [www.evo-world.org](http://www.evo-world.org).
79. FIBA - Federation Internationale de Basketball; (The International Basketball Federation); [www.fiba.com](http://www.fiba.com).
80. FIVB - Federation Internationale de Volleyball; (The International Volleyball Federation); [www.fivb.org](http://www.fivb.org).
81. FM Approvals - FM Approvals LLC; [www.fmglobal.com](http://www.fmglobal.com).
82. FM Global - FM Global; (Formerly: FMG - FM Global); [www.fmglobal.com](http://www.fmglobal.com).
83. FRSA - Florida Roofing, Sheet Metal & Air Conditioning Contractors Association, Inc.; [www.floridarroof.com](http://www.floridarroof.com).
84. FSA - Fluid Sealing Association; [www.fluidsealing.com](http://www.fluidsealing.com).
85. FSC - Forest Stewardship Council U.S.; [www.fscus.org](http://www.fscus.org).
86. GA - Gypsum Association; [www.gypsum.org](http://www.gypsum.org).
87. GANA - Glass Association of North America; [www.glasswebsite.com](http://www.glasswebsite.com).
88. GS - Green Seal; [www.greenseal.org](http://www.greenseal.org).
89. HI - Hydraulic Institute; [www.pumps.org](http://www.pumps.org).
90. HI/GAMA - Hydronics Institute/Gas Appliance Manufacturers Association; (See AHRI).
91. HMMA - Hollow Metal Manufacturers Association; (See NAAMM).
92. HPVA - Hardwood Plywood & Veneer Association; [www.hpva.org](http://www.hpva.org).
93. HPW - H. P. White Laboratory, Inc.; [www.hpwhite.com](http://www.hpwhite.com).
94. IAPSC - International Association of Professional Security Consultants; [www.iapsc.org](http://www.iapsc.org).
95. IAS - International Approval Services; (See CSA).
96. ICBO - International Conference of Building Officials; (See ICC).
97. ICC - International Code Council; [www.iccsafe.org](http://www.iccsafe.org).
98. ICEA - Insulated Cable Engineers Association, Inc.; [www.icea.net](http://www.icea.net).
99. ICPA - International Cast Polymer Alliance; [www.icpa-hq.org](http://www.icpa-hq.org).
100. ICRI - International Concrete Repair Institute, Inc.; [www.icri.org](http://www.icri.org).
101. IEC - International Electrotechnical Commission; [www.iec.ch](http://www.iec.ch).
102. IEEE - Institute of Electrical and Electronics Engineers, Inc. (The); [www.ieee.org](http://www.ieee.org).
103. IES - Illuminating Engineering Society; (Formerly: Illuminating Engineering Society of North America); [www.ies.org](http://www.ies.org).
104. IESNA - Illuminating Engineering Society of North America; (See IES).
105. IEST - Institute of Environmental Sciences and Technology; [www.iest.org](http://www.iest.org).
106. IGMA - Insulating Glass Manufacturers Alliance; [www.igmaonline.org](http://www.igmaonline.org).
107. IGSHPA - International Ground Source Heat Pump Association; [www.igshpa.okstate.edu](http://www.igshpa.okstate.edu).
108. ILI - Indiana Limestone Institute of America, Inc.; [www.iliai.com](http://www.iliai.com).
109. Intertek - Intertek Group; (Formerly: ETL SEMCO; Intertek Testing Service NA); [www.intertek.com](http://www.intertek.com).

110. ISA - International Society of Automation (The); (Formerly: Instrumentation, Systems, and Automation Society); [www.isa.org](http://www.isa.org).
111. ISAS - Instrumentation, Systems, and Automation Society (The); (See ISA).
112. ISFA - International Surface Fabricators Association; (Formerly: International Solid Surface Fabricators Association); [www.isfanow.org](http://www.isfanow.org).
113. ISO - International Organization for Standardization; [www.iso.org](http://www.iso.org).
114. ISSFA - International Solid Surface Fabricators Association; (See ISFA).
115. ITU - International Telecommunication Union; [www.itu.int/home](http://www.itu.int/home).
116. KCMA - Kitchen Cabinet Manufacturers Association; [www.kcma.org](http://www.kcma.org).
117. LMA - Laminating Materials Association; (See CPA).
118. LPI - Lightning Protection Institute; [www.lightning.org](http://www.lightning.org).
119. MBMA - Metal Building Manufacturers Association; [www.mbma.com](http://www.mbma.com).
120. MCA - Metal Construction Association; [www.metalconstruction.org](http://www.metalconstruction.org).
121. MFMA - Maple Flooring Manufacturers Association, Inc.; [www.maplefloor.org](http://www.maplefloor.org).
122. MFMA - Metal Framing Manufacturers Association, Inc.; [www.metalframingmfg.org](http://www.metalframingmfg.org).
123. MHIA - Material Handling Industry of America; [www.mhia.org](http://www.mhia.org).
124. MIA - Marble Institute of America; [www.marble-institute.com](http://www.marble-institute.com).
125. MMPA - Moulding & Millwork Producers Association; (Formerly: Wood Moulding & Millwork Producers Association); [www.wmmpa.com](http://www.wmmpa.com).
126. MPI - Master Painters Institute; [www.paintinfo.com](http://www.paintinfo.com).
127. MSS - Manufacturers Standardization Society of The Valve and Fittings Industry Inc.; [www.mss-hq.org](http://www.mss-hq.org).
128. NAAMM - National Association of Architectural Metal Manufacturers; [www.naamm.org](http://www.naamm.org).
129. NACE - NACE International; (National Association of Corrosion Engineers International); [www.nace.org](http://www.nace.org).
130. NADCA - National Air Duct Cleaners Association; [www.nadca.com](http://www.nadca.com).
131. NAIMA - North American Insulation Manufacturers Association; [www.naima.org](http://www.naima.org).
132. NBGQA - National Building Granite Quarries Association, Inc.; [www.nbgqa.com](http://www.nbgqa.com).
133. NCAA - National Collegiate Athletic Association (The); [www.ncaa.org](http://www.ncaa.org).
134. NCMA - National Concrete Masonry Association; [www.ncma.org](http://www.ncma.org).
135. NEBB - National Environmental Balancing Bureau; [www.nebb.org](http://www.nebb.org).
136. NECA - National Electrical Contractors Association; [www.necanet.org](http://www.necanet.org).
137. NeLMA - Northeastern Lumber Manufacturers Association; [www.nelma.org](http://www.nelma.org).
138. NEMA - National Electrical Manufacturers Association; [www.nema.org](http://www.nema.org).
139. NETA - InterNational Electrical Testing Association; [www.netaworld.org](http://www.netaworld.org).
140. NFHS - National Federation of State High School Associations; [www.nfhs.org](http://www.nfhs.org).
141. NFPA - NFPA; (National Fire Protection Association); [www.nfpa.org](http://www.nfpa.org).
142. NFPA - NFPA International; (See NFPA).
143. NFRC - National Fenestration Rating Council; [www.nfrc.org](http://www.nfrc.org).
144. NHLA - National Hardwood Lumber Association; [www.nhla.com](http://www.nhla.com).
145. NLGA - National Lumber Grades Authority; [www.nlga.org](http://www.nlga.org).
146. NOFMA - National Oak Flooring Manufacturers Association; (See NWFA).
147. NOMMA - National Ornamental & Miscellaneous Metals Association; [www.nomma.org](http://www.nomma.org).
148. NRCA - National Roofing Contractors Association; [www.nrca.net](http://www.nrca.net).
149. NRMCA - National Ready Mixed Concrete Association; [www.nrmca.org](http://www.nrmca.org).
150. NSF - NSF International; (National Sanitation Foundation International); [www.nsf.org](http://www.nsf.org).
151. NSPE - National Society of Professional Engineers; [www.nspe.org](http://www.nspe.org).
152. NSSGA - National Stone, Sand & Gravel Association; [www.nssga.org](http://www.nssga.org).

153. NTMA - National Terrazzo & Mosaic Association, Inc. (The); [www.ntma.com](http://www.ntma.com).
154. NWFA - National Wood Flooring Association; [www.nwfa.org](http://www.nwfa.org).
155. PCI - Precast/Prestressed Concrete Institute; [www.pci.org](http://www.pci.org).
156. PDI - Plumbing & Drainage Institute; [www.pdionline.org](http://www.pdionline.org).
157. PLASA - PLASA; (Formerly: ESTA - Entertainment Services and Technology Association); [www.plasa.org](http://www.plasa.org).
158. RCSC - Research Council on Structural Connections; [www.boltcouncil.org](http://www.boltcouncil.org).
159. RFCI - Resilient Floor Covering Institute; [www.rfci.com](http://www.rfci.com).
160. RIS - Redwood Inspection Service; [www.redwoodinspection.com](http://www.redwoodinspection.com).
161. SAE - SAE International; (Society of Automotive Engineers); [www.sae.org](http://www.sae.org).
162. SCTE - Society of Cable Telecommunications Engineers; [www.scte.org](http://www.scte.org).
163. SDI - Steel Deck Institute; [www.sdi.org](http://www.sdi.org).
164. SDI - Steel Door Institute; [www.steeldoor.org](http://www.steeldoor.org).
165. SEFA - Scientific Equipment and Furniture Association; [www.sefalabs.com](http://www.sefalabs.com).
166. SEI/ASCE - Structural Engineering Institute/American Society of Civil Engineers; (See ASCE).
167. SIA - Security Industry Association; [www.siaonline.org](http://www.siaonline.org).
168. SJI - Steel Joist Institute; [www.steeljoist.org](http://www.steeljoist.org).
169. SMA - Screen Manufacturers Association; [www.smainfo.org](http://www.smainfo.org).
170. SMACNA - Sheet Metal and Air Conditioning Contractors' National Association; [www.smacna.org](http://www.smacna.org).
171. SMPTE - Society of Motion Picture and Television Engineers; [www.smpte.org](http://www.smpte.org).
172. SPFA - Spray Polyurethane Foam Alliance; [www.sprayfoam.org](http://www.sprayfoam.org).
173. SPIB - Southern Pine Inspection Bureau; [www.spib.org](http://www.spib.org).
174. SPRI - Single Ply Roofing Industry; [www.spri.org](http://www.spri.org).
175. SRCC - Solar Rating and Certification Corporation; [www.solar-rating.org](http://www.solar-rating.org).
176. SSINA - Specialty Steel Industry of North America; [www.ssina.com](http://www.ssina.com).
177. SSPC - SSPC: The Society for Protective Coatings; [www.sspc.org](http://www.sspc.org).
178. STI - Steel Tank Institute; [www.steeltank.com](http://www.steeltank.com).
179. SWI - Steel Window Institute; [www.steelwindows.com](http://www.steelwindows.com).
180. SWPA - Submersible Wastewater Pump Association; [www.swpa.org](http://www.swpa.org).
181. TCA - Tilt-Up Concrete Association; [www.tilt-up.org](http://www.tilt-up.org).
182. TCNA - Tile Council of North America, Inc.; (Formerly: Tile Council of America); [www.tileusa.com](http://www.tileusa.com).
183. TEMA - Tubular Exchanger Manufacturers Association, Inc.; [www.tema.org](http://www.tema.org).
184. TIA - Telecommunications Industry Association; (Formerly: TIA/EIA - Telecommunications Industry Association/Electronic Industries Alliance); [www.tiaonline.org](http://www.tiaonline.org).
185. TIA/EIA - Telecommunications Industry Association/Electronic Industries Alliance; (See TIA).
186. TMS - The Masonry Society; [www.masonrysociety.org](http://www.masonrysociety.org).
187. TPI - Truss Plate Institute; [www.tpinst.org](http://www.tpinst.org).
188. TPI - Turfgrass Producers International; [www.turfgrassod.org](http://www.turfgrassod.org).
189. TRI - Tile Roofing Institute; [www.tilerroofing.org](http://www.tilerroofing.org).
190. UBC - Uniform Building Code; (See ICC).
191. UL - Underwriters Laboratories Inc.; [www.ul.com](http://www.ul.com).
192. UNI - Uni-Bell PVC Pipe Association; [www.uni-bell.org](http://www.uni-bell.org).
193. USAV - USA Volleyball; [www.usavolleyball.org](http://www.usavolleyball.org).

194. USGBC - U.S. Green Building Council; [www.usgbc.org](http://www.usgbc.org).
  195. USITT - United States Institute for Theatre Technology, Inc.; [www.usitt.org](http://www.usitt.org).
  196. WASTEC - Waste Equipment Technology Association; [www.wastec.org](http://www.wastec.org).
  197. WCLIB - West Coast Lumber Inspection Bureau; [www.wclib.org](http://www.wclib.org).
  198. WCMA - Window Covering Manufacturers Association; [www.wcmanet.org](http://www.wcmanet.org).
  199. WDMA - Window & Door Manufacturers Association; [www.wdma.com](http://www.wdma.com).
  200. WI - Woodwork Institute; (Formerly: WIC - Woodwork Institute of California); [www.wicnet.org](http://www.wicnet.org).
  201. WMMPA - Wood Moulding & Millwork Producers Association; (See MMPA).
  202. WSRCA - Western States Roofing Contractors Association; [www.wsrca.com](http://www.wsrca.com).
  203. WPA - Western Wood Products Association; [www.wwpa.org](http://www.wwpa.org).
- C. Code Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is believed to be accurate as of the date of the Contract Documents.
1. DIN - Deutsches Institut für Normung e.V.; [www.din.de](http://www.din.de).
  2. IAPMO - International Association of Plumbing and Mechanical Officials; [www.iapmo.org](http://www.iapmo.org).
  3. ICC - International Code Council; [www.iccsafe.org](http://www.iccsafe.org).
  4. ICC-ES - ICC Evaluation Service, LLC; [www.icc-es.org](http://www.icc-es.org).
- D. Federal Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. Information is subject to change and is up-to-date as of the date of the Contract Documents.
1. COE - Army Corps of Engineers; [www.usace.army.mil](http://www.usace.army.mil).
  2. CPSC - Consumer Product Safety Commission; [www.cpsc.gov](http://www.cpsc.gov).
  3. DOC - Department of Commerce; National Institute of Standards and Technology; [www.nist.gov](http://www.nist.gov).
  4. DOD - Department of Defense; <http://dodssp.daps.dla.mil>.
  5. DOE - Department of Energy; [www.energy.gov](http://www.energy.gov).
  6. EPA - Environmental Protection Agency; [www.epa.gov](http://www.epa.gov).
  7. FAA - Federal Aviation Administration; [www.faa.gov](http://www.faa.gov).
  8. FG - Federal Government Publications; [www.gpo.gov](http://www.gpo.gov).
  9. GSA - General Services Administration; [www.gsa.gov](http://www.gsa.gov).
  10. HUD - Department of Housing and Urban Development; [www.hud.gov](http://www.hud.gov).
  11. LBL - Lawrence Berkeley National Laboratory; Environmental Energy Technologies Division; <http://eetd.lbl.gov>.
  12. OSHA - Occupational Safety & Health Administration; [www.osha.gov](http://www.osha.gov).
  13. SD - Department of State; [www.state.gov](http://www.state.gov).
  14. TRB - Transportation Research Board; National Cooperative Highway Research Program; [www.trb.org](http://www.trb.org).
  15. USDA - Department of Agriculture; Agriculture Research Service; U.S. Salinity Laboratory; [www.ars.usda.gov](http://www.ars.usda.gov).

16. USDA - Department of Agriculture; Rural Utilities Service; [www.usda.gov](http://www.usda.gov).
  17. USDJ - Department of Justice; Office of Justice Programs; National Institute of Justice; [www.ojp.usdoj.gov](http://www.ojp.usdoj.gov).
  18. USP - U.S. Pharmacopeia; [www.usp.org](http://www.usp.org).
  19. USPS - United States Postal Service; [www.usps.com](http://www.usps.com).
- E. Standards and Regulations: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the standards and regulations in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.
1. CFR - Code of Federal Regulations; Available from Government Printing Office; [www.gpo.gov/fdsys](http://www.gpo.gov/fdsys).
  2. DOD - Department of Defense; Military Specifications and Standards; Available from Department of Defense Single Stock Point; <http://dodssp.daps.dla.mil>.
  3. DSCC - Defense Supply Center Columbus; (See FS).
  4. FED-STD - Federal Standard; (See FS).
  5. FS - Federal Specification; Available from Department of Defense Single Stock Point; <http://dodssp.daps.dla.mil>.
    - a. Available from Defense Standardization Program; [www.dsp.dla.mil](http://www.dsp.dla.mil).
    - b. Available from General Services Administration; [www.gsa.gov](http://www.gsa.gov).
    - c. Available from National Institute of Building Sciences/Whole Building Design Guide; [www.wbdg.org/ccb](http://www.wbdg.org/ccb).
  6. MILSPEC - Military Specification and Standards; (See DOD).
  7. USAB - United States Access Board; [www.access-board.gov](http://www.access-board.gov).
  8. USATBCB - U.S. Architectural & Transportation Barriers Compliance Board; (See USAB).
- F. State Government Agencies: Where abbreviations and acronyms are used in Specifications or other Contract Documents, they shall mean the recognized name of the entities in the following list. This information is subject to change and is believed to be accurate as of the date of the Contract Documents.
1. CBHF - State of California; Department of Consumer Affairs; Bureau of Electronic Appliance and Repair, Home Furnishings and Thermal Insulation; [www.bearhfti.ca.gov](http://www.bearhfti.ca.gov).
  2. CCR - California Code of Regulations; Office of Administrative Law; California Title 24 Energy Code; [www.calregs.com](http://www.calregs.com).
  3. CDHS - California Department of Health Services; (See CDPH).
  4. CDPH - California Department of Public Health; Indoor Air Quality Program; [www.cal-iaq.org](http://www.cal-iaq.org).
  5. CPUC - California Public Utilities Commission; [www.cpuc.ca.gov](http://www.cpuc.ca.gov).
  6. SCAQMD - South Coast Air Quality Management District; [www.aqmd.gov](http://www.aqmd.gov).
  7. TFS - Texas Forest Service; Forest Resource Development and Sustainable Forestry; <http://txforests-service.tamu.edu>.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

## - SECTION 01 5000 - TEMPORARY FACILITIES AND CONTROLS

---

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes requirements for temporary utilities, support facilities, and security and protection facilities.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 1100 "Summary of Work" for work restrictions and limitations on utility interruptions.

#### 1.4 USE CHARGES

- A. General: Installation and removal of and use charges for temporary facilities shall be included in the Contract Sum unless otherwise indicated. Allow other entities to use temporary services and facilities without cost, including, but not limited to, Owner's construction forces, Architect, occupants of Project, testing agencies, and authorities having jurisdiction.
- B. Arrangements for Site Utility Usage:
  - 1. Sewer Service: [Owner will pay] sewer-service use charges for sewer usage by all entities for construction operations;
  - 2. Water Service: [Owner will pay] water-service use charges for water used by all entities for construction operations;
- C. Electric Power Service: [Owner will pay] electric-power-service use charges for electricity used by all entities for construction operations;
- D. Water and Sewer Service from Existing System: Water from Owner's existing water system is available for use without metering and without payment of use charges. Provide connections and extensions of services as required for construction operations;
- E. Electric Power Service from Existing System: Electric power from Owner's existing system is available for use without metering and without payment of use charges. Provide connections and extensions of services as required for construction operations.

#### 1.5 INFORMATIONAL SUBMITTALS

- A. Site Plan: Show temporary facilities, utility hookups, staging areas, and parking areas for construction personnel.
- B. Existing Conditions Documentation: Prior to mobilization on the site, provide video or photographic documentation acceptable to the Owner of existing conditions of roads, drives,

parking, landscape areas and similar features adjacent to the area of work, and as required to traverse to access the area of work.

- C. Fire-Safety Program: Show compliance with requirements of NFPA 241 and authorities having jurisdiction. Indicate Contractor personnel responsible for management of fire-prevention program.
- D. Moisture-Protection Plan: Describe procedures and controls for protecting materials and construction from water absorption and damage.
  - 1. Describe delivery, handling, and storage provisions for materials subject to water absorption or water damage.
  - 2. Indicate procedures for discarding water-damaged materials, protocols for mitigating water intrusion into completed Work, and replacing water-damaged Work.
  - 3. Indicate sequencing of work that requires water, such as sprayed fire-resistive materials, plastering, and terrazzo grinding, and describe plans for dealing with water from these operations. Show procedures for verifying that wet construction has dried sufficiently to permit installation of finish materials.

## 1.6 QUALITY ASSURANCE

- A. Electric Service: Comply with NECA, NEMA, and UL standards and regulations for temporary electric service. Install service to comply with NFPA 70.
- B. Tests and Inspections: Arrange for authorities having jurisdiction to test and inspect each temporary utility before use. Obtain required certifications and permits.

## 1.7 PROJECT CONDITIONS

- A. Temporary Use of Permanent Facilities: Engage Installer of each permanent service to assume responsibility for operation, maintenance, and protection of each permanent service during its use as a construction facility before Owner's acceptance, regardless of previously assigned responsibilities.

# PART 2 – PRODUCTS

## 2.1 MATERIALS

- A. Fence Materials: Materials at Contractor's option to prevent unauthorized access to site, but not less than one of the following:
  - 1. Chain-Link Fencing: Minimum 2-inch (50-mm), 0.148-inch- (3.8-mm-) thick, galvanized-steel, chain-link fabric fencing; minimum 6 feet (1.8 m) high with galvanized-steel pipe posts; minimum 2-3/8-inch- (60-mm-) OD line posts and 2-7/8-inch- (73-mm-) OD corner and pull posts, with 1-5/8-inch- (42-mm-) OD top rails .
  - 2. Portable Chain-Link Fencing: Minimum 2-inch (50-mm), 0.148-inch- (3.8-mm-) thick, galvanized-steel, chain-link fabric fencing; minimum 6 feet (1.8 m) high with galvanized-steel pipe posts; minimum 2-3/8-inch- (60-mm-) OD line posts and 2-7/8-inch- (73-mm-) OD corner and pull posts, with 1-5/8-inch- (42-mm-) OD top and bottom rails. Provide concrete or galvanized-steel bases for supporting posts.

3. Wood Enclosure Fence: Plywood, 6 feet (1.8 m) high, framed with four 2-by-4-inch (50-by-100-mm) rails, with preservative-treated wood posts spaced not more than 8 feet (2.4 m) apart.
- B. Polyethylene Sheet: Reinforced, fire-resistive sheet, 10-mil (0.25-mm) minimum thickness, with flame-spread rating of 15 or less per ASTM E 84 and passing NFPA 701 Test Method 2.
- C. Dust-Control Adhesive-Surface Walk-off Mats: Provide mats minimum 36 by 60 inches (914 by 1624 mm).
- D. Insulation: Unfaced mineral-fiber blanket, manufactured from glass, slag wool, or rock wool; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively.

## 2.2 TEMPORARY FACILITIES

- A. Field Offices, General: Prefabricated or mobile units with serviceable finishes, temperature controls, and foundations adequate for normal loading.
- B. Common-Use Field Office: Of sufficient size to accommodate needs of Owner, Architect, and construction personnel office activities and to accommodate Project meetings specified in other Division 01 Sections. Keep office clean and orderly. Furnish and equip offices as follows:
  1. Furniture required for Project-site documents including file cabinets, plan tables, plan racks, and bookcases.
  2. Conference room of sufficient size to accommodate meetings of 10 individuals. Provide electrical power service and 120-V ac duplex receptacles, with no fewer than one receptacle on each wall. Furnish room with conference table, chairs, and 4-foot- (1.2-m-) square tack and marker boards.
  3. Drinking water and private toilet.
  4. Coffee machine and supplies.
  5. Heating and cooling equipment necessary to maintain a uniform indoor temperature of 68 to 72 deg F (20 to 22 deg C).
  6. Lighting fixtures capable of maintaining average illumination of 20 fc (215 lx) at desk height.
- C. Storage and Fabrication Sheds: Provide sheds sized, furnished, and equipped to accommodate materials and equipment for construction operations.
  1. Store combustible materials apart from building.

## 2.3 EQUIPMENT

- A. Fire Extinguishers: Portable, UL rated; with class and extinguishing agent as required by locations and classes of fire exposures.
- B. HVAC Equipment: Unless Owner authorizes use of permanent HVAC system, provide vented, self-contained, liquid-propane-gas or fuel-oil heaters with individual space thermostatic control.
  1. Use of gasoline-burning space heaters, open-flame heaters, or salamander-type heating units is prohibited.

2. Heating Units: Listed and labeled for type of fuel being consumed, by a qualified testing agency acceptable to authorities having jurisdiction, and marked for intended location and application.
  3. Permanent HVAC System: If Owner authorizes use of permanent HVAC system for temporary use during construction, provide filter with MERV of 8 at each return-air grille in system and remove at end of construction and clean HVAC system as required in Section 017700 "Closeout Procedures".
- C. Air-Filtration Units: Primary and secondary HEPA-filter-equipped portable units with four-stage filtration. Provide single switch for emergency shutoff. Configure to run continuously.

## **PART 3 – EXECUTION**

### **3.1 INSTALLATION, GENERAL**

- A. Locate facilities where they will serve Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as required by progress of the Work.
- B. Provide each facility ready for use when needed to avoid delay. Do not remove until facilities are no longer needed or are replaced by authorized use of completed permanent facilities.

### **3.2 TEMPORARY UTILITY INSTALLATION**

- A. General: Install temporary service or connect to existing service.
  1. Arrange with utility company, Owner, and existing users for time when service can be interrupted, if necessary, to make connections for temporary services.
- B. Sewers and Drainage: Provide temporary utilities to remove effluent lawfully.
  1. Connect temporary sewers as directed by authorities having jurisdiction.
- C. Water Service: Install water service and distribution piping in sizes and pressures adequate for construction.
- D. Sanitary Facilities: Provide temporary toilets, wash facilities, and drinking water for use of construction personnel. Comply with requirements of authorities having jurisdiction for type, number, location, operation, and maintenance of fixtures and facilities.
  1. Toilets: Use of Owner's existing toilet facilities will be permitted, as long as facilities are cleaned and maintained in a condition acceptable to Owner. At Substantial Completion, restore these facilities to condition existing before initial use.
- E. Heating and Cooling: Provide temporary heating and cooling required by construction activities for curing or drying of completed installations or for protecting installed construction from adverse effects of low temperatures or high humidity. Select equipment that will not have a harmful effect on completed installations or elements being installed.

- F. Ventilation and Humidity Control: Provide temporary ventilation required by construction activities for curing or drying of completed installations or for protecting installed construction from adverse effects of high humidity. Select equipment that will not have a harmful effect on completed installations or elements being installed. Coordinate ventilation requirements to produce ambient condition required and minimize energy consumption.
1. Provide dehumidification systems when required to reduce substrate moisture levels to level required to allow installation or application of finishes.
- G. Electric Power Service: Provide electric power service and distribution system of sufficient size, capacity, and power characteristics required for construction operations.
1. Connect temporary service to Owner's existing power source, as directed by Owner.
  2. Install electric power service [overhead] [underground] unless otherwise indicated.
- H. Lighting: Provide temporary lighting with local switching that provides adequate illumination for construction operations, observations, inspections, and traffic conditions.
1. Install and operate temporary lighting that fulfills security and protection requirements without operating entire system.
  2. Install lighting for Project identification sign.
- I. Telephone Service: Provide temporary telephone service in common-use facilities for use by all construction personnel. Install three telephone line(s) for each field office.
1. Provide additional telephone lines for the following:
    - a. Provide a dedicated telephone line for each facsimile machine in each field office.
  2. At each telephone, post a list of important telephone numbers.
    - a. Police and fire departments.
    - b. Ambulance service.
    - c. Contractor's home office.
    - d. Contractor's emergency after-hours telephone number.
    - e. Architect's office.
    - f. Engineers' offices.
    - g. Owner's office.
    - h. Principal subcontractors' field and home offices.
  3. Provide superintendent with cellular telephone or portable two-way radio for use when away from field office.
- J. Electronic Communication Service: Provide a desktop computer in the primary field office adequate for use by Architect and Owner to access Project electronic documents and maintain electronic communications. Equip computer with not less than the following:
1. Processor: Intel Pentium D or Intel CoreDuo, 3.0 GHz processing speed.
  2. Memory: 4 gigabyte.
  3. Disk Storage: 500 gigabyte hard-disk drive and combination DVD-RW/CD-RW drive.
  4. Display: 22-inch (560-mm) LCD monitor with 256-Mb dedicated video RAM.
  5. Full-size keyboard and mouse.
  6. Network Connectivity: 10/100 BaseT Ethernet.
  7. Operating System: Microsoft Windows XP Professional or Microsoft Windows Vista Business.

8. Productivity Software:
  - a. Microsoft Office Professional, XP or higher, including Word, Excel, and Outlook.
  - b. Adobe Reader 7.0 or higher.
  - c. WinZip 7.0 or higher.
9. Printer: "All-in-one" unit equipped with printer server, combining color printing, photocopying, scanning, and faxing, or separate units for each of these three functions.
10. Internet Service: Broadband modem, router and ISP, equipped with hardware firewall, providing minimum 384 Kbps upload and 1 Mbps download speeds at each computer.
11. Internet Security: Integrated software, providing software firewall, virus, spyware, phishing, and spam protection in a combined application.
12. Backup: External hard drive, minimum 500 gigabyte, with automated backup software providing daily backups.

### 3.3 SUPPORT FACILITIES INSTALLATION

- A. General: Comply with the following:
  1. Provide construction for temporary offices, shops, and sheds located within construction area or within 30 feet (9 m) of building lines that is noncombustible according to ASTM E 136. Comply with NFPA 241.
  2. Maintain support facilities until Architect schedules Substantial Completion inspection. Remove before Substantial Completion. Personnel remaining after Substantial Completion will be permitted to use permanent facilities, under conditions acceptable to Owner.
- B. Temporary Roads and Paved Areas: Construct and maintain temporary roads and paved areas adequate for construction operations. Locate temporary roads and paved areas within construction limits indicated on Drawings.
  1. Provide dust-control treatment that is nonpolluting and nontracking. Reapply treatment as required to minimize dust.
- C. Temporary Use of Permanent Roads and Paved Areas: Locate temporary roads and paved areas in same location as permanent roads and paved areas. Construct and maintain temporary roads and paved areas adequate for construction operations. Extend temporary roads and paved areas, within construction limits indicated, as necessary for construction operations.
  1. Coordinate elevations of temporary roads and paved areas with permanent roads and paved areas.
  2. Prepare subgrade and install subbase and base for temporary roads and paved areas according to Civil Drawings.
  3. Recondition base after temporary use, including removing contaminated material, regrading, proofrolling, compacting, and testing.
  4. Delay installation of final course of permanent hot-mix asphalt pavement until immediately before Substantial Completion. Repair hot-mix asphalt base-course pavement before installation of final course according to Civil Drawings.
- D. Traffic Controls: Comply with requirements of authorities having jurisdiction.
  1. Protect existing site improvements to remain including curbs, pavement, and utilities.

2. Maintain access for fire-fighting equipment and access to fire hydrants.
- E. Parking: Provide temporary parking areas for construction personnel.
- F. Dewatering Facilities and Drains: Comply with requirements of authorities having jurisdiction. Maintain Project site, excavations, and construction free of water.
  1. Dispose of rainwater in a lawful manner that will not result in flooding Project or adjoining properties or endanger permanent Work or temporary facilities.
  2. Remove snow and ice as required to minimize accumulations.
- G. Project Signs: Provide Project signs as indicated. Unauthorized signs are not permitted.
  1. Temporary Signs: Provide signs as indicated and as required to inform individuals seeking entrance to Project.
    - a. Provide temporary, directional signs for construction personnel and visitors.
  2. Maintain and touchup signs so they are legible at all times.
- H. Waste Disposal Facilities: Comply with requirements specified in Section 01 7419 "Construction Waste Management and Disposal".
- I. Lifts and Hoists: Provide facilities necessary for hoisting materials and personnel.
  1. Truck cranes and similar devices used for hoisting materials are considered "tools and equipment" and not temporary facilities.
- J. Temporary Elevator Use: [Use of elevators is not permitted] See related Section(s) specifying Elevators for temporary use of new elevators.
- K. Temporary Stairs: Until permanent stairs are available, provide temporary stairs where ladders are not adequate.
- L. Temporary Use of Permanent Stairs: Use of new stairs for construction traffic will be permitted, provided stairs are protected and finishes restored to new condition at time of Substantial Completion.

### 3.4 SECURITY AND PROTECTION FACILITIES INSTALLATION

- A. Protection of Existing Facilities: Protect existing vegetation, equipment, structures, utilities, and other improvements at Project site and on adjacent properties, except those indicated to be removed or altered. Repair damage to existing facilities.
- B. Environmental Protection: Provide protection, operate temporary facilities, and conduct construction as required to comply with environmental regulations and that minimize possible air, waterway, and subsoil contamination or pollution or other undesirable effects.
  1. Comply with work restrictions specified in Section 01 1100 "Summary of Work".
- C. Temporary Erosion and Sedimentation Control: Comply with requirements of 2003 EPA Construction General Permit and authorities having jurisdiction, whichever is more stringent and requirements specified in related Sections "Erosion and Sedimentation Control" or "Site Clearing."
  1. Dust Palliation

- a. All unpaved construction areas shall be sprinkled with water or other acceptable South Coast Air Quality Management District (SCAQMD) dust control agents during dust generating activities to reduce dust emissions. Additional watering or acceptable SCAQMD dust control agents shall be applied during dry weather or windy days until dust emissions are not visible.
    - 1) All grading and construction activities shall be suspended when wind speeds exceed 20 miles per hour, as directed by the Local Agency Having Jurisdiction.
    - 2) Construction sites shall be watered as directed by the local Agency Having Jurisdiction.
  - b. On dry days, dirt or debris spilled onto paved surfaces shall be swept up immediately to reduce resuspension of particulate matter caused by vehicle movement. Approach routes to the Project site shall be cleaned daily of construction related dirt in dry weather.
  - c. On-site stockpiles of excavated material shall be covered or watered.
- D. Stormwater Control: Comply with requirements of authorities having jurisdiction. Provide barriers in and around excavations and subgrade construction to prevent flooding by runoff of stormwater from heavy rains.
- E. Tree and Plant Protection: Comply with requirements specified in Section 01 5639 "Tree Protection". If no requirements are included, then provide as follows.
- 1. Install temporary fencing located as indicated or outside the drip line of trees to protect damage, flooding, and erosion.
- F. Pest Control: Engage pest-control service to recommend practices to minimize attraction and harboring of rodents, roaches, and other pests and to perform extermination and control procedures at regular intervals so Project will be free of pests and their residues at Substantial Completion. Perform control operations lawfully, using environmentally safe materials.
- G. Site Enclosure Fence: Before construction operations begin, furnish and install site enclosure fence in a manner that will prevent people and animals from easily entering site except by entrance gates.
- 1. Extent of Fence: As required to enclose entire Project site or portion determined sufficient to accommodate construction operations or as indicated on Drawings otherwise.
  - 2. Maintain security by limiting number of keys and restricting distribution to authorized personnel. Furnish one set of keys to Owner.
- H. Security Enclosure and Lockup: Install temporary enclosure around partially completed areas of construction. Provide lockable entrances to prevent unauthorized entrance, vandalism, theft, and similar violations of security. Lock entrances at end of each work day.
- I. Barricades, Warning Signs, and Lights: Comply with requirements of authorities having jurisdiction for erecting structurally adequate barricades, including warning signs and lighting.
- J. Temporary Egress: Maintain temporary egress from existing occupied facilities as indicated and as required by authorities having jurisdiction.

- K. Temporary Enclosures: Provide temporary enclosures for protection of construction, in progress and completed, from exposure, foul weather, other construction operations, and similar activities. Provide temporary weathertight enclosure for building exterior.
  - 1. Where heating or cooling is needed and permanent enclosure is incomplete, insulate temporary enclosures.
- L. Temporary Partitions: Provide floor-to-ceiling dustproof partitions to limit dust and dirt migration and to separate areas occupied by Owner and tenants from fumes and noise.
  - 1. Construct dustproof partitions with gypsum wallboard with joints taped on occupied side, and fire-retardant-treated plywood on construction operations side.
  - 2. Construct dustproof partitions with two layers of 6-mil (0.14-mm) polyethylene sheet on each side. Cover floor with two layers of 6-mil (0.14-mm) polyethylene sheet, extending sheets 18 inches (460 mm) up the sidewalls. Overlap and tape full length of joints. Cover floor with fire-retardant-treated plywood.
    - a. Construct vestibule and airlock at each entrance through temporary partition with not less than 48 inches (1219 mm) between doors. Maintain water-dampened foot mats in vestibule.
  - 3. Where fire-resistance-rated temporary partitions are indicated or are required by authorities having jurisdiction, construct partitions according to the rated assemblies.
  - 4. Insulate partitions to control noise transmission to occupied areas.
  - 5. Seal joints and perimeter. Equip partitions with gasketed dustproof doors and security locks where openings are required.
  - 6. Protect air-handling equipment.
  - 7. Provide walk-off mats at each entrance through temporary partition.
- M. Temporary Fire Protection: Install and maintain temporary fire-protection facilities of types needed to protect against reasonably predictable and controllable fire losses. Comply with NFPA 241; manage fire-prevention program.
  - 1. Prohibit smoking in construction areas.
  - 2. Supervise welding operations, combustion-type temporary heating units, and similar sources of fire ignition according to requirements of authorities having jurisdiction.
  - 3. Develop and supervise an overall fire-prevention and -protection program for personnel at Project site. Review needs with local fire department and establish procedures to be followed. Instruct personnel in methods and procedures. Post warnings and information.
  - 4. Provide temporary standpipes and hoses for fire protection. Hang hoses with a warning sign stating that hoses are for fire-protection purposes only and are not to be removed. Match hose size with outlet size and equip with suitable nozzles.

### 3.5 MOISTURE AND MOLD CONTROL

- A. Contractor's Moisture-Protection Plan: Avoid trapping water in finished work. Document visible signs of mold that may appear during construction.
- B. Exposed Construction Phase: Before installation of weather barriers, when materials are subject to wetting and exposure and to airborne mold spores, protect as follows:
  - 1. Protect porous materials from water damage.
  - 2. Protect stored and installed material from flowing or standing water.
  - 3. Keep porous and organic materials from coming into prolonged contact with concrete.
  - 4. Remove standing water from decks.
  - 5. Keep deck openings covered or dammed.

- C. Partially Enclosed Construction Phase: After installation of weather barriers but before full enclosure and conditioning of building, when installed materials are still subject to infiltration of moisture and ambient mold spores, protect as follows:
1. Do not load or install drywall or other porous materials or components, or items with high organic content, into partially enclosed building.
  2. Keep interior spaces reasonably clean and protected from water damage.
  3. Periodically collect and remove waste containing cellulose or other organic matter.
  4. Discard or replace water-damaged material.
  5. Do not install material that is wet.
  6. Discard, replace, or clean stored or installed material that begins to grow mold.
  7. Perform work in a sequence that allows any wet materials adequate time to dry before enclosing the material in drywall or other interior finishes.
- D. Controlled Construction Phase of Construction: After completing and sealing of the building enclosure but prior to the full operation of permanent HVAC systems, maintain as follows:
1. Control moisture and humidity inside building by maintaining effective dry-in conditions.
  2. Use permanent HVAC system to control humidity.
  3. Comply with manufacturer's written instructions for temperature, relative humidity, and exposure to water limits.
    - a. Hygroscopic materials that may support mold growth, including wood and gypsum-based products, that become wet during the course of construction and remain wet for 24 hours are considered defective.
    - b. Measure moisture content of materials that have been exposed to moisture during construction operations or after installation. Record readings beginning at time of exposure and continuing daily for 48 hours. Identify materials containing moisture levels higher than allowed. Report findings in writing to Architect.
    - c. Remove materials that cannot be completely restored to their manufactured moisture level within 48 hours.

### 3.6 CONTINUITY OF SERVICES

- A. Provide temporary panels, raceway, conductors, piping, ductwork and other facilities or equipment as required for continuous operation of utilities in service. Do not allow interruption of utilities.
1. All utility services, such as water, gas, sewers, electricity, data, cable television, communication, clock, bell, security or fire protection system serving the project, or any part of it, shall be maintained in continuous operation at all times for the duration of the contract.
  2. Transfer of utilities function to new systems shall be coordinated in writing with the Owner at least two weeks in advance of the proposed date.
  3. Notify and obtain approval from agencies having jurisdiction over utilities prior to transfer of function.
  4. Coordinate provision and removal of temporary facilities with phasing of construction operations as indicated, or as necessary for continuity of service.

### 3.7 OPERATION, TERMINATION, AND REMOVAL

- A. Supervision: Enforce strict discipline in use of temporary facilities. To minimize waste and abuse, limit availability of temporary facilities to essential and intended uses.

- B. Maintenance: Maintain facilities in good operating condition until removal.
  - 1. Maintain operation of temporary enclosures, heating, cooling, humidity control, ventilation, and similar facilities on a 24-hour basis where required to achieve indicated results and to avoid possibility of damage.
- C. Operate Project-identification-sign lighting daily from dusk until 12:00 midnight.
- D. Temporary Facility Changeover: Do not change over from using temporary security and protection facilities to permanent facilities until Substantial Completion.
- E. Termination and Removal: Remove each temporary facility when need for its service has ended, when it has been replaced by authorized use of a permanent facility, or no later than Substantial Completion. Complete or, if necessary, restore permanent construction that may have been delayed because of interference with temporary facility. Repair damaged Work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.
  - 1. Materials and facilities that constitute temporary facilities are property of Contractor. Owner reserves right to take possession of Project identification signs.
  - 2. Remove temporary roads and paved areas not intended for or acceptable for integration into permanent construction. Where area is intended for landscape development, remove soil and aggregate fill that do not comply with requirements for fill or subsoil. Remove materials contaminated with road oil, asphalt and other petrochemical compounds, and other substances that might impair growth of plant materials or lawns. Repair or replace street paving, curbs, and sidewalks at temporary entrances, as required by authorities having jurisdiction.
  - 3. At Substantial Completion, repair, renovate, and clean permanent facilities used during construction period. Comply with final cleaning requirements specified in Section 01 7700 "Closeout Procedures."

**- END OF SECTION -**

## - SECTION 01 5719 - CONSTRUCTION INDOOR AIR QUALITY MANAGEMENT

---

### PART 1 - GENERAL

#### 1.1 GENERAL PROVISIONS

- A. Attention is directed to the CONTRACT AND GENERAL CONDITIONS and all Sections within DIVISION 01 - GENERAL REQUIREMENTS which are hereby made a part of this Section of the Specifications.

#### 1.2 DESCRIPTION OF WORK

- A. Work Included: Provide labor, materials and equipment necessary to complete the work of this Section, including but not limited to the following:
1. LEED EQ Prerequisite 2: Prevent exposure of building systems to environmental tobacco smoke during construction. The use of any tobacco products during construction is now explicitly prohibited inside the building and within 25 feet (7.5 meters) (or greater, if required by the local jurisdiction) of the building entrance.
  2. LEED EQ Credit 3: Requirements for minimum indoor air quality (IAQ) performance standards during the construction period.
  3. LEED EQ Credit 4: Requirements for assessment of minimum indoor air quality (IAQ) performance standards through either building flush-out or air testing before occupancy
  4. With regard to these goals the Contractor shall develop, for Owner and Architect review, a Construction Indoor Air Quality Management Plan for this Project.
- B. Related Work: The following items are not included in this Section and are specified under the designated Sections:
1. Section 017419 — CONSTRUCTION AND DEMOLITION WASTE MANAGEMENT AND DISPOSAL for demolition and construction waste management.
  2. Division 23 - HVAC.

#### 1.3 PERFORMANCE REQUIREMENTS

- A. LEED EQ Prerequisite 2: Prevent exposure of building systems to environmental tobacco smoke during construction. At a minimum, take the following measures:
1. Do not allow smoking in enclosed portions of the project site. Do not allow smoking on the rooftop.
    - a. This prohibition includes electronic cigarettes.
  2. Locate exterior designated smoking areas at least 25 feet (7.5 m) away from entries, outdoor air intakes and operable windows. Provide signage for designated smoking areas, located within 10 feet of each entry.
- B. During construction meet or exceed the minimum requirements of the recommended Control Measures of the Sheet Metal and Air Conditioning National Contractors Association (SMACNA) IAQ Guidelines for Occupied Buildings under Construction, Second Edition, November 2007, Chapter 3.

- C. Protect absorptive materials from moisture damage when stored on-site and after installation.
- D. LEED EQ Credit 3: During construction, comply with the following requirements:
  - 1. If permanently installed air handlers are used during construction, filtration media with a Minimum Efficiency Reporting Value (MERV) of at least 8 (for ID+C) shall be used at each return air grille, as determined by ASHRAE 52.2-1999. Replace filtration media immediately prior to occupancy.
- E. LEED EQ Credit 4: Comply with one of the following requirements:
  - 1. Option 1: Perform a building flush-out with outside air, either before occupancy or during occupancy.
  - 2. Option 2: Conduct IAQ testing for air contaminant levels in the building, after construction ends and before occupancy.
- F. Pertinent Sections specifying Volatile Organic Compound (VOC) Content Restrictions.

#### 1.4 REQUIREMENTS

- A. Guidelines- REQUIREMENTS LEED BDC V4
- B. Develop and implement an indoor air quality (IAQ) management plan for the construction and preoccupancy phases of the building. The plan must address all of the following.
  - 1. During construction, our plan will meet or exceed all applicable recommended control measures of the Sheet Metal and Air Conditioning National Contractors Association (SMACNA) IAQ Guidelines for Occupied Buildings under Construction, 2nd edition, 2007, ANSI/SMACNA 008—2008, Chapter 3. Protect absorptive materials stored on-site and installed from moisture damage. Do not operate permanently installed air-handling equipment during construction unless filtration media with a minimum efficiency reporting value (MERV) of 8, as determined by ASHRAE 52.2—2007, with errata (or equivalent filtration media class of F5 or higher, as defined by CEN Standard EN 779—2002, Particulate Air Filters for General Ventilation, Determination of the Filtration Performance), are installed at each return air grille and return or transfer duct inlet opening such that there is no bypass around the filtration media. Immediately before occupancy, replace all filtration media with the final design filtration media, installed in accordance with the manufacturer's recommendations.
- C. Exhaust and Dilution Ventilation —
  - 1. Contractor will provide exhaust ventilation to collect air contaminants, dust and debris at the source of generation inside the work area and direct them outside of the building. Additionally, the system outlet ducting will be directed away from the building HVAC system inlets (mechanical or natural) and other migration vectors into the building. Capture velocities shall be sufficient (as specified in ACGIH Industrial Ventilation Manual) to maintain the levels of air contaminants in the work area to less than one-half the Permissible Exposure Limit (PEL) as defined in 29 CFR 1910.1000 and the Threshold Limit Value.
  - 2. Where materials or processes are used in the construction area that are hazardous, unpleasant, produces strong odors or generates fine particulate, HEPA equipped air filtration devices will be utilized to clean the air before discharging to the outside.

- D. HVAC Duct Protection —
1. Per SMACNA's IAQ Guidelines for Buildings under Construction, section 3.1, Contractor will take the following measures to ensure that HVAC systems and ducts are protected from airborne contaminants:
  2. Keep contaminants out of the HVAC system. Do not run permanently installed equipment if possible, or maintain proper filtration if it is used.
  3. If conditioning is required during construction, use supplementary HVAC units instead of permanently installed equipment if possible.
  4. If permanently installed HVAC system must be used during construction, install filtration to protect the return (negative pressure) side of the system. Replace these filters regularly during construction.
  5. Seal all ductwork, registers, diffusers, and returns with plastic when stored on site or not in service. Seal unfinished runs of ductwork at the end of each day.
  6. Replace all filtration media before occupancy.
  7. Do not store materials in mechanical rooms, to reduce potential debris and contamination to mechanical systems.
  8. Shut down or seal off the return air during any demolition operations.
- E. Moisture Control —
1. Because moisture can lead to microbial growth and the decomposition of building products, Contractor will take the following measures:
  2. Weather protection will be installed in areas where water intrusion may possibly occur.
  3. Work areas will be inspected for leaks and moisture damage on a continual basis.
  4. If leaks are observed, they will be repaired as soon as possible.
  5. Should building materials become wet, restoration drying techniques such as drying and dehumidification shall be employed in order to remove excess moisture from substrates.
  6. Porous building materials that cannot be dried within several hours will be discarded and replaced.
  7. Water-damaged and mold-contaminated building materials will be removed and replaced.
- F. Control of Combustion Products —
1. Because fuel-burning equipment releases contaminants such as carbon monoxide and respirable particulates into the air, Contractor will take steps to minimize use of such equipment inside the work areas. When alternatives to this type of equipment are impossible, the following measures will be taken:
    - a. Minimization of fuel-burning equipment inside and near the building. These machines will be cycled off when not in use.
    - b. No vehicles shall be left idling near temporary or permanent air intakes. When possible, motorized equipment used in the building will be electric powered.
    - c. If combustion engines are used within the building, they will be equipped with air scrubbers in order to minimize airborne contaminants.
- G. Source Control —
1. Adhesives and Sealants: Contractor will implement effective measures during construction to reduce the quantity of indoor air contaminants that are odorous, irritating or harmful to the comfort and well-being of workers and occupants. Measures will

include the adherence to Adhesives, Sealants and Sealant Primers: South Coast Air Quality Management District (SCAQMD) Rule #1168 concerning VOC limits.

2. Paints & Coatings: In order to reduce the quantity of indoor air contaminants that are odorous, irritating or harmful to the comfort and well being of workers and occupants, Contractor will use paints and coatings that meet the criteria as outlined in United States Green Building Council,
- H. LEED Reference Guide for Building Design and Construction, LEED v4.
1. Work Practices: In addition to the adherence to the above referenced guidelines, Contractor will implement the following measures:
    - a. Replacement of MERV8 filtration media immediately prior to occupancy.
    - b. Creation of continuous ventilation during installation of materials that emit high levels of VOCs. Interior areas will be ventilated directly to the outdoors.
    - c. Perform frequent periodic maintenance if the HVAC system is being utilized. When activities that produce high dust, such as drywall sanding, concrete cutting, masonry work, wood sawing and insulating or pollution levels occur, seal off the return air system openings completely for the duration of the task.
    - d. If permanently installed air handlers are used during construction, filtration media will be used at each return air grille that meets one of the following criteria below:
    - e. Filtration media with a minimum efficiency reporting value (MERV) of 8 as determined by ASHRAE Standard 52.2—2007.
    - f. Filtration media is Class F5 or higher, as defined by CEN Standard EN 779—2002, Particulate air filters for general ventilation, Determination of the filtration performance.
    - g. Filtration media with a minimum dust spot efficiency of 30% or higher and greater than 90% arrestance on a particle size of 3—10 µg.
    - h. Provide periodic duct inspections during construction. If ducts become contaminated due to inadequate protection, clean the ducts professionally in accordance with NADCA (National Air Duct Cleaning Association) standards.
    - i. Store ductwork and equipment off floor and out of water during construction.
    - j. Installation of odorous or VOC-containing products prior to the installation of porous or fibrous materials. Where this is not possible, the porous or fibrous materials will be protected with plastic.
    - k. Collection from Subcontractors of all MSDS sheets for VOC-containing products. These sheets will be kept in the Contractor Field Office.
    - l. Tobacco Smoke will be non-existent as there is no smoking allowed within the building or onsite unless you are within the designated smoking area, which is located over 100 feet from the building. These limitations shall also apply to electronic cigarettes and chewing tobacco.
    - m. The General Contractor shall take photographs showing measures in place.
- I. Pathway Interruption —
1. During construction, Contractor will isolate areas of work to prevent contamination of clean or occupied spaces. Depending on the weather conditions, ventilate using 100% outside air to exhaust contaminated air directly to the outside during installation of VOC-emitting materials. If needed, depressurization of the work area allowing the air pressure differential between construction and clean areas to contain dust and odors. Temporary barriers, if needed, will be erected to contain construction areas.
- J. Housekeeping —

1. Contractor will institute cleaning activities designed to control contaminants in building spaces during construction and prior to occupancy. Porous building materials will be protected from exposure to moisture and stored in a clean area prior to installation. Some other strategies include vacuum cleaners with high efficiency particulate filters, increasing the cleaning frequency and utilizing wetting agents from dust.
  2. Contractor will buyout green cleaning products with the Final Cleaners.
- K. Scheduling —
1. Construction activities over the duration of the project will be sequenced carefully to minimize the impact on the IAQ. Upon completion of construction, all filtration media will be replaced immediately prior to occupancy.
  2. For major renovations, Contractor will coordinate construction activities to minimize or eliminate disruption of operations in occupied areas.
  3. Contractor will keep trades that affect IAQ physically isolated on site and separated from each other by the construction schedule. For example, schedule drywall finishing and carpet installation for different days or different sections of the building. Consider after-hours or weekend work if practical.
  4. Contractor will install absorptive-finish materials after wet-applied materials have fully cured whenever possible. For example, install carpet and ceiling tile after paints and stains are completely dry.
  5. If applicable, Contractor will plan adequate time to conduct a flush-out and/or perform IAQ testing before occupancy, in compliance with EQ Credit Indoor Air Quality Assessment (see Related Credit Tips).
  6. Contractor will remove all temporary filtration media and replace them with new filters before occupancy.
- L. Documentation
1. Contractor will take photographs of each IAQ/SMACNA measures at least 3 separate time intervals for the project providing a minimum of 18 Photographs.
  2. Annotate photographs to indicate each IAQ measure depicted and its general location.
  3. Provide photographs of the methods employed to protect stored and installed absorptive materials from moisture damage during construction and preoccupancy.

## 1.5 SUBMITTALS

- A. Construction Indoor Air Quality (IAQ) Management Plan: With the completed Form of Bidder's Proposal, the Contractor shall submit a preliminary Construction IAQ Management Plan.
1. Within 21 calendar days after receipt of Notice to Proceed, the Contractor shall submit to the Owner a finalized Construction IAQ Management Plan.
  2. The proposed Plan shall comply with Division 23 — HVAC requirements.
  3. The proposed Plan shall include, but not be limited to, the following:
    - a. Protection of ventilation system components during construction.
    - b. Cleaning and replacing contaminated ventilation system components after construction, including filtration media.
    - c. Temporary ventilation.
    - d. Protection of absorptive materials from moisture damage when stored on-site and after installation, including exterior wall rain protection.
    - e. Sequence of finish installation plan.

- f. Selection of cleaning products and procedures to be used during construction and final cleaning.
  - g. Other items as required by SMACNA IAQ Guidelines for Occupied Buildings under Construction, Chapter 3.
  - 4. Coordinate Construction IAQ Management Plan with Owner's current IAQ management plans and procedures.
  - 5. Comply with the requirements of LEED EQ Credits 3 and 4.
- B. Indoor Air Quality (IAQ) Data: Submit emission test data as required, with testing laboratory and date clearly identified.
- C. Material Safety Data Sheets (MSDS): Submit for materials as required, with date clearly identified. MSDS must contain specific chemical content data identifying the percent of the total product mass represented by each listed chemical.
- D. Product Data: Submit for each type of filtration media used during construction and installed immediately prior to occupancy, with MERV values clearly identified.

#### **1.6 DELIVERY, STORAGE, AND HANDLING**

- A. Take special care to prevent accumulation of moisture on materials and within packaging during delivery, storage, and handling to prevent development of mold and mildew inside packaging and on products.
- B. Immediately remove from site and properly dispose of materials showing signs of mold and mildew, including materials with moisture stains.

## **2 PART 2 - PRODUCTS**

### **2.1 FILTRATION MEDIA**

- A. Filtration Media: Comply with ASHRAE 52.2-1999 and provide MERV as required.

## **3 PART 3 - EXECUTION**

### **3.1 CONSTRUCTION IAQ MANAGEMENT PLAN IMPLEMENTATION**

- A. IAQ Manager: The Contractor shall designate an on-site person responsible for instructing workers and overseeing and documenting results of the Construction IAQ Management Plan for the Project.
- B. Distribution: The Contractor shall distribute copies of the Construction IAQ Management Plan to the Job Site Foreman, each subcontractor, the Owner, and the Architect.
- C. Instruction: The Contractor shall provide on-site instruction of appropriate procedures and methods to be used by all parties at the appropriate stages of the Project.

- D. Preconditioning: Allow products, which have odors and significant VOC emissions, to off-gas in a dry, well-ventilated space for sufficient period to dissipate odors and emissions prior to delivery to Project.
  - 1. Remove containers and packaging from materials prior to conditioning to maximize off-gassing of VOCs.
  - 2. Condition products in ventilated warehouse or other building.
  
- E. Coordinate Construction IAQ Management Plan with final cleaning as indicated in Section 017300 -EXECUTION.

**- END OF SECTION -**

## - SECTION 01 6000 - PRODUCT REQUIREMENTS

---

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for selection of products for use in Project; product delivery, storage, and handling; manufacturers' standard warranties on products; special warranties; and comparable products.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 2500 "Substitution Procedures" for requests for substitutions.
- B. Section 01 4200 "References" for applicable industry standards for products specified.

#### 1.4 DEFINITIONS

- A. Products: Items obtained for incorporating into the Work, whether purchased for Project or taken from previously purchased stock. The term "product" includes the terms "material," "equipment," "system," and terms of similar intent.
  - 1. Named Products: Items identified by manufacturer's product name, including make or model number or other designation shown or listed in manufacturer's published product literature, that is current as of date of the Contract Documents.
  - 2. New Products: Items that have not previously been incorporated into another project or facility. Products salvaged or recycled from other projects are not considered new products.
  - 3. Comparable Product: Product that is demonstrated and approved through submittal process to have the indicated qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics that equal or exceed those of specified product.
- B. Basis-of-Design Product Specification: A specification in which a specific manufacturer's product is named and accompanied by the words "basis-of-design product," including make or model number or other designation, to establish the significant qualities related to type, function, dimension, in-service performance, physical properties, appearance, and other characteristics for purposes of evaluating comparable products of additional manufacturers named in the specification.

#### 1.5 ACTION SUBMITTALS

- A. Comparable Product Requests: Submit request for consideration of each comparable product. Identify product or fabrication or installation method to be replaced. Include Specification Section number and title and Drawing numbers and titles.
  - 1. Include data to indicate compliance with the requirements specified in "Comparable Products" Article.

2. Architect's Action: If necessary, Architect will request additional information or documentation for evaluation within one week of receipt of a comparable product request. Architect will notify Contractor of approval or rejection of proposed comparable product request within 15 days of receipt of request, or seven days of receipt of additional information or documentation, whichever is later.
  - a. Form of Approval: As specified in Section 01 3300 "Submittal Procedures."
  - b. Use product specified if Architect does not issue a decision on use of a comparable product request within time allocated.
- B. Basis-of-Design Product Specification Submittal: Comply with requirements in Section 01 3300 "Submittal Procedures." Show compliance with requirements.

## 1.6 QUALITY ASSURANCE

- A. Compatibility of Options: If Contractor is given option of selecting between two or more products for use on Project, select product compatible with products previously selected, even if previously selected products were also options.
  1. Each contractor is responsible for providing products and construction methods compatible with products and construction methods of other contractors.
  2. If a dispute arises between contractors over concurrently selectable but incompatible products, Architect will determine which products shall be used.

## 1.7 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, and handle products using means and methods that will prevent damage, deterioration, and loss, including theft and vandalism. Comply with manufacturer's written instructions.
- B. Delivery and Handling:
  1. Schedule delivery to minimize long-term storage at Project site and to prevent overcrowding of construction spaces.
  2. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damaged, or sensitive to deterioration, theft, and other losses.
  3. Deliver products to Project site in an undamaged condition in manufacturer's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting, and installing.
  4. Inspect products on delivery to determine compliance with the Contract Documents and to determine that products are undamaged and properly protected.
- C. Storage:
  1. Store products to allow for inspection and measurement of quantity or counting of units.
  2. Store materials in a manner that will not endanger Project structure.
  3. Store products that are subject to damage by the elements, under cover in a weathertight enclosure above ground, with ventilation adequate to prevent condensation.
  4. Protect foam plastic from exposure to sunlight, except to extent necessary for period of installation and concealment.
  5. Comply with product manufacturer's written instructions for temperature, humidity, ventilation, and weather-protection requirements for storage.

6. Protect stored products from damage and liquids from freezing.
7. Provide a secure location and enclosure at Project site for storage of materials and equipment by Owner's construction forces. Coordinate location with Owner.

## 1.8 PRODUCT WARRANTIES

- A. Warranties specified in other Sections shall be in addition to, and run concurrent with, other warranties required by the Contract Documents. Manufacturer's disclaimers and limitations on product warranties do not relieve Contractor of obligations under requirements of the Contract Documents.
  1. Manufacturer's Warranty: Written warranty furnished by individual manufacturer for a particular product and specifically endorsed by manufacturer to Owner.
  2. Special Warranty: Written warranty required by the Contract Documents to provide specific rights for Owner.
- B. Special Warranties: Prepare a written document that contains appropriate terms and identification, ready for execution.
  1. Manufacturer's Standard Form: Modified to include Project-specific information and properly executed.
  2. Specified Form: When specified forms are included with the Specifications, prepare a written document using indicated form properly executed.
  3. See other Sections for specific content requirements and particular requirements for submitting special warranties.
- C. Submittal Time: Comply with requirements in Section 01 7700 "Closeout Procedures."

## PART 2 - PRODUCTS

### 2.1 PRODUCT SELECTION PROCEDURES

- A. General Product Requirements: Provide products that comply with the Contract Documents, are undamaged and, unless otherwise indicated, are new at time of installation.
  1. Provide products complete with accessories, trim, finish, fasteners, and other items needed for a complete installation and indicated use and effect.
  2. Standard Products: If available, and unless custom products or nonstandard options are specified, provide standard products of types that have been produced and used successfully in similar situations on other projects.
  3. Owner reserves the right to limit selection to products with warranties not in conflict with requirements of the Contract Documents.
  4. Where products are accompanied by the term "as selected," Architect will make selection.

5. Descriptive, performance, and reference standard requirements in the Specifications establish salient characteristics of products.
  6. Or Equal: For products specified by name and accompanied by the term "or equal," or "or approved equal," or "or approved," comply with requirements in "Comparable Products" Article to obtain approval for use of an unnamed product.
- B. Product Selection Procedures:
1. Product: Where Specifications name a single manufacturer and product, provide the named product that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
  2. Manufacturer/Source: Where Specifications name a single manufacturer or source, provide a product by the named manufacturer or source that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered.
  3. Products:
    - a. Restricted List: Where Specifications include a list of names of both manufacturers and products, provide one of the products listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered unless otherwise indicated.
    - b. Nonrestricted List: Where Specifications include a list of names of both available manufacturers and products, provide one of the products listed, or an unnamed product, that complies with requirements. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product.
  4. Manufacturers:
    - a. Restricted List: Where Specifications include a list of manufacturers' names, provide a product by one of the manufacturers listed that complies with requirements. Comparable products or substitutions for Contractor's convenience will not be considered unless otherwise indicated.
    - b. Nonrestricted List: Where Specifications include a list of available manufacturers, provide a product by one of the manufacturers listed, or a product by an unnamed manufacturer, that complies with requirements. Comply with requirements in "Comparable Products" Article for consideration of an unnamed manufacturer's product.
  5. Basis-of-Design Product: Where Specifications name a product, or refer to a product indicated on Drawings, and include a list of manufacturers, provide the specified or indicated product or a comparable product by one of the other named manufacturers. Drawings and Specifications indicate sizes, profiles, dimensions, and other characteristics that are based on the product named. Comply with requirements in "Comparable Products" Article for consideration of an unnamed product by one of the other named manufacturers.
- C. Visual Matching Specification: Where Specifications require "match Architect's sample", provide a product that complies with requirements and matches Architect's sample. Architect's decision will be final on whether a proposed product matches.
1. If no product available within specified category matches and complies with other specified requirements, comply with requirements in Section 01 2500 "Substitution Procedures" for proposal of product.

- D. Visual Selection Specification: Where Specifications include the phrase "as selected by Architect from manufacturer's full range" or similar phrase, select a product that complies with requirements. Architect will select color, gloss, pattern, density, or texture from manufacturer's product line that includes both standard and premium items.

## 2.2 COMPARABLE PRODUCTS

- A. Conditions for Consideration: Architect will consider Contractor's request for comparable product when the following conditions are satisfied. If the following conditions are not satisfied, Architect may return requests without action, except to record noncompliance with these requirements:
1. Evidence that the proposed product does not require revisions to the Contract Documents, that it is consistent with the Contract Documents and will produce the indicated results, and that it is compatible with other portions of the Work.
  2. Detailed comparison of significant qualities of proposed product with those named in the Specifications. Significant qualities include attributes such as performance, weight, size, durability, visual effect, and specific features and requirements indicated.
  3. Evidence that proposed product provides specified warranty.
  4. List of similar installations for completed projects with project names and addresses and names and addresses of architects and owners, if requested.
  5. Samples, if requested.

## 2.3 PRODUCT REQUIREMENTS

- A. Salient Physical Attributes: Physical and other characteristics of products which may not be individually noted in the specifications are essential parts of the product specification. Products shall possess all attributes set forth in the manufacturer's catalog description for the specified item, except for such modifications thereto as may be indicated in the Contract Documents. Such attributes include:
1. Size: Dimensions, Form Factor (relative proportions of height, width, depth), Configuration. Ability to fit in space provided, without change to other assemblies or systems, set in place for use without reconfiguration.
  2. Capacity: Ability to fulfill specified requirements.
  3. Weight: Ability to be supported and braced by structure as shown.
  4. Physical arrangement of connections or ports: Intakes, exhausts, utility connections and other such items; their dimensions, form factors and relative proportions. Connect to other systems, ductwork, utilities, controls without changes to other systems.
  5. Required Clearances: Vertical, horizontal, to other equipment or construction, other similar attributes.
- B. Proprietary Names, Catalog Numbers and Identification: These attributes may be included for convenience in identifying products. Unless modified by Specifications or notation on Drawings, manufacturer's complete product catalog description for indicated product name or number shall constitute requirements for each product as if fully included in the product specification. Products shall incorporate all features set forth in the manufacturer's catalog description for the standard item, except for such modifications thereto as may be indicated in the Contract Documents.
- C. Proprietary names, catalog numbers, and specific requirements as may be set forth, are given to establish standard of design and quality for materials, construction and workmanship. Use

of this information to identify products is not intended to preclude use of alternate products by other manufacturers, except as specified in that given section.

- D. Manufacturer's Requirements: All deviations from design requirements shown or specified, resulting either from Contractor's or supplier's change of model, or manufacturer's recommendation, or from submitted alternates or accepted substitutions, shall be clearly indicated on the Contractor's submittals. Contractor shall provide all such manufacturer or supplier supplemental requirements at no additional cost.

## **PART 3 - EXECUTION (NOT USED)**

**- END OF SECTION -**

## - SECTION 01 7300 - EXECUTION

---

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section includes general administrative and procedural requirements governing execution of the Work including, but not limited to, the following:
  1. Construction layout.
  2. Field engineering and surveying.
  3. Installation of the Work.
  4. Cutting and patching, as required to:
    - a. Make the several parts fit properly.
    - b. Uncover work to provide for installation, inspection, or both of ill-timed work.
    - c. Remove and replace work non-conforming or defective work.
  5. Coordination of Owner-installed products.
  6. Progress cleaning.
  7. Starting and adjusting.
  8. Protection of installed construction.

#### **1.3 RELATED REQUIREMENTS**

- A. Section 01 1100 "Summary of Work" for limits on use of Project site.
- B. Section 01 3300 "Submittal Procedures" for submitting surveys.
- C. Section 01 7700 "Closeout Procedures" for submitting final property survey with Project Record Documents, recording of Owner-accepted deviations from indicated lines and levels, and final cleaning.
- D. Section 07 8413 "Penetration Firestopping" for patching penetrations in fire-rated construction.

#### **1.4 DEFINITIONS**

- A. Cutting: Removal of in-place construction necessary to permit installation or performance of other work.
- B. Patching: Fitting and repair work required to restore construction to original conditions after installation of other work.

### 1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For land surveyor.
- B. Certificates: Submit certificate signed by land surveyor certifying that location and elevation of improvements comply with requirements.
- C. Cutting and Patching Plan: Submit plan describing procedures at least 10 days prior to the time cutting and patching will be performed. Include the following information:
  - 1. Extent: Describe reason for and extent of each occurrence of cutting and patching.
  - 2. Changes to In-Place Construction: Describe anticipated results. Include changes to structural elements and operating components as well as changes in building appearance and other significant visual elements.
  - 3. Products: List products to be used for patching and firms or entities that will perform patching work.
  - 4. Dates: Indicate when cutting and patching will be performed.
  - 5. Utilities and Mechanical and Electrical Systems: List services and systems that cutting and patching procedures will disturb or affect. List services and systems that will be relocated and those that will be temporarily out of service. Indicate length of time permanent services and systems will be disrupted.
    - a. Include description of provisions for temporary services and systems during interruption of permanent services and systems.
- D. Landfill Receipts: Submit copy of receipts issued by a landfill facility, licensed to accept hazardous materials, for hazardous waste disposal.
- E. Certified Surveys: Submit two copies signed by land surveyor.
- F. Final Property Survey: Submit 10 copies showing the Work performed and record survey data.

### 1.6 QUALITY ASSURANCE

- A. Land Surveyor Qualifications: A professional land surveyor who is legally qualified to practice in jurisdiction where Project is located and who is experienced in providing land-surveying services of the kind indicated.
- B. Cutting and Patching: Comply with requirements for and limitations on cutting and patching of construction elements.
  - 1. Structural Elements: When cutting and patching structural elements, notify Architect of locations and details of cutting and await directions from Architect before proceeding. Shore, brace, and support structural elements during cutting and patching. Do not cut and patch structural elements in a manner that could change their load-carrying capacity or increase deflection.
  - 2. Operational Elements: Do not cut and patch operating elements and related components in a manner that results in reducing their capacity to perform as intended or that results in increased maintenance or decreased operational life or safety. Operational elements include the following:
    - a. Primary operational systems and equipment.
    - b. Fire separation assemblies.
    - c. Air or smoke barriers.
    - d. Fire-suppression systems.

- e. Mechanical systems piping and ducts.
  - f. Control systems.
  - g. Communication systems.
  - h. Fire-detection and -alarm systems.
  - i. Conveying systems.
  - j. Electrical wiring systems.
  - k. Operating systems of special construction.
  - l. Operating systems critical to the function of the facility.
3. Other Construction Elements: Do not cut and patch other construction elements or components in a manner that could change their load-carrying capacity, that results in reducing their capacity to perform as intended, or that results in increased maintenance or decreased operational life or safety. Other construction elements include but are not limited to the following:
- a. Water, moisture, or vapor barriers, including roofing.
  - b. Membranes and flashings.
  - c. Exterior curtain-wall construction.
  - d. Sprayed fire-resistive material.
  - e. Equipment supports.
  - f. Piping, ductwork, vessels, and equipment.
  - g. Noise- and vibration-control elements and systems.
4. Visual Elements: Do not cut and patch construction in a manner that results in visual evidence of cutting and patching. Do not cut and patch exposed construction in a manner that would, in Architect's opinion, reduce the building's aesthetic qualities. Remove and replace construction that has been cut and patched in a visually unsatisfactory manner.
- C. Cutting and Patching Conference: Before proceeding, meet at Project site with parties involved in cutting and patching, including mechanical and electrical trades. Review areas of potential interference and conflict. Coordinate procedures and resolve potential conflicts before proceeding.
- D. Manufacturer's Installation Instructions: Obtain and maintain on-site manufacturer's written recommendations and instructions for installation of products and equipment.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. General: Comply with requirements specified in other Sections.
- B. In-Place Materials: Use materials for patching identical to in-place materials. For exposed surfaces, use materials that visually match in-place adjacent surfaces to the fullest extent possible.
  - 1. If identical materials are unavailable or cannot be used, use materials that, when installed, will provide a match acceptable to Architect for the visual and functional performance of in- place materials.

## 2.2 FABRICATION

- A. Curved Construction: Where curved construction is shown, provide true curves minimizing joints. Segmented fabrication not allowed.
  - 1. Machine-roll components or elements required to be curved or "radiused".
  - 2. Do not field bend or "walk-down".

# PART 3 - EXECUTION

## 3.1 EXAMINATION

- A. Existing Conditions: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify the existence and location of underground utilities, mechanical and electrical systems, and other construction affecting the Work.
  - 1. Before construction, verify the location and invert elevation at points of connection of sanitary sewer, storm sewer, and water-service piping; underground electrical services, and other utilities.
  - 2. Furnish location data for work related to Project that must be performed by public utilities serving Project site.
- B. Examination and Acceptance of Conditions: Before proceeding with each component of the Work, examine substrates, areas, and conditions, with Installer or Applicator present where indicated, for compliance with requirements for installation tolerances and other conditions affecting performance. Record observations.
  - 1. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
  - 2. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
  - 3. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
- C. Written Report: Where a written report listing conditions detrimental to performance of the Work is required by other Sections, include the following:
  - 1. Description of the Work.
  - 2. List of detrimental conditions, including substrates.
  - 3. List of unacceptable installation tolerances.
  - 4. Recommended corrections.
- D. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

## 3.2 PREPARATION

- A. Existing Utility Information: Furnish information to local utility and Owner that is necessary to adjust, move, or relocate existing utility structures, utility poles, lines, services, or other utility appurtenances located in or affected by construction. Coordinate with authorities having jurisdiction.

- B. Field Measurements: Take field measurements as required to fit the Work properly. Recheck measurements before installing each product. Where portions of the Work are indicated to fit to other construction, verify dimensions of other construction by field measurements before fabrication. Coordinate fabrication schedule with construction progress to avoid delaying the Work.
- C. Space Requirements: Verify space requirements and dimensions of items shown diagrammatically on Drawings.
- D. Review of Contract Documents and Field Conditions: Immediately on discovery of the need for clarification of the Contract Documents caused by differing field conditions outside the control of Contractor, submit a request for information to Architect according to requirements in Section 01 3100 "Project Management and Coordination."

### 3.3 CONSTRUCTION LAYOUT

- A. Verification: Before proceeding to lay out the Work, verify layout information shown on Drawings, in relation to the property survey and existing benchmarks. If discrepancies are discovered, notify Architect promptly.
- B. General: Engage a land surveyor to lay out the Work using accepted surveying practices.
  - 1. Establish benchmarks and control points to set lines and levels at each story of construction and elsewhere as needed to locate each element of Project.
  - 2. Establish limits on use of Project site.
  - 3. Establish dimensions within tolerances indicated. Do not scale Drawings to obtain required dimensions.
  - 4. Inform installers of lines and levels to which they must comply.
  - 5. Check the location, level and plumb, of every major element as the Work progresses.
  - 6. Notify Architect when deviations from required lines and levels exceed allowable tolerances.
  - 7. Close site surveys with an error of closure equal to or less than the standard established by authorities having jurisdiction.
- C. Site Improvements: Locate and lay out site improvements, including pavements, grading, fill and topsoil placement, utility slopes, and rim and invert elevations.
- D. Building Lines and Levels: Locate and lay out control lines and levels for structures, building foundations, column grids, and floor levels, including those required for mechanical and electrical work. Transfer survey markings and elevations for use with control lines and levels. Level foundations and piers from two or more locations.
- E. Record Log: Maintain a log of layout control work. Record deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used. Make the log available for reference by Architect.

### 3.4 FIELD ENGINEERING

- A. Identification: Owner will identify existing benchmarks, control points, and property corners.
- B. Reference Points: Locate existing permanent benchmarks, control points, and similar reference points before beginning the Work. Preserve and protect permanent benchmarks and control points during construction operations.
  - 1. Do not change or relocate existing benchmarks or control points without prior written approval of Architect. Report lost or destroyed permanent benchmarks or control points promptly. Report the need to relocate permanent benchmarks or control points to Architect before proceeding.
  - 2. Replace lost or destroyed permanent benchmarks and control points promptly. Base replacements on the original survey control points.
- C. Benchmarks: Establish and maintain a minimum of two permanent benchmarks on Project site, referenced to data established by survey control points. Comply with authorities having jurisdiction for type and size of benchmark.
  - 1. Record benchmark locations, with horizontal and vertical data, on Project Record Documents.
  - 2. Where the actual location or elevation of layout points cannot be marked, provide temporary reference points sufficient to locate the Work.
  - 3. Remove temporary reference points when no longer needed. Restore marked construction to its original condition.
- D. Certified Survey: On completion of foundation walls, major site improvements, and other work requiring field-engineering services, prepare a certified survey showing dimensions, locations, angles, and elevations of construction and sitework.
- E. Final Property Survey: Engage a land surveyor to prepare a final property survey showing significant features (real property) for Project. Include on the survey a certification, signed by land surveyor, that principal metes, bounds, lines, and levels of Project are accurately positioned as shown on the survey.
  - 1. Show boundary lines, monuments, streets, site improvements and utilities, existing improvements and significant vegetation, adjoining properties, acreage, grade contours, and the distance and bearing from a site corner to a legal point.
  - 2. Recording: At Substantial Completion, have the final property survey recorded by or with authorities having jurisdiction as the official "property survey."

### 3.5 INSTALLATION

- A. General: Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
  - 1. Make vertical work plumb and make horizontal work level.
  - 2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
  - 3. Conceal pipes, ducts, and wiring in finished areas unless otherwise indicated.
  - 4. Maintain minimum headroom clearance of 96 inches (2440 mm) in occupied spaces and 90 inches (2300 mm) in unoccupied spaces, unless more stringent requirements are shown on the Drawings or related specifications.

- B. Comply with manufacturer's written instructions and recommendations for installing products in applications indicated.
- C. Install products at the time and under conditions that will ensure the best possible results. Maintain conditions required for product performance until Substantial Completion.
- D. Conduct construction operations so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy.
- E. Sequence the Work and allow adequate clearances to accommodate movement of construction items on site and placement in permanent locations.
- F. Tools and Equipment: Do not use tools or equipment that produce harmful noise levels.
- G. Templates: Obtain and distribute to the parties involved templates for work specified to be factory prepared and field installed. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing products to comply with indicated requirements.
- H. Attachment: Provide blocking and attachment plates and anchors and fasteners of adequate size and number to securely anchor each component in place, accurately located and aligned with other portions of the Work. Where size and type of attachments are not indicated, verify size and type required for load conditions.
  - 1. Mounting Heights: Where mounting heights are not indicated, mount components at heights directed by Architect.
  - 2. Allow for building movement, including thermal expansion and contraction.
  - 3. Coordinate installation of anchorages. Furnish setting drawings, templates, and directions for installing anchorages, including sleeves, concrete inserts, anchor bolts, and items with integral anchors, that are to be embedded in concrete or masonry. Deliver such items to Project site in time for installation.
- I. Joints: Make joints of uniform width. Where joint locations in exposed work are not indicated, arrange joints for the best visual effect. Fit exposed connections together to form hairline joints.
- J. Grind or bush split-faced or textured masonry to achieve hairline fit to adjacent trim, flashings, inserts, escutcheons or other penetrating elements.
- K. Hazardous Materials: Use products, cleaners, and installation materials that are not considered hazardous.

### 3.6 CUTTING AND PATCHING

- A. Cutting and Patching, General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.
  - 1. Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.

- B. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during installation or cutting and patching operations, by methods and with materials so as not to void existing warranties.
- C. Temporary Support: Provide temporary support of work to be cut.
- D. Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.
- E. Adjacent Occupied Areas: Where interference with use of adjoining areas or interruption of free passage to adjoining areas is unavoidable, coordinate cutting and patching according to requirements in Section 01 1100 "Summary of Work".
- F. Existing Utility Services and Mechanical/Electrical Systems: Where existing services/systems are required to be removed, relocated, or abandoned, bypass such services/systems before cutting to prevent interruption to occupied areas.
- G. Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
  - 1. In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots neatly to minimum size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
  - 2. Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
  - 3. Concrete and Masonry: Cut using a cutting machine, such as an abrasive saw or a diamond-core drill.
  - 4. Excavating and Backfilling: Comply with requirements in applicable Sections where required by cutting and patching operations.
  - 5. Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
  - 6. Proceed with patching after construction operations requiring cutting are complete.
- H. Discrepancies:
  - 1. If uncovered conditions are not as anticipated, immediately notify the Architect through the Owner's Representative and secure needed directions.
  - 2. Do not proceed in areas of discrepancy until all such discrepancies have been fully resolved.
- I. Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other work. Patch with durable seams that are as invisible as practicable. Provide materials and comply with installation requirements specified in other Sections, where applicable.
  - 1. Inspection: Where feasible, test and inspect patched areas after completion to demonstrate physical integrity of installation.

2. Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will minimize evidence of patching and refinishing.
    - a. Clean piping, conduit, and similar features before applying paint or other finishing materials.
    - b. Restore damaged pipe covering to its original condition.
  3. When existing finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect.
  4. Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, color, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform color and appearance.
    - a. Where patching occurs in a painted surface, prepare substrate and apply primer and intermediate paint coats appropriate for substrate over the patch, and apply final paint coat over entire unbroken surface containing the patch. Provide additional coats until patch blends with adjacent surfaces.
  5. Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.
  6. Exterior Building Enclosure: Employ original installer to perform cutting for weather exposed and moisture resistant elements, and sight exposed surfaces. Patch components in a manner that restores enclosure to a weathertight condition and ensures thermal and moisture integrity of building enclosure.
- J. Cleaning: Clean areas and spaces where cutting and patching are performed. Remove paint, mortar, oils, putty, and similar materials from adjacent finished surfaces.

### 3.7 OWNER-INSTALLED PRODUCTS

- A. Site Access: Provide access to Project site for Owner's construction personnel.
- B. Coordination: Coordinate construction and operations of the Work with work performed by Owner's construction personnel.
  1. Construction Schedule: Inform Owner of Contractor's preferred construction schedule for Owner's portion of the Work. Adjust construction schedule based on a mutually agreeable timetable. Notify Owner if changes to schedule are required due to differences in actual construction progress.
  2. Preinstallation Conferences: Include Owner's construction personnel at preinstallation conferences covering portions of the Work that are to receive Owner's work. Attend preinstallation conferences conducted by Owner's construction personnel if portions of the Work depend on Owner's construction.

### 3.8 PROGRESS CLEANING

- A. General: Clean Project site and work areas daily, including common areas. Enforce requirements strictly. Dispose of materials lawfully.
  1. Comply with requirements in NFPA 241 for removal of combustible waste materials and debris.

2. Do not hold waste materials more than seven days during normal weather or three days if the temperature is expected to rise above 80 deg F (27 deg C).
  3. Containerize hazardous and unsanitary waste materials separately from other waste. Mark containers appropriately and dispose of legally, according to regulations.
    - a. Use containers intended for holding waste materials of type to be stored.
  4. Coordinate progress cleaning for joint-use areas where Contractor and other contractors are working concurrently.
- B. Site: Maintain Project site free of waste materials and debris.
- C. Work Areas: Clean areas where work is in progress to the level of cleanliness necessary for proper execution of the Work.
  1. Remove liquid spills promptly.
  2. Where dust would impair proper execution of the Work, broom-clean or vacuum the entire work area, as appropriate.
- D. Installed Work: Keep installed work clean. Clean installed surfaces according to written instructions of manufacturer or fabricator of product installed, using only cleaning materials specifically recommended. If specific cleaning materials are not recommended, use cleaning materials that are not hazardous to health or property and that will not damage exposed surfaces.
- E. Concealed Spaces: Remove debris from concealed spaces before enclosing the space.
- F. Exposed Surfaces in Finished Areas: Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.
- G. Waste Disposal: Do not bury or burn waste materials on-site. Do not wash waste materials down sewers or into waterways. Comply with waste disposal requirements in Section 01 7419 "Construction Waste Management and Disposal".
- H. During handling and installation, clean and protect construction in progress and adjoining materials already in place. Apply protective covering where required to ensure protection from damage or deterioration at Substantial Completion.
- I. Clean and provide maintenance on completed construction as frequently as necessary through the remainder of the construction period. Adjust and lubricate operable components to ensure operability without damaging effects.
- J. Limiting Exposures: Supervise construction operations to assure that no part of the construction, completed or in progress, is subject to harmful, dangerous, damaging, or otherwise deleterious exposure during the construction period.

### **3.9 STARTING AND ADJUSTING**

- A. Start equipment and operating components to confirm proper operation. Remove malfunctioning units, replace with new units, and retest.

- B. Adjust equipment for proper operation. Adjust operating components for proper operation without binding.
- C. Test each piece of equipment to verify proper operation. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- D. Manufacturer's Field Service: Comply with qualification requirements in Section 01 4000 "Quality Requirements".

### **3.10 PROTECTION OF INSTALLED CONSTRUCTION**

- A. Provide final protection and maintain conditions that ensure installed Work is without damage or deterioration at time of Substantial Completion.
- B. Comply with manufacturer's written instructions for temperature and relative humidity.

### **3.11 EXISTING UTILITY CONTINUITY**

- A. Examine and test existing building systems and utilities with components requiring relocation during performance of this work. Examples may include but are not limited to:
  - 1. Mechanical Systems
  - 2. Plumbing Systems
  - 3. Electrical Systems, line voltage, low voltage, signal alarm, or data.
  - 4. Fiber-optic data or communication cabling systems.
- B. Remove or relocate these components while work is performed.
  - 1. Fiber-optic data cabling systems are extremely fragile and subject to mechanical damage. Relocate these systems with great care. Do not disconnect or remove these systems, which must remain in place and in operation during the Work.
- C. Restore these components to the former location upon completion of the Work.
- D. Test systems under provisions of related sections specifying start-up and adjusting to confirm proper operation. Conduct tests in the presence of the Architect and Owner's Representative.
- E. Perform remedial work as necessary to establish proper operation. Assume responsibility for proper operation of systems following completion of Work.

**- END OF SECTION -**

## - SECTION 01 7419 - CONSTRUCTION AND DEMOLITION MANAGEMENT AND DISPOSAL

---

### PART 1 – GENERAL

#### 1.1 GENERAL PROVISIONS

- A. Attention is directed to the CONTRACT AND GENERAL CONDITIONS and all Sections within DIVISION 01 - GENERAL REQUIREMENTS which are hereby made a part of this Section of the Specifications

#### 1.2 SUMMARY

- A. This Section includes requirements for the Contractor's implementation of waste management controls and systems for the duration of the Work.
- B. LEED MRp2, Construction and Demolition Waste Management Planning: Develop a waste management plan, quantifying material diversion by either weight or volume to recycle and/or salvage non-hazardous construction and demolition debris.
  - 1. Exclude excavated soil and land-clearing debris from calculations.
  - 2. Include materials destined for alternative daily cover (ADC) in the calculations as waste (not diversion).
  - 3. Include wood waste converted to fuel (bio-fuel) in the calculations. Other types of waste-to-energy are not considered diversion for this credit.
- C. LEED MRc6, Construction and Demolition Waste Management: Comply with the following path, as directed by the LEED Checklist:
  - 1. Option 1, Diversion, Path 2: Divert at least 75 percent and four material streams of non-hazardous construction and demolition debris.
  - 2. The performance threshold requires both a minimum diversion percentage and diversion of at least four (Path 2) material streams. This will require source separation of these materials.
  - 3. Ensure that units are consistent for all materials, in either weight or volume.
  - 4. Diverted waste includes all recycled, salvaged, reused, and donated materials.
  - 5. ADC does not count as diversion but must be included in total construction and demolition waste.
  - 6. Exclude hazardous waste, land-clearing debris, soil, and landscaping materials.
  - 7. Projects that cannot meet the credit threshold via reuse or recycling are eligible to claim diversion through waste-to-energy systems, provided they meet applicable standards and requirements.
  - 8. As a best practice, a material stream should constitute at least 5% (by weight or volume) of total diverted materials.
- D. Sustainable Design Intent: Comply with project requirements intended to achieve certification, measured and documented according to the LEED Green Building Rating System, of the US Green Building Council. Refer to Section 018110 - SUSTAINABLE DESIGN REQUIREMENTS, for certification level and certification requirements.

- E. Related Sections include the following:
1. Section 018120 - CONSTRUCTION INDOOR AIR QUALITY MANAGEMENT.
  2. Section 024100 - DEMOLITION for demolition, salvage, and reuse requirements.
  3. Section 028213 - ASBESTOS ABATEMENT.
  4. Section 028310 - LEAD-BASED PAINT AWARENESS.
  5. Section 028416 - HANDLING OF LIGHTING BALLASTS AND MERCURY.
  6. Section 042000 - UNIT MASONRY for waste management and disposal of masonry waste.
  7. Section 044200 - EXTERIOR STONE CLADDING for waste management and disposal of stone waste.
  8. Section 075400 - THERMOPLASTIC MEMBRANE ROOFING for waste management and disposal of roofing waste.
  9. Section 076200 - SHEET METAL FLASHING AND TRIM for waste management and disposal of flashing waste.

### 1.3 DEFINITIONS

- A. Construction Waste: Building and site improvement materials and other solid waste resulting from construction, remodeling, renovation, or repair operations. Construction waste includes packaging.
- B. Demolition Waste: Building and site improvement materials resulting from demolition or selective demolition operations.
- C. Disposal: Removal off-site of demolition and construction waste and subsequent sale, recycling, reuse, or deposit in landfill or incinerator acceptable to authorities having jurisdiction.
- D. Recycle: Recovery of demolition or construction waste for subsequent processing in preparation for reuse.
- E. Salvage: Recovery of demolition or construction waste and subsequent sale or reuse in another facility.
- F. Salvage and Reuse: Recovery of demolition or construction waste and subsequent incorporation into the Work.

### 1.4 REQUIREMENTS FOR CONSTRUCTION WASTE MANAGEMENT

- A. LEED BD+C: New Construction LEED v4 Construction and Demolition Waste Management Plan.
- B. The Contractor shall prepare and submit a Construction Waste Management Plan to the Owner and Architect for approval. The CWM Plan shall outline the provisions to be implemented by the Contractor and Subcontractors to recycle and salvage demolition and construction waste generated during the project. Develop and implement a construction and demolition waste management plan:
1. Establish waste diversion goals for the project by identifying at least five materials (both structural and nonstructural) targeted for diversion. Approximate a percentage of the overall project waste that these materials represent.
  2. Specify whether materials will be separated or commingled and describe the diversion strategies planned for the project. Describe where the materials will be taken and how the recycling facility will process the material.
  3. Provide a final report detailing all major waste streams generated, including disposal and diversion rates.
  4. Alternative daily cover (ADC) does not qualify as material diverted from disposal.

5. Land-clearing debris is not considered construction, demolition, or renovation waste that can contribute to waste diversion.
  6. Hazardous waste shall not contribute to the recycling rate.
  7. Include wood waste converted to fuel (bio-fuel) in the calculations; other types of waste-to-energy are not considered diversion for this credit.
- C. Upon approval of the CWM Plan by the Owner and Architect, it shall be implemented by the Contractor and Subcontractors throughout the duration of the project, and documented in accordance with the Submittal Requirements below.
- D. The Construction Waste Management Plan shall include, but not be limited to, the following components:
1. Listing of Targeted Materials: The contractor shall develop a list of the waste materials from the Project that will be targeted for reuse, salvage, or recycling. The following materials, at minimum, shall be accounted for (materials that will not be recycled shall be indicated as such):
  2. Divert at least 95% of the total construction and demolition material; diverted materials must include at least four material streams.
    - a. Cardboard, paper, and packaging materials.
    - b. Clean dimensional wood, palette wood.
    - c. Beverage containers and employee food containers.
    - d. Concrete and concrete masonry units (CMU).
    - e. Metals from banding, stud trim, ductwork, piping, rebar, roofing, flashing, other trim, steel, iron, galvanized sheet steel, stainless steel, aluminum, copper, zinc, lead, brass, and bronze.
    - f. Drywall or gypsum wall board (GWB).
    - g. Carpet and pad.
    - h. Paint.
    - i. Rigid Foam.
    - j. Glass.
    - k. Plastics.
    - l. Acoustical ceiling panels.
  3. Landfill Information: The contractor shall provide the name and location of the landfill(s) where trash will be disposed of.
  4. Recycling or Salvaging Facilities: The contractor shall provide the names and locations of the recycling or salvaging facilities where waste materials will be delivered. All recycling facilities provide a letter fitting the following criteria:
    - a. Must be on letterhead of the Recycling Facility.
    - b. Must be signed by responsible party at Recycling Facility.
    - c. Must state end-use of recycled material (ex — wood may be ground and sold as mulch).
    - d. Must state recycling rate of the Recycling Facility.
  5. Sorting Method: The contractor shall provide a description of the proposed means of sorting and transporting the recyclable materials (whether materials will be site-separated and self-hauled to designated centers, or whether mixed materials will be collected by a waste hauler and removed from the site for off-site sorting). Waste haulers using off-site sorting operations shall provide a written description of the sorting process used, and their method for calculating project-specific recycling rates.
  6. Packaging Waste: The contractor shall note whether suppliers will eliminate or take back packaging for major materials delivered to the site.

7. Implementation and Supervision: The contractor shall include provisions in the Construction Waste Management Plan for addressing conditions in the field that do not adhere to the CWM Plan, including provisions to rectify non-compliant conditions.
  8. Additional Information: The contractor shall include any additional information deemed relevant to describe the scope and intent of the CWM Plan to the Owner and Architect.
- E. Construction Waste Management and recycling requirements shall be incorporated into all Subcontractor's contracts.

## 1.5 SUBMITTALS

- A. Waste Management Plan: Submit three copies of plan within 30 days of date established for the Notice to Proceed.
- B. Demonstrate the achievement of 75% diversion of the total construction and demolition material; be sure to track diverted materials for at least four material streams.
- C. Calculations and supporting documentation to demonstrate end-of—project recycling rates meeting the requirements for Construction Waste Management above. The process for recording and assembling documentation shall be as follows:
  1. Record and document the total weight (in tons) of all demolition and construction waste materials sent to the landfill. Monthly Waste Management Reporting Forms shall be used as the basis for determining the total amount of waste landfilled for the project. The monthly reporting forms shall specify:
    - a. the number of dumpsters or other containers sent to the landfill for that month;
    - b. the volume (in cubic yards) of each dumpster or container sent to the landfill for that month;
    - c. the type of waste contained in each dumpster or container; and
    - d. the weight of the waste in each dumpster or container. If the weight of the waste is not directly measured for each dumpster or container, the following Solid Waste Conversion Factors shall be used to convert the volume of waste to weight:
      - 1) Mixed Waste: 350 lbs/cubic yard.
      - 2) Wood: 300 lbs/cubic yard.
      - 3) Cardboard: 100 lbs/cubic yard.
      - 4) Gypsum Wallboard: 500 lbs/cubic yard.
      - 5) Rubble: 1,400 lbs/cubic yard.
  2. Record and document the total weight (in tons) of all demolition and construction waste materials recycled or salvaged. Monthly Waste Management Reporting Forms shall be used as the basis for determining the total amount of waste recycled or salvaged for the project. The monthly reporting forms shall specify:
    - a. the number of dumpsters or other containers of recycled or salvaged materials for that month;
    - b. the volume (in cubic yards) of each dumpster or container of recycled or salvaged materials for that month;
    - c. the type of recycled or salvaged material contained in each dumpster or container; and
    - d. the weight of the recycled or salvaged material in each dumpster or container. If the weight of the material is not directly measured for each dumpster or container, the Solid Waste Conversion Factors listed for landfill waste (see above) shall be used, where applicable, to convert the volume of material to weight. For materials

not contained in the Solid Waste Conversion Factors (e.g., metals, glass), the Contractor shall propose a conversion factor for review by the Owner and Architect.

3. Calculate the end-of-project recycling rate percentage by dividing the recycled and salvaged waste (in tons) by the total waste generated (recycled, salvaged, and landfilled waste — also in tons), and multiplying by 100.
- D. LEED Submittal: LEED BD+C: Building Design & Construction LEED v4 Construction and Demolition Waste Management Plan signed by Contractor, tabulating total waste material, quantities diverted and means by which it is diverted, and statement that requirements for the credit have been met.
- E. Qualification Data: For Waste Management Coordinator.

## 1.6 QUALITY ASSURANCE

- A. Waste Management Coordinator Qualifications: LEED Accredited Professional by U.S. Green Building Council. Waste management coordinator may also serve as LEED coordinator.
- B. Regulatory Requirements: Comply with hauling and disposal regulations of authorities having jurisdiction.
- C. Waste Management Conference: Conduct conference at Project site to comply with requirements in Division 01 Section "Project Management and Coordination." Review methods and procedures related to waste management including, but not limited to, the following:
  1. Review and discuss waste management plan including responsibilities of Waste Management Coordinator.
  2. Review requirements for documenting quantities of each type of waste and its disposition.
  3. Review and finalize procedures for materials separation and verify availability of containers and bins needed to avoid delays.
  4. Review procedures for periodic waste collection and transportation to recycling and disposal facilities.
  5. Review waste management requirements for each trade.

## 1.7 WASTE MANAGEMENT PLAN

- A. General: Develop plan consisting of waste identification, waste reduction work plan, and cost/revenue analysis. Include separate sections in plan for demolition and construction waste. Indicate quantities by weight or volume, but use same units of measure throughout waste management plan.
- B. Waste Identification: Indicate anticipated types and quantities of demolition, site-clearing, and construction waste generated by the Work. Include estimated quantities and assumptions for estimates.
- C. Waste Reduction Work Plan: List each type of waste and whether it will be salvaged, recycled, or disposed of in landfill or incinerator. Include points of waste generation, total quantity of

each type of waste, quantity for each means of recovery, and handling and transportation procedures.

1. Salvaged Materials for Reuse: For materials that will be salvaged and reused in this Project, describe methods for preparing salvaged materials before incorporation into the Work.
  2. Salvaged Materials for Sale: For materials that will be sold to individuals and organizations, include list of their names, addresses, and telephone numbers.
  3. Salvaged Materials for Donation: For materials that will be donated to individuals and organizations, include list of their names, addresses, and telephone numbers.
  4. Recycled Materials: Include list of local receivers and processors and type of recycled materials each will accept. Include names, addresses, and telephone numbers.
  5. Disposed Materials: Indicate how and where materials will be disposed of. Include name, address, and telephone number of each landfill and incinerator facility.
  6. Handling and Transportation Procedures: Include method that will be used for separating recyclable waste including sizes of containers, container labeling, and designated location on Project site where materials separation will be located.
- D. Forms: Prepare waste management plan on forms included at end of this Section.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 - EXECUTION**

### **3.1 PLAN IMPLEMENTATION**

- A. General: Implement waste management plan as approved by Architect, Owner, and Construction Manager. Provide handling, containers, storage, signage, transportation, and other items as required to implement waste management plan during the entire duration of the Contract.
- B. Waste Management Coordinator: Engage a waste management coordinator to be responsible for implementing, monitoring, and reporting status of waste management work plan. Coordinator shall be present at Project site full time for duration of Project.
- C. Training: Train workers, subcontractors, and suppliers on proper waste management procedures, as appropriate for the Work occurring at Project site.
  1. Distribute waste management plan to everyone concerned within three days of submittal return.
  2. Distribute waste management plan to entities when they first begin work on-site. Review plan procedures and locations established for salvage, recycling, and disposal.
- D. Site Access and Temporary Controls: Conduct waste management operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
  1. Designate and label specific areas on Project site necessary for separating materials that are to be salvaged, recycled, reused, donated, and sold.
  2. Comply with Division 01 Section "Temporary Facilities and Controls" for controlling dust and dirt, environmental protection, and noise control.

### **3.2 SALVAGING DEMOLITION WASTE**

- A. Refer to Section 024100 - DEMOLITION

### **3.3 RECYCLING DEMOLITION AND CONSTRUCTION WASTE**

- A. General: Recycle paper and beverage containers used by on-site workers.
- B. Recycling Incentives: Revenues, savings, rebates, tax credits, and other incentives received for recycling waste materials shall be reflected in the GMP.
- C. Procedures: Separate recyclable waste from other waste materials, trash, and debris. Separate recyclable waste by type at Project site to the maximum extent practical.
  - 1. Provide appropriately marked containers or bins for controlling recyclable waste until they are removed from Project site. Include list of acceptable and unacceptable materials at each container and bin.
    - a. Inspect containers and bins for contamination and remove contaminated materials if found.
  - 2. Stockpile processed materials on-site without intermixing with other materials. Place, grade, and shape stockpiles to drain surface water. Cover to prevent windblown dust.
  - 3. Stockpile materials away from construction area. Do not store within drip line of remaining trees.
  - 4. Store components off the ground and protect from the weather.
  - 5. Remove recyclable waste off Owner's property and transport to recycling receiver or processor.
- D. Gypsum Board: Investigate recycling of gypsum board in a separate collection container from general construction wastes. If costs for separate disposal are approved by Owner, recycle gypsum board separately from general construction wastes.

### **3.4 RECYCLING CONSTRUCTION WASTE**

- A. Packaging:
  - 1. Cardboard and Boxes: Break down packaging into flat sheets. Bundle and store in a dry location.
  - 2. Polystyrene Packaging: Separate and bag materials.
  - 3. Pallets: As much as possible, require deliveries using pallets to remove pallets from Project site. For pallets that remain on-site, break down pallets into component wood pieces and comply with requirements for recycling wood.
  - 4. Crates: Break down crates into component wood pieces and comply with requirements for recycling wood.

### **3.5 DISPOSAL OF WASTE**

- A. General: Except for items or materials to be salvaged, recycled, or otherwise reused, remove waste materials from Project site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.

PROJECT NO.  
#CA23-2526

STEM CLASSROOM HVAC UPGRADES  
WEST VALLEY COLLEGE, SARATOGA, CA

1. Except as otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
  2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
- B. Burning: Do not burn waste materials.
- C. Disposal: Transport waste materials off Owner's property and legally dispose of them.

**- END OF SECTION -**

## - SECTION 01 7700 - CLOSEOUT PROCEDURES

---

### **PART 1 - GENERAL**

#### **1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### **1.2 SUMMARY**

- A. Section includes administrative and procedural requirements for contract closeout, including, but not limited to, the following:
  - 1. Substantial Completion procedures.
  - 2. Final completion procedures.
  - 3. Warranties.
  - 4. Final cleaning.
  - 5. Repair of the Work.

#### **1.3 RELATED REQUIREMENTS**

- A. Section 01 7300 "Execution" for progress cleaning of Project site.
- B. Section 01 7823 "Operation and Maintenance Data" for operation and maintenance manual requirements.
- C. Section 01 7839 "Project Record Documents" for submitting record Drawings, record Specifications, and record Product Data.
- D. Section 01 7900 "Demonstration and Training" for requirements for instructing Owner's personnel.

#### **1.4 ACTION SUBMITTALS**

- A. Product Data: For cleaning agents.
- B. Contractor's List of Incomplete Items: Initial submittal at Substantial Completion.
- C. Certified List of Incomplete Items: Final submittal at Final Completion.

#### **1.5 CLOSEOUT SUBMITTALS**

- A. Certificates of Release: From authorities having jurisdiction.
- B. Certificate of Insurance: For continuing coverage.
- C. Field Report: For pest control inspection.

## 1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Schedule of Maintenance Material Items: For maintenance material submittal items specified in other Sections.

## 1.7 SUBSTANTIAL COMPLETION PROCEDURES

- A. Contractor's List of Incomplete Items: Prepare and submit a list of items to be completed and corrected (Contractor's punch list), indicating the value of each item on the list and reasons why the Work is incomplete.
- B. Submittals Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.
1. Certificates of Release: Obtain and submit releases from authorities having jurisdiction permitting Owner unrestricted use of the Work and access to services and utilities. Include occupancy permits, operating certificates, and similar releases.
  2. Submit closeout submittals specified in other Division 01 Sections, including project record documents, operation and maintenance manuals, final completion construction photographic documentation, damage or settlement surveys, property surveys, and similar final record information.
  3. Submit closeout submittals specified in individual Sections, including specific warranties, workmanship bonds, maintenance service agreements, final certifications, and similar documents.
  4. Submit maintenance material submittals specified in individual Sections, including tools, spare parts, extra materials, and similar items, and deliver to location designated by Architect. Label with manufacturer's name and model number where applicable.
    - a. Schedule of Maintenance Material Items: Prepare and submit schedule of maintenance material submittal items, including name and quantity of each item and name and number of related Specification Section. Obtain Architect's signature for receipt of submittals.
  5. Submit test/adjust/balance records.
  6. Submit sustainable design submittals required in Section 01 8113 "Sustainable Design Requirements" and in individual Sections.
  7. Submit changeover information related to Owner's occupancy, use, operation, and maintenance.
- C. Procedures Prior to Substantial Completion: Complete the following a minimum of 10 days prior to requesting inspection for determining date of Substantial Completion. List items below that are incomplete at time of request.
1. Advise Owner of pending insurance changeover requirements.
  2. Make final changeover of permanent locks and deliver keys to Owner. Advise Owner's personnel of changeover in security provisions.
  3. Complete startup and testing of systems and equipment.
  4. Perform preventive maintenance on equipment used prior to Substantial Completion.
  5. Instruct Owner's personnel in operation, adjustment, and maintenance of products, equipment, and systems. Submit demonstration and training video recordings specified in Section 01 7900 "Demonstration and Training."
  6. Advise Owner of changeover in heat and other utilities.
  7. Participate with Owner in conducting inspection and walkthrough with local emergency responders.

8. Terminate and remove temporary facilities from Project site, along with mockups, construction tools, and similar elements.
  9. Complete final cleaning requirements, including touchup painting.
  10. Touch up and otherwise repair and restore marred exposed finishes to eliminate visual defects.
- D. Inspection: Submit a written request for inspection to determine Substantial Completion a minimum of 10 days prior to date the work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare the Certificate of Substantial Completion after inspection or will notify Contractor of items, either on Contractor's list or additional items identified by Architect, that must be completed or corrected before certificate will be issued.
1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.
  2. Results of completed inspection will form the basis of requirements for final completion.

## **1.8 FINAL COMPLETION PROCEDURES**

- A. Submittals Prior to Final Completion: Before requesting final inspection for determining final completion, complete the following:
1. Submit a final Application for Payment according to Section 01 2900 "Payment Procedures."
  2. Certified List of Incomplete Items: Submit certified copy of Architect's Substantial Completion inspection list of items to be completed or corrected (punch list), endorsed and dated by Architect. Certified copy of the list shall state that each item has been completed or otherwise resolved for acceptance.
  3. Certificate of Insurance: Submit evidence of final, continuing insurance coverage complying with insurance requirements.
  4. Submit pest-control final inspection report.
- B. Inspection: Submit a written request for final inspection to determine acceptance a minimum of 10 days prior to date the work will be completed and ready for final inspection and tests. On receipt of request, Architect will either proceed with inspection or notify Contractor of unfulfilled requirements. Architect will prepare a final Certificate for Payment after inspection or will notify Contractor of construction that must be completed or corrected before certificate will be issued.
1. Reinspection: Request reinspection when the Work identified in previous inspections as incomplete is completed or corrected.

## **1.9 LIST OF INCOMPLETE ITEMS (PUNCH LIST)**

- A. Organization of List: Include name and identification of each space and area affected by construction operations for incomplete items and items needing correction including, if necessary, areas disturbed by Contractor that are outside the limits of construction.
1. Organize list of spaces in sequential order, starting with exterior areas first and proceeding from lowest floor to highest floor.
  2. Organize items applying to each space by major element, including categories for ceiling, individual walls, floors, equipment, and building systems.

3. Include the following information at the top of each page:
  - a. Project name.
  - b. Date.
  - c. Name of Architect.
  - d. Name of Contractor.
  - e. Page number.
4. Submit list of incomplete items in the following format:
  - a. MS Excel electronic file. Architect will return annotated file.
  - b. PDF electronic file. Architect will return annotated file.
  - c. Three paper copies. Architect will return two copies.

### **1.10 SUBMITTAL OF PROJECT WARRANTIES**

- A. Time of Submittal: Submit written warranties on request of Architect for designated portions of the Work where commencement of warranties other than date of Substantial Completion is indicated, or when delay in submittal of warranties might limit Owner's rights under warranty.
- B. Partial Occupancy: Submit properly executed warranties within 15 days of completion of designated portions of the Work that are completed and occupied or used by Owner during construction period by separate agreement with Contractor.
- C. Organize warranty documents into an orderly sequence based on the table of contents of Project Manual.
  1. Bind warranties and bonds in heavy-duty, three-ring, vinyl-covered, loose-leaf binders, thickness as necessary to accommodate contents, and sized to receive 8-1/2 inch x 11 inch (215 mm x 280 mm) paper.
  2. Provide heavy paper dividers with plastic-covered tabs for each separate warranty. Mark tab to identify the product or installation. Provide a typed description of the product or installation, including the name of the product and the name, address, and telephone number of Installer.
  3. Identify each binder on the front and spine with the typed or printed title "WARRANTIES," Project name, and name of Contractor.
  4. Warranty Electronic File: Scan warranties and bonds and assemble complete warranty and bond submittal package into a single indexed electronic PDF file with links enabling navigation to each item. Provide bookmarked table of contents at beginning of document.
- D. Provide additional copies of each warranty to include in operation and maintenance manuals.

## **PART 2 - PRODUCTS**

### **2.1 MATERIALS**

- A. Cleaning Agents: Use cleaning materials and agents recommended by manufacturer or fabricator of the surface to be cleaned. Do not use cleaning agents that are potentially hazardous to health or property or that might damage finished surfaces.

1. Use cleaning products that comply with Green Seal's GS-37, or if GS-37 is not applicable, use products that comply with the California Code of Regulations maximum allowable VOC levels.

### **3 PART 3 - EXECUTION**

#### **3.1 FINAL CLEANING**

- A. General: Perform final cleaning. Conduct cleaning and waste-removal operations to comply with local laws and ordinances and Federal and local environmental and antipollution regulations.
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to condition expected in an average commercial building cleaning and maintenance program. Comply with manufacturer's written instructions.
  1. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion for entire Project or for a designated portion of Project:
    - a. Clean Project site, yard, and grounds, in areas disturbed by construction activities, including landscape development areas, of rubbish, waste material, litter, and other foreign substances.
    - b. Sweep paved areas broom clean. Remove petrochemical spills, stains, and other foreign deposits.
    - c. Rake grounds that are neither planted nor paved to a smooth, even-textured surface.
    - d. Remove tools, construction equipment, machinery, and surplus material from Project site.
    - e. Remove snow and ice to provide safe access to building.
    - f. Clean exposed exterior and interior hard-surfaced finishes to a dirt-free condition, free of stains, films, and similar foreign substances. Avoid disturbing natural weathering of exterior surfaces. Restore reflective surfaces to their original condition.
    - g. Remove debris and surface dust from limited access spaces, including roofs, plenums, shafts, trenches, equipment vaults, manholes, attics, and similar spaces.
    - h. Sweep concrete floors broom clean in unoccupied spaces.
    - i. Vacuum carpet and similar soft surfaces, removing debris and excess nap; clean according to manufacturer's recommendations if visible soil or stains remain.
    - j. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compounds and other noticeable, vision-obscuring materials. Polish mirrors and glass, taking care not to scratch surfaces.
    - k. Remove labels that are not permanent.
    - l. Wipe surfaces of mechanical and electrical equipment, elevator equipment, and similar equipment. Remove excess lubrication, paint and mortar droppings, and other foreign substances.
    - m. Clean plumbing fixtures to a sanitary condition, free of stains, including stains resulting from water exposure.
    - n. Replace disposable air filters and clean permanent air filters. Clean exposed surfaces of diffusers, registers, and grilles.

- o. Clean ducts, blowers, and coils if units were operated without filters during construction or that display contamination with particulate matter on inspection.
    - 1) Clean HVAC system in compliance with NADCA Standard 1992-01. Provide written report on completion of cleaning.
  - p. Clean light fixtures, lamps, globes, and reflectors to function with full efficiency.
  - q. Leave Project clean and ready for occupancy.
- C. Pest Control: Comply with pest control requirements in Section 0 15000 "Temporary Facilities and Controls." Prepare written report.
- D. Construction Waste Disposal: Comply with waste disposal requirements in Section 01 7419 "Construction Waste Management and Disposal."

### 3.2 REPAIR OF THE WORK

- A. Complete repair and restoration operations before requesting inspection for determination of Substantial Completion.
- B. Repair or remove and replace defective construction. Repairing includes replacing defective parts, refinishing damaged surfaces, touching up with matching materials, and properly adjusting operating equipment. Where damaged or worn items cannot be repaired or restored, provide replacements. Remove and replace operating components that cannot be repaired. Restore damaged construction and permanent facilities used during construction to specified condition.
- 1. Remove and replace chipped, scratched, and broken glass, reflective surfaces, and other damaged transparent materials.
  - 2. Touch up and otherwise repair and restore marred or exposed finishes and surfaces. Replace finishes and surfaces that that already show evidence of repair or restoration.
    - a. Do not paint over "UL" and other required labels and identification, including mechanical and electrical nameplates. Remove paint applied to required labels and identification.
  - 3. Replace parts subject to operating conditions during construction that may impede operation or reduce longevity.
  - 4. Replace burned-out bulbs, bulbs noticeably dimmed by hours of use, and defective and noisy starters in fluorescent and mercury vapor fixtures to comply with requirements for new fixtures.

**- END OF SECTION -**

## - SECTION 01 7823 - OPERATION AND MAINTENANCE DATA

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for preparing operation and maintenance manuals, including the following:
  1. Operation and maintenance documentation directory.
  2. Emergency manuals.
  3. Operation manuals for systems, subsystems, and equipment.
  4. Product maintenance manuals.
  5. Systems and equipment maintenance manuals.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 3300 "Submittal Procedures" for submitting copies of submittals for operation and maintenance manuals.
- B. Section 01 9113 "General Commissioning Requirements" for verification and compilation of data into operation and maintenance manuals.

#### 1.4 DEFINITIONS

- A. System: An organized collection of parts, equipment, or subsystems united by regular interaction.
- B. Subsystem: A portion of a system with characteristics similar to a system.

#### 1.5 CLOSEOUT SUBMITTALS

- A. Manual Content: Operations and maintenance manual content is specified in individual Specification Sections to be reviewed at the time of Section submittals. Submit reviewed manual content formatted and organized as required by this Section.
  1. Architect and Commissioning Authority will comment on whether content of operations and maintenance submittals are acceptable.
  2. Where applicable, clarify and update reviewed manual content to correspond to revisions and field conditions.

- B. Format: Submit operations and maintenance manuals in the following format:
  - 1. PDF electronic file. Assemble each manual into a composite electronically indexed file. Submit on digital media acceptable to Architect.
    - a. Name each indexed document file in composite electronic index with applicable item name. Include a complete electronically linked operation and maintenance directory.
    - b. Enable inserted reviewer comments on draft submittals.
  - 2. Three paper copies. Include a complete operation and maintenance directory. Enclose title pages and directories in clear plastic sleeves. Architect will return two copies.
- C. Initial Manual Submittal: Submit draft copy of each manual at least 30 days before commencing demonstration and training. Architect and Commissioning Authority will comment on whether general scope and content of manual are acceptable.
- D. Final Manual Submittal: Submit each manual in final form prior to requesting inspection for Substantial Completion and at least 15 days before commencing demonstration and training. Architect and Commissioning Authority will return copy with comments.
  - 1. Correct or revise each manual to comply with Architect's and Commissioning Authority's comments. Submit copies of each corrected manual within 15 days of receipt of Architect's and Commissioning Authority's comments and prior to commencing demonstration and training.

## **PART 2 - PRODUCTS**

### **2.1 OPERATION AND MAINTENANCE DOCUMENTATION DIRECTORY**

- A. Directory: Prepare a single, comprehensive directory of emergency, operation, and maintenance data and materials, listing items and their location to facilitate ready access to desired information. Include a section in the directory for each of the following:
  - 1. List of documents.
  - 2. List of systems.
  - 3. List of equipment.
  - 4. Table of contents.
- B. List of Systems and Subsystems: List systems alphabetically. Include references to operation and maintenance manuals that contain information about each system.
- C. List of Equipment: List equipment for each system, organized alphabetically by system. For pieces of equipment not part of system, list alphabetically in separate list.
- D. Tables of Contents: Include a table of contents for each emergency, operation, and maintenance manual.
- E. Identification: In the documentation directory and in each operation and maintenance manual, identify each system, subsystem, and piece of equipment with same designation used in the Contract Documents. If no designation exists, assign a designation according to ASHRAE

Guideline 4, "Preparation of Operating and Maintenance Documentation for Building Systems."

## 2.2 REQUIREMENTS FOR EMERGENCY, OPERATION, AND MAINTENANCE MANUALS

- A. Organization: Unless otherwise indicated, organize each manual into a separate section for each system and subsystem, and a separate section for each piece of equipment not part of a system. Each manual shall contain the following materials, in the order listed:
  - 1. Title page.
  - 2. Table of contents.
  - 3. Manual contents.
  
- B. Title Page: Include the following information:
  - 1. Subject matter included in manual.
  - 2. Name and address of Project.
  - 3. Name and address of Owner.
  - 4. Date of submittal.
  - 5. Name and contact information for Contractor.
  - 6. Name and contact information for Architect.
  - 7. Name and contact information for Commissioning Authority.
  - 8. Names and contact information for major consultants to the Architect that designed the systems contained in the manuals.
  - 9. Cross-reference to related systems in other operation and maintenance manuals.
  
- C. Table of Contents: List each product included in manual, identified by product name, indexed to the content of the volume, and cross-referenced to Specification Section number in Project Manual.
  - 1. If operation or maintenance documentation requires more than one volume to accommodate data, include comprehensive table of contents for all volumes in each volume of the set.
  
- D. Manual Contents: Organize into sets of manageable size. Arrange contents alphabetically by system, subsystem, and equipment. If possible, assemble instructions for subsystems, equipment, and components of one system into a single binder.
  
- E. Manuals, Electronic Files: Submit manuals in the form of a multiple file composite electronic PDF file for each manual type required.
  - 1. Electronic Files: Use electronic files prepared by manufacturer where available. Where scanning of paper documents is required, configure scanned file for minimum readable file size.
  - 2. File Names and Bookmarks: Enable bookmarking of individual documents based on file names. Name document files to correspond to system, subsystem, and equipment names used in manual directory and table of contents. Group documents for each system and subsystem into individual composite bookmarked files, then create composite manual, so that resulting bookmarks reflect the system, subsystem, and equipment names in a readily navigated file tree. Configure electronic manual to display bookmark panel on opening file.

- F. Manuals, Paper Copy: Submit manuals in the form of hard copy, bound and labeled volumes.
1. Binders: Heavy-duty, three-ring, vinyl-covered, loose-leaf or post-type binders, in thickness necessary to accommodate contents, sized to hold 8-1/2 inch x 11 inch (215 mm x 280 mm) paper; with clear plastic sleeve on spine to hold label describing contents and with pockets inside covers to hold folded oversize sheets.
    - a. If two or more binders are necessary to accommodate data of a system, organize data in each binder into groupings by subsystem and related components. Cross-reference other binders if necessary to provide essential information for proper operation or maintenance of equipment or system.
    - b. Identify each binder on front and spine, with printed title "OPERATION AND MAINTENANCE MANUAL," Project title or name, and subject matter of contents, and indicate Specification Section number on bottom of spine. Indicate volume number for multiple-volume sets.
  2. Dividers: Heavy-paper dividers with plastic-covered tabs for each section of the manual. Mark each tab to indicate contents. Include typed list of products and major components of equipment included in the section on each divider, cross-referenced to Specification Section number and title of Project Manual.
  3. Protective Plastic Sleeves: Transparent plastic sleeves designed to enclose diagnostic software storage media for computerized electronic equipment.
  4. Supplementary Text: Prepared on 8-1/2 inch x 11 inch (215 mm x 280 mm) white bond paper.
  5. Drawings: Attach reinforced, punched binder tabs on drawings and bind with text.
    - a. If oversize drawings are necessary, fold drawings to same size as text pages and use as foldouts.
    - b. If drawings are too large to be used as foldouts, fold and place drawings in labeled envelopes and bind envelopes in rear of manual. At appropriate locations in manual, insert typewritten pages indicating drawing titles, descriptions of contents, and drawing locations.

### 2.3 EMERGENCY MANUALS

- A. Content: Organize manual into a separate section for each of the following:
1. Type of emergency.
  2. Emergency instructions.
  3. Emergency procedures.
- B. Type of Emergency: Where applicable for each type of emergency indicated below, include instructions and procedures for each system, subsystem, piece of equipment, and component:
1. Fire.
  2. Flood.
  3. Gas leak.
  4. Water leak.
  5. Power failure.
  6. Water outage.
  7. System, subsystem, or equipment failure.
  8. Chemical release or spill.

- C. Emergency Instructions: Describe and explain warnings, trouble indications, error messages, and similar codes and signals. Include responsibilities of Owner's operating personnel for notification of Installer, supplier, and manufacturer to maintain warranties.
- D. Emergency Procedures: Include the following, as applicable:
  - 1. Instructions on stopping.
  - 2. Shutdown instructions for each type of emergency.
  - 3. Operating instructions for conditions outside normal operating limits.
  - 4. Required sequences for electric or electronic systems.
  - 5. Special operating instructions and procedures.

## 2.4 OPERATION MANUALS

- A. Content: In addition to requirements in this Section, include operation data required in individual Specification Sections and the following information:
  - 1. System, subsystem, and equipment descriptions. Use designations for systems and equipment indicated on Contract Documents.
  - 2. Performance and design criteria if Contractor has delegated design responsibility.
  - 3. Operating standards.
  - 4. Operating procedures.
  - 5. Operating logs.
  - 6. Wiring diagrams.
  - 7. Control diagrams.
  - 8. Piped system diagrams.
  - 9. Precautions against improper use.
  - 10. License requirements including inspection and renewal dates.
- B. Descriptions: Include the following:
  - 1. Product name and model number. Use designations for products indicated on Contract Documents.
  - 2. Manufacturer's name.
  - 3. Equipment identification with serial number of each component.
  - 4. Equipment function.
  - 5. Operating characteristics.
  - 6. Limiting conditions.
  - 7. Performance curves.
  - 8. Engineering data and tests.
  - 9. Complete nomenclature and number of replacement parts.
- C. Operating Procedures: Include the following, as applicable:
  - 1. Startup procedures.
  - 2. Equipment or system break-in procedures.
  - 3. Routine and normal operating instructions.
  - 4. Regulation and control procedures.
  - 5. Instructions on stopping.

6. Normal shutdown instructions.
  7. Seasonal and weekend operating instructions.
  8. Required sequences for electric or electronic systems.
  9. Special operating instructions and procedures.
- D. Systems and Equipment Controls: Describe the sequence of operation, and diagram controls as installed.
- E. Piped Systems: Diagram piping as installed, and identify color-coding where required for identification.

## 2.5 PRODUCT MAINTENANCE MANUALS

- A. Content: Organize manual into a separate section for each product, material, and finish. Include source information, product information, maintenance procedures, repair materials and sources, and warranties and bonds, as described below.
- B. Source Information: List each product included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- C. Product Information: Include the following, as applicable:
1. Product name and model number.
  2. Manufacturer's name.
  3. Color, pattern, and texture.
  4. Material and chemical composition.
  5. Reordering information for specially manufactured products.
- D. Maintenance Procedures: Include manufacturer's written recommendations and the following:
1. Inspection procedures.
  2. Types of cleaning agents to be used and methods of cleaning.
  3. List of cleaning agents and methods of cleaning detrimental to product.
  4. Schedule for routine cleaning and maintenance.
  5. Repair instructions.
- E. Repair Materials and Sources: Include lists of materials and local sources of materials and related services.
- F. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
1. Include procedures to follow and required notifications for warranty claims.

## 2.6 SYSTEMS AND EQUIPMENT MAINTENANCE MANUALS

- A. Content: For each system, subsystem, and piece of equipment not part of a system, include source information, manufacturers' maintenance documentation, maintenance procedures, maintenance and service schedules, spare parts list and source information, maintenance service contracts, and warranty and bond information, as described below.
- B. Source Information: List each system, subsystem, and piece of equipment included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of Installer or supplier and maintenance service agent, and cross-reference Specification Section number and title in Project Manual and drawing or schedule designation or identifier where applicable.
- C. Manufacturers' Maintenance Documentation: Manufacturers' maintenance documentation including the following information for each component part or piece of equipment:
  - 1. Standard maintenance instructions and bulletins.
  - 2. Drawings, diagrams, and instructions required for maintenance, including disassembly and component removal, replacement, and assembly.
  - 3. Identification and nomenclature of parts and components.
  - 4. List of items recommended to be stocked as spare parts.
- D. Maintenance Procedures: Include the following information and items that detail essential maintenance procedures:
  - 1. Test and inspection instructions.
  - 2. Troubleshooting guide.
  - 3. Precautions against improper maintenance.
  - 4. Disassembly; component removal, repair, and replacement; and reassembly instructions.
  - 5. Aligning, adjusting, and checking instructions.
  - 6. Demonstration and training video recording, if available.
- E. Maintenance and Service Schedules: Include service and lubrication requirements, list of required lubricants for equipment, and separate schedules for preventive and routine maintenance and service with standard time allotment.
  - 1. Scheduled Maintenance and Service: Tabulate actions for daily, weekly, monthly, quarterly, semiannual, and annual frequencies.
  - 2. Maintenance and Service Record: Include manufacturers' forms for recording maintenance.
- F. Spare Parts List and Source Information: Include lists of replacement and repair parts, with parts identified and cross-referenced to manufacturers' maintenance documentation and local sources of maintenance materials and related services.
- G. Maintenance Service Contracts: Include copies of maintenance agreements with name and telephone number of service agent.
- H. Warranties and Bonds: Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.

1. Include procedures to follow and required notifications for warranty claims.

## **PART 3 – EXECUTION**

### **3.1 MANUAL PREPARATION**

- A. Operation and Maintenance Documentation Directory: Prepare a separate manual that provides an organized reference to emergency, operation, and maintenance manuals.
- B. Emergency Manual: Assemble a complete set of emergency information indicating procedures for use by emergency personnel and by Owner's operating personnel for types of emergencies indicated.
- C. Product Maintenance Manual: Assemble a complete set of maintenance data indicating care and maintenance of each product, material, and finish incorporated into the Work.
- D. Operation and Maintenance Manuals: Assemble a complete set of operation and maintenance data indicating operation and maintenance of each system, subsystem, and piece of equipment not part of a system.
  1. Engage a factory-authorized service representative to assemble and prepare information for each system, subsystem, and piece of equipment not part of a system.
  2. Prepare a separate manual for each system and subsystem, in the form of an instructional manual for use by Owner's operating personnel.
- E. Manufacturers' Data: Where manuals contain manufacturers' standard printed data, include only sheets pertinent to product or component installed. Mark each sheet to identify each product or component incorporated into the Work. If data include more than one item in a tabular format, identify each item using appropriate references from the Contract Documents. Identify data applicable to the Work and delete references to information not applicable.
  1. Prepare supplementary text if manufacturers' standard printed data are not available and where the information is necessary for proper operation and maintenance of equipment or systems.
- F. Drawings: Prepare drawings supplementing manufacturers' printed data to illustrate the relationship of component parts of equipment and systems and to illustrate control sequence and flow diagrams. Coordinate these drawings with information contained in record Drawings to ensure correct illustration of completed installation.
  1. Do not use original project record documents as part of operation and maintenance manuals.
  2. Comply with requirements of newly prepared record Drawings in Section 01 7839 "Project Record Documents."
- G. Comply with Section 01 7700 "Closeout Procedures" for schedule for submitting operation and maintenance documentation.

**- END OF SECTION -**

## - SECTION 01 7839 - PROJECT RECORD DOCUMENTS

---

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for project record documents, including the following:
  - 1. Record Drawings.
  - 2. Record Specifications.
  - 3. Record Product Data.
  - 4. Miscellaneous record submittals.

#### 1.3 RELATED REQUIREMENTS

- A. Section 01 7300 "Execution" for final property survey.
- B. Section 01 7700 "Closeout Procedures" for general closeout procedures.
- C. Section 01 7823 "Operation and Maintenance Data" for operation and maintenance manual requirements.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Record Drawings: Comply with the following:
  - 1. Number of Copies: Submit copies of record Drawings as follows:
    - a. Initial Submittal:
      - 1) Submit PDF electronic files of scanned record prints and one set of file prints.
      - 2) Architect will indicate whether general scope of changes, additional information recorded, and quality of drafting are acceptable.
    - b. Final Submittal:
      - 1) Submit PDF electronic files of scanned record prints and three set(s) of prints.
      - 2) Print each drawing, whether or not changes and additional information were recorded.
- B. Record Specifications: Submit annotated PDF electronic files of Project's Specifications, including addenda and contract modifications.
- C. Record Product Data: Submit annotated PDF electronic files and directories of each submittal.
  - 1. Where record Product Data are required as part of operation and maintenance manuals, submit duplicate marked-up Product Data as a component of manual.

- D. Miscellaneous Record Submittals: See other Specification Sections for miscellaneous record-keeping requirements and submittals in connection with various construction activities. Submit annotated PDF electronic files and directories of each submittal.
- E. Reports: Submit written report weekly indicating items incorporated into project record documents concurrent with progress of the Work, including revisions, concealed conditions, field changes, product selections, and other notations incorporated.

## **PART 2 - PRODUCTS**

### **2.1 RECORD DRAWINGS**

- A. Record Prints: Maintain one set of marked-up paper copies of the Contract Drawings and Shop Drawings, incorporating new and revised drawings as modifications are issued.
  - 1. Preparation: Mark record prints to show the actual installation where installation varies from that shown originally. Require individual or entity who obtained record data, whether individual or entity is Installer, subcontractor, or similar entity, to provide information for preparation of corresponding marked-up record prints.
    - a. Give particular attention to information on concealed elements that would be difficult to identify or measure and record later.
    - b. Accurately record information in an acceptable drawing technique.
    - c. Record data as soon as possible after obtaining it.
    - d. Record and check the markup before enclosing concealed installations.
    - e. Cross-reference record prints to corresponding archive photographic documentation.
  - 2. Content: Types of items requiring marking include, but are not limited to, the following:
    - a. Dimensional changes to Drawings.
    - b. Revisions to details shown on Drawings.
    - c. Depths of foundations below first floor.
    - d. Locations and depths of underground utilities.
    - e. Revisions to routing of piping and conduits.
    - f. Revisions to electrical circuitry.
    - g. Actual equipment locations.
    - h. Duct size and routing.
    - i. Locations of concealed internal utilities.
    - j. Changes made by Change Order or Construction Change Directive.
    - k. Changes made following Architect's written orders.
    - l. Details not on the original Contract Drawings.
    - m. Field records for variable and concealed conditions.
    - n. Record information on the Work that is shown only schematically.
  - 3. Mark the Contract Drawings and Shop Drawings completely and accurately. Use personnel proficient at recording graphic information in production of marked-up record prints.
  - 4. Mark record sets with erasable, red-colored pencil. Use other colors to distinguish between changes for different categories of the Work at same location.
  - 5. Mark important additional information that was either shown schematically or omitted from original Drawings.
  - 6. Note Construction Change Directive numbers, alternate numbers, Change Order numbers, and similar identification, where applicable.

- B. Record Digital Data Files: Immediately before inspection for Certificate of Substantial Completion, review marked-up record prints with Architect. When authorized, prepare a full set of corrected digital data files of the Contract Drawings, as follows:
1. Format: Same digital data software program, version, and operating system as the original Contract Drawings.
  2. Format: DWG Version, Microsoft Windows operating system.
  3. Format: Annotated PDF electronic file with comment function enabled.
  4. Incorporate changes and additional information previously marked on record prints. Delete, redraw, and add details and notations where applicable.
  5. Refer instances of uncertainty to Architect for resolution.
  6. Architect will furnish Contractor one set of digital data files of the Contract Drawings for use in recording information.
    - a. See Section 01 3300 "Submittal Procedures" for requirements related to use of Architect's digital data files.
    - b. Architect will provide data file layer information. Record markups in separate layers.
- C. Newly Prepared Record Drawings: Prepare new Drawings instead of preparing record Drawings where Architect determines that neither the original Contract Drawings nor Shop Drawings are suitable to show actual installation.
1. New Drawings may be required when a Change Order is issued as a result of accepting an alternate, substitution, or other modification.
  2. Consult Architect for proper scale and scope of detailing and notations required to record the actual physical installation and its relation to other construction. Integrate newly prepared record Drawings into record Drawing sets; comply with procedures for formatting, organizing, copying, binding, and submitting.
- D. Format: Identify and date each record Drawing; include the designation "PROJECT RECORD DRAWING" in a prominent location.
1. Record Prints: Organize record prints and newly prepared record Drawings into manageable sets. Bind each set with durable paper cover sheets. Include identification on cover sheets.
  2. Format: Annotated PDF electronic file with comment function enabled.
  3. Record Digital Data Files: Organize digital data information into separate electronic files that correspond to each sheet of the Contract Drawings. Name each file with the sheet identification. Include identification in each digital data file.
  4. Identification: As follows:
    - a. Project name.
    - b. Date.
    - c. Designation "PROJECT RECORD DRAWINGS."
    - d. Name of Architect.
    - e. Name of Contractor.

## 2.2 RECORD SPECIFICATIONS

- A. Preparation: Mark Specifications to indicate the actual product installation where installation varies from that indicated in Specifications, addenda, and contract modifications.

1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
  2. Mark copy with the proprietary name and model number of products, materials, and equipment furnished, including substitutions and product options selected.
  3. Record the name of manufacturer, supplier, Installer, and other information necessary to provide a record of selections made.
  4. For each principal product, indicate whether record Product Data has been submitted in operation and maintenance manuals instead of submitted as record Product Data.
  5. Note related Change Orders, record Product Data, and record Drawings where applicable.
- B. Format: Submit record Specifications as annotated PDF electronic file.

### **2.3 RECORD PRODUCT DATA**

- A. Preparation: Mark Product Data to indicate the actual product installation where installation varies substantially from that indicated in Product Data submittal.
1. Give particular attention to information on concealed products and installations that cannot be readily identified and recorded later.
  2. Include significant changes in the product delivered to Project site and changes in manufacturer's written instructions for installation.
  3. Note related Change Orders, record Specifications, and record Drawings where applicable.
- B. Format: Submit record Product Data as annotated PDF electronic file.
1. Include record Product Data directory organized by Specification Section number and title, electronically linked to each item of record Product Data.

### **2.4 MISCELLANEOUS RECORD SUBMITTALS**

- A. Assemble miscellaneous records required by other Specification Sections for miscellaneous record keeping and submittal in connection with actual performance of the Work. Bind or file miscellaneous records and identify each, ready for continued use and reference.
- B. Format: Submit miscellaneous record submittals as PDF electronic file.
1. Include miscellaneous record submittals directory organized by Specification Section number and title, electronically linked to each item of miscellaneous record submittals.

## **PART 3 - EXECUTION**

### **3.1 RECORDING AND MAINTENANCE**

- A. Recording: Maintain one copy of each submittal during the construction period for project record document purposes. Post changes and revisions to project record documents as they occur; do not wait until end of Project.
- B. Maintenance of Record Documents and Samples: Store record documents and Samples in the field office apart from the Contract Documents used for construction. Do not use project record documents for construction purposes. Maintain record documents in good order and

PROJECT NO.  
#CA23-2526

STEM CLASSROOM HVAC UPGRADES  
WEST VALLEY COLLEGE, SARATOGA, CA

in a clean, dry, legible condition, protected from deterioration and loss. Provide access to project record documents for Architect's reference during normal working hours.

**- END OF SECTION -**

## - SECTION 01 7900 - DEMONSTRATION AND TRAINING

---

### PART 1 – GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section includes administrative and procedural requirements for instructing Owner's personnel, including the following:
  - 1. Demonstration of operation of systems, subsystems, and equipment.
  - 2. Training in operation and maintenance of systems, subsystems, and equipment.
  - 3. Demonstration and training video recordings.

#### 1.3 INFORMATIONAL SUBMITTALS

- A. Instruction Program: Submit outline of instructional program for demonstration and training, including a list of training modules and a schedule of proposed dates, times, length of instruction time, and instructors' names for each training module. Include learning objective and outline for each training module.
  - 1. Indicate proposed training modules using manufacturer-produced demonstration and training video recordings for systems, equipment, and products in lieu of video recording of live instructional module.
- B. Qualification Data: For facilitator, instructor, videographer.
- C. Attendance Record: For each training module, submit list of participants and length of instruction time.
- D. Evaluations: For each participant and for each training module, submit results and documentation of performance-based test.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Demonstration and Training Video Recordings: Submit two copies within seven days of end of each training module.
  - 1. Identification: On each copy, provide an applied label with the following information:
    - a. Name of Project.
    - b. Name and address of videographer.
    - c. Name of Architect.

- d. Name of Contractor.
- e. Date of video recording.
2. Transcript: Prepared and bound in format matching operation and maintenance manuals. Mark appropriate identification on front and spine of each binder. Include a cover sheet with same label information as the corresponding video recording. Include name of Project and date of video recording on each page.
3. Transcript: Prepared in PDF electronic format. Include a cover sheet with same label information as the corresponding video recording and a table of contents with links to corresponding training components. Include name of Project and date of video recording on each page.
4. At completion of training, submit complete training manual(s) for Owner's use in PDF electronic file format on compact disc.

### 1.5 QUALITY ASSURANCE

- A. Facilitator Qualifications: A firm or individual experienced in training or educating maintenance personnel in a training program similar in content and extent to that indicated for this Project, and whose work has resulted in training or education with a record of successful learning performance.
- B. Instructor Qualifications: A factory-authorized service representative, complying with requirements in Section 01 4000 "Quality Requirements," experienced in operation and maintenance procedures and training.
- C. Videographer Qualifications: A professional videographer who is experienced photographing demonstration and training events similar to those required.
- D. Preinstruction Conference: Conduct conference at Project site to comply with requirements in Section 01 3100 "Project Management and Coordination." Review methods and procedures related to demonstration and training including, but not limited to, the following:
  1. Inspect and discuss locations and other facilities required for instruction.
  2. Review and finalize instruction schedule and verify availability of educational materials, instructors' personnel, audiovisual equipment, and facilities needed to avoid delays.
  3. Review required content of instruction.
  4. For instruction that must occur outside, review weather and forecasted weather conditions and procedures to follow if conditions are unfavorable.

### 1.6 COORDINATION

- A. Coordinate instruction schedule with Owner's operations. Adjust schedule as required to minimize disrupting Owner's operations and to ensure availability of Owner's personnel.
- B. Coordinate instructors, including providing notification of dates, times, length of instruction time, and course content.

- C. Coordinate content of training modules with content of approved emergency, operation, and maintenance manuals. Do not submit instruction program until operation and maintenance data has been reviewed and approved by Architect.

## **PART 2 - PRODUCTS**

### **2.1 INSTRUCTION PROGRAM**

- A. Program Structure: Develop an instruction program that includes individual training modules for each system and for equipment not part of a system, as required by individual Specification Sections.
  
- B. Training Modules: Develop a learning objective and teaching outline for each module. Include a description of specific skills and knowledge that participant is expected to master. For each module, include instruction for the following as applicable to the system, equipment, or component:
  - 1. Basis of System Design, Operational Requirements, and Criteria: Include the following:
    - a. System, subsystem, and equipment descriptions.
    - b. Performance and design criteria if Contractor is delegated design responsibility.
    - c. Operating standards.
    - d. Regulatory requirements.
    - e. Equipment function.
    - f. Operating characteristics.
    - g. Limiting conditions.
    - h. Performance curves.
  - 2. Documentation: Review the following items in detail:
    - a. Emergency manuals.
    - b. Operations manuals.
    - c. Maintenance manuals.
    - d. Project record documents.
    - e. Identification systems.
    - f. Warranties and bonds.
    - g. Maintenance service agreements and similar continuing commitments.
  - 3. Emergencies: Include the following, as applicable:
    - a. Instructions on meaning of warnings, trouble indications, and error messages.
    - b. Instructions on stopping.
    - c. Shutdown instructions for each type of emergency.
    - d. Operating instructions for conditions outside of normal operating limits.
    - e. Sequences for electric or electronic systems.
    - f. Special operating instructions and procedures.
  - 4. Operations: Include the following, as applicable:
    - a. Startup procedures.
    - b. Equipment or system break-in procedures.
    - c. Routine and normal operating instructions.
    - d. Regulation and control procedures.
    - e. Control sequences.
    - f. Safety procedures.
    - g. Instructions on stopping.

- h. Normal shutdown instructions.
  - i. Operating procedures for emergencies.
  - j. Operating procedures for system, subsystem, or equipment failure.
  - k. Seasonal and weekend operating instructions.
  - l. Required sequences for electric or electronic systems.
  - m. Special operating instructions and procedures.
5. Adjustments: Include the following:
    - a. Alignments.
    - b. Checking adjustments.
    - c. Noise and vibration adjustments.
    - d. Economy and efficiency adjustments.
  6. Troubleshooting: Include the following:
    - a. Diagnostic instructions.
    - b. Test and inspection procedures.
  7. Maintenance: Include the following:
    - a. Inspection procedures.
    - b. Types of cleaning agents to be used and methods of cleaning.
    - c. List of cleaning agents and methods of cleaning detrimental to product.
    - d. Procedures for routine cleaning
    - e. Procedures for preventive maintenance.
    - f. Procedures for routine maintenance.
    - g. Instruction on use of special tools.
  8. Repairs: Include the following:
    - a. Diagnosis instructions.
    - b. Repair instructions.
    - c. Disassembly; component removal, repair, and replacement; and reassembly instructions.
    - d. Instructions for identifying parts and components.
    - e. Review of spare parts needed for operation and maintenance.

## **PART 3 – EXECUTION**

### **3.1 PREPARATION**

- A. Assemble educational materials necessary for instruction, including documentation and training module. Assemble training modules into a training manual organized in coordination with requirements in Section 01 7823 "Operation and Maintenance Data".
- B. Set up instructional equipment at instruction location.

### **3.2 INSTRUCTION**

- A. Facilitator: Engage a qualified facilitator to prepare instruction program and training modules, to coordinate instructors, and to coordinate between Contractor and Owner for number of participants, instruction times, and location.

- B. Engage qualified instructors to instruct Owner's personnel to adjust, operate, and maintain systems, subsystems, and equipment not part of a system.
  - 1. Architect will furnish an instructor to describe basis of system design, operational requirements, criteria, and regulatory requirements.
  - 2. Owner will furnish an instructor to describe Owner's operational philosophy.
  - 3. Owner will furnish Contractor with names and positions of participants.
- C. Scheduling: Provide instruction at mutually agreed on times. For equipment that requires seasonal operation, provide similar instruction at start of each season.
  - 1. Schedule training with Owner with at least seven days' advance notice.
- D. Training Location and Reference Material: Conduct training on-site in the completed and fully operational facility using the actual equipment in-place. Conduct training using final operation and maintenance data submittals.
- E. Evaluation: At conclusion of each training module, assess and document each participant's mastery of module by use of a demonstration performance-based test.
- F. Cleanup: Collect used and leftover educational materials and give to Owner. Remove instructional equipment. Restore systems and equipment to condition existing before initial training use.

### 3.3 DEMONSTRATION AND TRAINING VIDEO RECORDINGS

- A. General: Engage a qualified commercial videographer to record demonstration and training video recordings. Record each training module separately. Include classroom instructions and demonstrations, board diagrams, and other visual aids, but not student practice.
  - 1. At beginning of each training module, record each chart containing learning objective and lesson outline.
- B. Video: Provide minimum 640 x 480 video resolution converted to .mp4 format file type or other format file type acceptable to Owner, on electronic media.
  - 1. Electronic Media: Read-only format compact disc acceptable to Owner, with commercial-grade graphic label.
  - 2. File Hierarchy: Organize folder structure and file locations according to project manual table of contents. Provide complete screen-based menu.
  - 3. File Names: Utilize file names based upon name of equipment generally described in video segment, as identified in Project specifications.
  - 4. Contractor and Installer Contact File: Using appropriate software, create a file for inclusion on the Equipment Demonstration and Training DVD that describes the following for each Contractor involved on the Project, arranged according to Project table of contents:
    - a. Name of Contractor/Installer.
    - b. Business address.
    - c. Business phone number.
    - d. Point of contact.
    - e. E-mail address.

- C. Recording: Mount camera on tripod before starting recording, unless otherwise necessary to adequately cover area of demonstration and training. Display continuous running time.
  - 1. Film training session(s) in segments not to exceed 15 minutes.
    - a. Produce segments to present a single significant piece of equipment per segment.
    - b. Organize segments with multiple pieces of equipment to follow order of Project Manual table of contents.
    - c. Where a training session on a particular piece of equipment exceeds 15 minutes, stop filming and pause training session. Begin training session again upon commencement of new filming segment.
  
- D. Light Levels: Verify light levels are adequate to properly light equipment. Verify equipment markings are clearly visible prior to recording.
  - 1. Furnish additional portable lighting as required.
  
- E. Narration: Describe scenes on video recording by audio narration by microphone or by dubbing audio narration off-site after video recording is recorded. Include description of items being viewed.
  
- F. Transcript: Provide a transcript of the narration. Display images and running time captured from videotape opposite the corresponding narration segment.
  
- G. Preproduced Video Recordings: Provide video recordings used as a component of training modules in same format as recordings of live training.

**- END OF SECTION -**

## - SECTION 01 9113 -

# GENERAL COMMISSIONING REQUIREMENTS

---

## PART 1 - GENERAL

### 1.1 SUMMARY

- A. Work Included:
  - 1. Scope of systems and equipment to be commissioned.
  - 2. Commissioning duties and procedures at the site.

### 1.2 RELATED SECTIONS

- A. Division 01, General Requirements applies to this Section.
- B. Contents of Division 22, 23, 26, and 28 apply to this Section.
- C. In addition, reference the following:
  - 1. 22 08 00, Commissioning of Plumbing
  - 2. 23 08 00, Commissioning of HVAC
  - 3. 26 08 05, Commissioning of Electrical

### 1.3 REFERENCES AND STANDARDS

- A. References and Standards as required by:
  - 1. Division 01, General Requirements.
  - 2. 22 08 00, Commissioning of Plumbing
  - 3. 23 08 00, Commissioning of HVAC
  - 4. 26 08 05, Commissioning of Electrical
- B. In addition, meet the following:
  - 1. Current edition of the ASHRAE Guideline 0, The Commissioning Process.

### 1.4 SUBMITTALS

- A. Submittals as required by:
  - 1. Division 01, General Requirements.
  - 2. 22 08 00, Commissioning of Plumbing
  - 3. 23 08 00, Commissioning of HVAC
  - 4. 26 08 05, Commissioning of Electrical

### 1.5 QUALITY ASSURANCE

- A. Quality assurance as required by:
  - 1. Division 01, General Requirements.
  - 2. 22 08 00, Commissioning of Plumbing
  - 3. 23 08 00, Commissioning of HVAC
  - 4. 26 08 05, Commissioning of Electrical

### 1.6 WARRANTY

- A. Warranty of materials and workmanship as required by Division 01, General Requirements.
  - 1. Division 01, General Requirements.
  - 2. 22 08 00, Commissioning of Plumbing
  - 3. 23 08 00, Commissioning of HVAC
  - 4. 26 08 05, Commissioning of Electrical

## 1.7 DEFINITIONS

- A. Commissioning Authority: The Commissioning Authority is the person or entity referred to throughout the Contract Documents as if singular in number who works with the Owner's Authorized Representative under a separate Contract.
- B. Commissioning:
  - 1. Commissioning is a process for achieving, verifying, and documenting that performance of a building and its various energy consuming systems meets the Design Engineer's design intent and the Owner's operational needs.
  - 2. Commissioning includes tests for the operation of equipment and building systems to ensure that they operate as designed by the Design Engineer, and meet the needs of the building throughout the entire range of operating conditions.
  - 3. Commissioning is a cooperative effort that requires participation by the Owner's Authorized Representative, General Contractor, system and equipment installers, building automation system installer, Testing and Balancing Agency, equipment manufacturers' representatives, Architect, Architect's design engineers, and Commissioning Authority.
- C. Owner's Project Requirements (OPR): Document that details the functional requirements and expectations of how the building will be used and operated. This may include project location, goals, cost considerations, equipment manufacturers, and environmental control requirements.
- D. Basis of Design (BoD): A document that records concepts, calculations, decisions, and product selections used to meet the OPR and to satisfy applicable regulatory requirements, standards, and guidelines.
- E. Commissioning Procedures:
  - 1. Inspection and testing procedures that are written by the Commissioning Authority for equipment and systems within the scope of commissioning.
  - 2. Inspection checklists typically address items of installation compliance with design intent and approved submittals.
  - 3. Functional performance test procedures typically address all sequences for normal and emergency equipment and system operation. These procedures consist of a mix of One- Time Tests and Continuous Measurement.
  - 4. One-Time Tests: Functional performance tests of equipment and systems that are performed by forcing specific conditions that are intended to trigger specific responses, per the design intent.
- F. Continuous Measurements:
  - 1. Functional performance tests of equipment and systems that are performed by observing parameters of normal operation over an extended period. This is typically accomplished by means of the BAS trend logging capabilities, by monitoring with stand-alone data logging equipment, or by some combination of both.
  - 2. Temperature conditions in occupied spaces, control stability, and lighting levels in areas with daylighting controls are three typical subjects of continuous measurement.
- G. Commissioning Plan: The document, provided by the Commissioning Authority, that states the required tests for all equipment and systems within the scope of commissioning.
- H. Commissioning Meetings: Issues related to commissioning will be discussed as required during regularly scheduled progress meetings.

## 1.8 PERFORMANCE REQUIREMENTS

- A. Testing, inspecting and performance monitoring tasks specified in this Section and in Sections 22 08 00, 23 08 00, and 26 08 05 are the responsibility of the Commissioning Authority, unless specifically indicated otherwise, and not part of the General Construction Contract. These

tasks are included in these Sections for the Contractor's information, so the Contractor can understand the standards of system performance that are required and more effectively coordinate with the process of commissioning.

- B. The Commissioning Authority will verify for that commissioned mechanical, plumbing, electrical, and controls system function interactively and in compliance with the Project design intent, and to facilitate orderly and efficient transfer of building operating systems to the Owner.
- C. Commissioning does not relieve the Contractor of Contract obligations.

### **1.9 EQUIPMENT AND SYSTEMS TO BE COMMISSIONED**

- A. Systems:
  - 1. HVAC Equipment
  - 2. Instrumentation and Control System
  - 3. Domestic Hot Water Equipment
  - 4. Automatic Lighting Controls (LCP, Daylighting, Occupancy Sensors)
  - 5. Electrical Service and Distribution
  - 6. Energy and Water Use Metering

### **1.10 COMMISSIONING DUTIES**

- A. Duties of Owner: Provide the OPR to the Architect/Engineer and Commissioning Authority prior to design development.
- B. Duties of Architect:
  - 1. Attend commissioning portion of Progress Meetings as necessary.
  - 2. Lead the design team in assisting the resolution of deficiencies.
- C. Duties of Architect's Mechanical Engineer:
  - 1. Attend commissioning portion of Progress Meetings as necessary.
  - 2. At the request of either the Owner's Authorized Representative or the Commissioning Authority, review Commissioning Procedures and submit comments to Owner's Authorized Representative.
  - 3. Assist in resolution of problems and deficiencies that are discovered during commissioning.
  - 4. Participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid.
- D. Duties of Architect's Electrical Engineer:
  - 1. Attend commissioning portion of Project Meetings as necessary.
  - 2. At request of either the Owner's Authorized Representative or the Commissioning Authority, review Commissioning Procedures and submit comments to Owner's Authorized Representative.
  - 3. Assist in resolution of problems and deficiencies that are discovered during commissioning.
  - 4. Participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid.
- E. Duties of Commissioning Authority:
  - 1. Attend commissioning portion of Project Meetings as necessary, minimum two meetings.
  - 2. Review the design set documents for the commissioned systems at 75 percent construction set document submission.
  - 3. Review Contractor's and Control Contractor's submittals related to commissioned systems, and make comments through Architect.
  - 4. Provide plan to Owner's Authorized Representative for review and comment.

5. Utilize web based Commissioning software to manage all commissioning related checklists, tests, issues, and observation reports.
  6. Prepare commissioning procedures for each commissioned system based on actual system configuration.
  7. Commissioning Procedures written by Commissioning Authority will include, in field data collection format, the detailed test procedures, test conditions, and criteria for acceptance of test results.
  8. Submit any commissioning procedures that are written by Commissioning Authority to the Owner's Authorized Representative for review and approval at least 1 week prior to scheduled field testing.
  9. Provide personnel experienced in technical aspects of each system to be commissioned for execution of tests.
  10. BAS Sequence Demonstration:
    - a. Witness the Control Contractor's demonstration of their sequence tests.
    - b. If any of the demonstrated sequences fails to operate per the controls submittal, witness the repeat demonstration after corrective action has been taken.
  11. Execute the Commissioning Procedures.
  12. Perform periodic site visits and submit Site Observation Reports as required, but within 3 days of noting any deficiency.
  13. Submit to Owner's Authorized Representative a weekly written report of commissioning progress, unresolved deficiencies, and projected inspection, and test schedule during field testing.
  14. Take the lead in timely evaluation of deficiencies, and advise Owner's Authorized Representative on resolution.
  15. Assist in resolving commissioned system disputes by performing research to determine the scope of the dispute, and informing the involved parties on possible solutions to disputes.
  16. During the systems warranty period(s) CxA to retest any systems that had their full testing deferred during the initial functional testing due to the lack of peak season conditions. This testing must ensure that all system sequences of operations and capacity have been verified.
  17. Verify that the Owner's maintenance personnel are adequately trained as per the Contract Documents and the OPR.
  18. Prepare a Commissioning Report that includes a summary of overall commissioning process, including deficiencies found, deficiency corrections, unresolved deficiencies, approved equipment and systems, discrepancies between final design intent and as-built systems, completed commissioning checklists, test documentation, and other commissioning documentation.
  19. Develop a Current Facility Requirements and Operations Plan that provides the facilities operations staff the information necessary to understand and operate the commissioned systems.
- F. Duties of General Contractor:
1. Attend commissioning portion of Project Meetings as necessary, minimum four meetings.
  2. Participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid.
  3. Coordinate and direct system installers in executing their commissioning tasks.
  4. Direct subcontractors to participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid. A desktop, laptop, tablet or iPad will be required.

5. Coordinate with Commissioning Authority on integration of construction and commissioning schedules.
  6. Oversee and perform documentation requirements for all Pre-Functional Checklists.
  7. Notify Commissioning Authority when all the following has been achieved. It is permissible, with prior approval by Commissioning Authority, to provide notification for individual systems as the following are all completed for each system.
    - a. All controls point-to-point and sequence checkout is complete.
    - b. All test and balancing is complete.
    - c. Normal equipment schedules have been activated.
    - d. All control overrides and temporary valves have been returned to normal automatic control.
    - e. All manual isolation valves have been left open.
    - f. Class II ductwork distribution systems have been pressure tested.
    - g. Luminaires are installed with operational daylighting controls and occupancy sensors.
    - h. Distribution boards, including overcurrent devices, containing breakers over 600 amps, are installed.
    - i. Building inspector acceptance of emergency lighting system following their site inspection.
  8. Provide all startup, flushing, pressure testing, etc results/reports for commissioned systems.
- G. Duties of Installer's and Manufacturer's Representatives:
1. Attend commissioning portion of Project Meetings as necessary, minimum two meetings.
  2. Participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid.
  3. Within three months of the award of the Contract, as part of the required submittals for the contract, Contractor submits manufacturer's startup and installation procedures as well as controls point-to-point and sequence checkout and provides in checkset format for each piece of equipment and controls.
  4. Demonstrate proper system operation in the presence of the Commissioning Authority.
  5. Commissioning does not relieve installers from obligations to complete Work as required by Contract Documents.
- H. Duties of BAS Installer:
1. Attend commissioning portion of project meetings as necessary, minimum two meetings.
  2. Participate and respond to commissioning related issues by using the Commissioning Authority's web based commissioning software Facility Grid.
  3. Review and approve Commissioning Procedures as relevant to controls work.
  4. Point-to-Point Checkout:
    - a. Perform point-to-point checkout and calibration of all energy management system points.
    - b. Document checkout and calibration on forms as approved by mechanical designer, and/or Commissioning Authority.
    - c. Submit three copies of the completed point-to-point checkout forms to the Owner's Authorized Representative within five working days of completion of field checkout. Distribute copies to the Commissioning Authority and the designer.
  5. Control Sequence Testing:
    - a. Prepare control sequence test procedure forms to a degree of rigor comparable to the Commissioning Authority's Commissioning Procedures.

- b. Submit test procedure forms to the Commissioning Authority for approval at least two weeks prior to intended sequence testing. At the contractor's option, it is acceptable to use the Commissioning Authority's Commissioning Procedures, substituting one- time tests for continuous measurement wherever applicable. However, it is still necessary to submit any edited Commissioning Authority Commissioning Procedures as least two weeks prior to intended sequence testing.
          - c. Submit the completed sequence testing forms to the Owner's Authorized Representative. The Owner's Authorized Representative distributes copies to the Commissioning Authority and the designer.
  6. Submit to Commissioning Authority, prior to Sequence Demonstration, two copies of installed control Drawings, sequence narratives, control wiring diagrams, and program code or block diagrams.
  7. Sequence Demonstration:
    - a. After completing and documenting all required sequence tests with own staff, demonstrate sequence tests to the Commissioning Authority. Demonstration is to be performed by the BAS installer's programmer who programmed the control system for this specific project.
    - b. If any of the demonstrated sequences fails to operate per the controls submittal, take corrective action and demonstrate the failed sequence tests to the Commissioning Authority a second time.
    - c. If the Control Contractor fails to demonstrate proper sequence operation in any of the second round of sequence tests, the Commissioning Authority's costs for witnessing all further demonstration of that sequence may be assigned to the Control Contractor by the Owner as a deduct to their contracted price. The Control Contractor will not be responsible for costs related to failure due to design or to other factors beyond their control, though it is expected to call any design concerns (and other factors beyond their control that might cause failure) to the attention of the Commissioning Authority and the Owner's Authorized Representative.
  8. Assist Commissioning Authority with programming of the energy management system for trend logs to support functional performance testing during field testing.
  9. Assist Commissioning Authority with execution of the Commissioning Procedures. Commissioning Authority will present test schedule at Progress Meeting at least one week ahead of scheduled tests.
  10. The Commissioning Authority, acting with Owner authority, may request the Control Contractor to assist with or perform minor loop tuning adjustments, set point and schedule changes, and other similar minor field corrections.
  11. Recommended changes to the controls sequences, program code, and recommendations for additional points must go through the Owner's Authorized Representative and the designer. The designer is the final authority on all recommended sequence changes, and will submit such changes to the Owner's Authorized Representative for implementation.
  12. Submit to Owner's Authorized Representative, at least two weeks prior to Final Completion, two copies of as-built version of points list, including I/O and virtual points, controls Drawings, program printout, and sequence narratives.
  13. Participate in resolution of problems and deficiencies that are discovered during commissioning.
- I. Duties of Balancer:
1. Attend commissioning portion of Project Meetings as necessary, minimum two meetings.

2. Participate in resolution of problems and deficiencies that are discovered during commissioning.
3. Assist Commissioning Authority with execution of commissioning procedures.
4. Demonstrate accuracy of final balance report in the presence of the Commissioning Authority. This will be a 10 percent spot check.

## **PART 2 - PRODUCTS (NOT USED)**

## **PART 3 – EXECUTION**

### **3.1 COMMISSIONING PROCEDURES AT THE SITE**

- A. Testing Techniques:
  1. Each testing procedure may use a variety of techniques. Generally it is preferred to observe new and existing equipment and systems during normal operation.
  2. When functional and emergency modes of operation occur rarely or seasonally, if possible, simulate the conditions that trigger these operational modes.
  3. Simulation of conditions may involve changing set points, changing schedules, simulating pneumatic system pressures or energy management system voltages and currents, disconnecting power, jumpering contacts, or other such procedures.
  4. Whenever temporary adjustments are made, restore the system to its original condition once tests are completed.
  5. When testing requires observing equipment operation over an extended period, use the building energy management system's trend logging capabilities or independent monitoring equipment.
  6. Do not use the building automation system trend logging in the commissioning process prior to point-to-point checkout by Controls Contractor and approval of point-to-point checkout by Commissioning Authority.
  7. Measurement of room lighting levels during evening hours with only artificial lighting, during mid-morning, around noon and mid-afternoon with only natural lighting and with both natural and artificial lighting. Repeat same measurements following calibration of room daylighting sensor.
- B. Commissioning Documentation:
  1. The Contractors are required to perform startup and checkout of their systems (prefunctional testing) and document the results in Facility Grid. The Commissioning Authority will provide electronic forms that may be used by the Contractors. The Contractors may use their own forms if they contain all the required information on the Commissioning Authority's forms, but prior approval must be obtained.
    - a. Where numeric data is required, a narrative entry or simple check-off is not acceptable.
    - b. Annotate trend logs and monitored data as necessary to clarify meaning, and attach to relevant test reports.
    - c. Do not attach irrelevant data to test reports.
  2. The Contractor sends the startup and checkout forms to the Commissioning Authority when they are complete and functional. The Contractor sends a "Certificate of Readiness" with the forms which will signal that functional testing can begin.
  3. The technician who performed the pretesting and checkout of the system completes the Pre-Functional Checklists using the web based commissioning software Facility Grid.
  4. E-mail an "issues log" weekly to inform the design and construction team of issues that need resolution. The "issues log" will open and close items as they are discovered and resolved until all items are closed.

5. The Commissioning Authority will assemble all the information from the Commissioning Plan (test forms, trend logs, issues log, and basis of design) into a final Commissioning Report.
- C. Coordination of Commissioning and Equipment Startup: Do not initiate functional performance testing for equipment or systems in advance of their startup and checkout by affected equipment or system installers and manufacturers' representatives.
- D. Test Acceptance Criteria:
1. Acceptance Criteria are the test results that are required before the mode of performance or inspection item in question will be considered acceptable.
  2. Any procedures in Specification Sections 22 08 00, 23 08 00, or 26 08 05 that begin with "Verify that..." have an implied acceptance criterion that the sequence as stated is proven to occur and is documented with visual observation notes, measurements, trend logs, and/or monitored data.
  3. Acceptance criteria for other functional modes and checklist items are as stated in each section of the Commissioning Plan.
  4. Input will be sought when necessary from the Architect's Engineer to determine if test results indicate compliance with Design Intent.
  5. The Commissioning Authority will recommend acceptance or rejection of commissioned system work based on test results.
- E. Resolution of Deficiencies:
1. Adjust, repair, or replace defective equipment and systems to meet Commissioning Procedure Acceptance Criteria as directed by Owner's Authorized Representative.
  2. Inform the Owner's Authorized Representative and Commissioning Authority of the date for completion of corrective activities.
  3. If the date for completion of corrective work passes without resolution of deficiencies, Owner's Authorized Representative reserves the right to obtain supplementary services and equipment to correct the problem as indicated in General Conditions.
- F. Rechecking and Retesting Charges:
1. In the event of a second failure of a specific commissioning procedure item or test, the responsible party may be assessed charges by Owner's Authorized Representative.
  2. Charges will be based on each party's actual expenses, including normal hourly billing rates for preparation, testing, and travel time, and materials, equipment rental, and travel expenses as applicable.
- G. Construction and Acceptance Milestones for Tasks Related to Commissioning:
1. Equipment, ductwork, and piping installation.
  2. Equipment startup.
  3. Pre-functional checklists.
  4. Substantial completion.
  5. Point-to-point checkout and sequence testing of controls.
  6. Test and balance.
  7. Commissioning field testing.
  8. Owner training.
  9. Occupant move-in.
  10. Final completion.
  11. Seasonal testing.
  12. Commissioning report submittal.

**- END OF SECTION -**